



Operating Permit - Elevating Device
Permis d'exploitation - Appareil élévateur

Issued under the Elevators and Lifts Act
Délivré en vertu de la Loi sur les ascenseurs et les monte-charge

Technical Inspection Services
Services d'inspection technique
Justice and Public Safety
Justice et sécurité publique

Permit No./N° de Permis: 1170-028

Issued To: **ANGLOPHONE WEST SCHOOL DISTRICT**
Délivré à:

Expiry Date: **2026/04/11**
Date d'échéance:

Mailing Address: **1135 PROSPECT ST**
Adresse d'envoi: **FREDERICTON NB**
E3B 3B9

Device No: **1170**
N° d'appareil:

Operating Address: **KESWICK VALLEY MEMORIAL SCHOOL**
Adresse d'appareil: **20 617 HWY**
BURTTS CORNER NB

Site No: **1559-01**
N° du site:

Type of Device: **PASSENGER ELEVATOR**
Type d'attraction: **ASCENSEUR**

Capacity: **1500** or **9** Persons
Capacité: ou Personnes

Description:
Description:

Chief Elevator Inspector/Inspecteur en chef des élévateurs

Brunswick Fyr Systems Division
A Day & Night Company
231 Edinburgh Drive, Moncton NB E1E 2K9
Telephone: (506) 853-3473 Fax: (506) 857-3192
Toll Free: 1-877-853-2473 Email: systems@brunswickfyr.ca

Inspection Report

Service Date Dec 17th, 2024

SYS 21

CUSTOMER: SCH014
KESWICK VALLEY MEMORIAL SCHOOL
ANGLOPHONE WEST
1135 PROSPECT STREET
FREDERICTON NB E3B 3B9

LOCATION SYS
KESWICK VALLEY MEMORIAL SCHOOL
20 ROUTE 617
BURTT'S CORNER NB E6L 2X3

CONTACT:
PHONE: 506-453-5454

CONTACT: KIM
PHONE: 506-756-9968

EMAIL: peggy.barkwell@bed.nb.ca; nadine.peters@gnb.ca; angus.smith@bed.nb.ca

---SERVICE INFORMATION---

DATE OF LAST SERVICE: May 13, 2024 ANNIVERSARY DATE: 05 / 11
FREQUENCY: 2

ROUTE: 87 (11/23) / 13 (8/21)

SYSTEM: ANSUL R102 3 GALLON WCS WW HOOD @ 3 FLOWPOINTS ✓

Hydro Test Date: 2889

System(s) deficiencies? YES NO Meet UL300? NO ✓

Class K fire extinguisher? YES NO Class K required? YES / NO

Equipment Lineup MUST BE LISTED LEFT TO RIGHT Tech Initials C.S

36" RANGE / 24" GRILL

Hood Size 6'

Detectors 2

of Ducts 1

Duct Nozzles 8

Plenum Nozzles 8

Appliance Nozzles 3

Shut Off ELECTRIC ✓

If mechanical, was cable tight? YES or NO

If NO were adjustments made?

Is gas valve piping and cable secure?

Extinguishers / Emergency Lights FEXT 1 ATLANTIC / EL

REQUIRES NOZZLES; QUICK SEALS; DUCT PROTECTION / SYSTEM SHOULD BE UPGRADED TO MEET UL300
NOTHING SHOULD BE HUNG ON DETECTION EMT

CUSTOMER'S SIGNATURE

TECHNICIAN'S SIGNATURE
HST 12073 3200

Date printed 25 Oct 24

Splash Guard installed-Required? / Cartridge installed? / Safety pin removed? / System Certificate installed?

NO

✓ ✓ ✓ ✓

Report of Inspection / Test

Frequency: Annual ITM

2024-08-07

Property

KESWICK VALLEY MEMORIAL - D14
20 ROUTE 617
BURTT'S CORNER NB E6L 2X3

WO Ref #: 768424

Conducted by: Roy Barton
NB Sprinkler System Installer 10072972

Troy Life & Fire Safety Ltd
175 Henri Dunant Street
Moncton New Brunswick E1E 1E4
1-877-441-8769



Life & Fire Safety Ltd.

24 HR. SERVICE
1-877-441-8769

troylfs.com

Report of Inspection / Test General Questions

OWNER SECTION

Is the building occupied?	Yes	Has the occupancy classification, hazard of contents, and/or storage method remained the same since the last inspection?	Yes
Are all fire protection systems in service?	Yes	Has the system remained in service without modification since the last inspection?	Yes
Was the system free of actuations of devices or alarms since the last inspection?	Yes	Name of owner representative who provided the information?	Mike / Troy LFS Inspector
Does the property owner maintain records per NFPA 25 4.3.3?	Yes	Is the building/owner able to supply as-built drawings for the system(s)?	Yes

FIRE DEPARTMENT CONNECTION

Are the FDC caps and plugs in place and undamaged?	Yes	Is the FDC check valve free of leaks?	Yes
Has the interior of the FDC been inspected for obstructions?	Yes	Is the visible piping supplying the FDC undamaged?	Yes
If locking caps/plugs are in place, has an internal inspections been conducted?	Yes	Are the fire department connections visible and accessible?	Yes
Are gaskets in place and in good condition?	Yes	Is the fire department connection clapper(s) in place and operating properly?	Yes
Are identification signs in place?	Yes	Is the automatic drain valve in place and operating properly?	Yes

SPRINKLER HEADS

Were all areas accessible for visual sprinkler inspection?	Yes	Are visible sprinklers in the proper position: upright, pendent, sidewall?	Yes
Are visible sprinklers free of corrosion and physical damage?	Yes	Is there proper clearance below the sprinklers?	Yes
Are visible sprinklers free of foreign materials including foreign paint?	Yes	Is there liquid in all visible glass bulb sprinklers?	Yes
Are all the sprinklers dated 1920 or later?	Yes	Have fast-response sprinklers 20 or more years old been replaced or successfully sample tested within last 10 years?	N/A
Have standard response sprinklers 50 or more years old been replaced or successfully sample tested within last 10 years?	N/A	In the last 10 years, have dry-type sprinklers been replaced or successfully sample tested?	N/A
Have standard response sprinklers 75 or more years old been replaced or successfully sample tested within last 5 years?	N/A	In the last 5 years, have sprinklers subject to harsh environments been replaced or successfully sample tested?	N/A
If any sprinklers failed a multiyear representative sample test, were all sprinklers within the area represented by that sample replaced?	N/A	In last 5 years, have solder-type sprinkler with temperature classification of extra high [325deg F (163 deg C)] or greater been tested?	N/A

Report of Inspection / Test

Frequency: Annual ITM

2024-08-07

Property

KESWICK VALLEY MEMORIAL - D14
20 ROUTE 617
BURTT'S CORNER NB E6L 2X3

WO Ref #: 768424

Conducted by: Roy Barton
NB Sprinkler System Installer 10072972

Troy Life & Fire Safety Ltd
175 Henri Dunant Street
Moncton New Brunswick E1E 1E4
1-877-441-8769



Life & Fire Safety Ltd.

24 HR. SERVICE
1-877-441-8769

troylfs.com

Are there the correct number and type of spare sprinklers as required?	Yes	Is there a list of spare sprinklers?	Yes
Is there a sprinkler wrench for each type of sprinkler?	Yes	Do all installed recessed, flush, and concealed sprinklers appear to have their listed escutcheon or coverplate installed?	Yes
PIPES			
Are the visible pipe and fittings in good condition with no external corrosion?	Yes	Do visible pipe and fittings have no mechanical damage or leaks?	Yes
Does visible pipe have no external loads?	Yes	Are visible pipe hangers and seismic braces not damaged or loose?	Yes
If system pipe flushing was identified (as required during previous 5 year internal) was it completed?	N/A	In the last 5 years, has an internal pipe inspection been performed?	Yes
Did dry pipe system piping protecting or passing through refrigerated spaces pass internal inspection for ice obstruction?	N/A	If yes, was additional pipe examined to ensure that no additional ice obstructions or ice blockages exist on dry system?	N/A
Have dry systems passed air leakage test within the last 3 years?	Yes		
CONTROL VALVE AREA			
Are the control valves in correct (open or closed) position?	Yes	Are the control valves locked or is supervision in place?	Yes
Are the control valves accessible?	Yes	Are the control valves free from leaks?	Yes
Are appropriate wrenches available for the control valves?	Yes	Are the control valves properly identified?	Yes
VALVE AREA			
All control valves operated through full range and returned to normal position?	Yes	Are the gauges in good condition and showing normal air and water pressure?	Yes
Are all check valves externally inspected, operating properly, and are in good condition?	Yes	Are Pressure reducing valves (sprinkler system) in open position and not leaking?	N/A
Are Pressure reducing valves (sprinkler system) with downstream pressure per the design?	N/A	Are Pressure reducing valves in good condition including no handwheels broken?	N/A
Do valve supervisory switches indicate movement?	Yes	The electrical waterflow alarm devices passed test by opening inspector's test connection/bypass connection with alarms actuating and flow observed?	Yes
Have post indicating valves been opened until spring or torsion felt in the rod and then closed back 1/4 turn?	N/A	In last 5 years, have pressure reducing valves passed partial flow test?	N/A
In last 5 years, have alarm valves and associated strainers, filters, and restricted orifices passed an internal inspection?	Yes	In last 5 years, have strainers, filters, restricted orifices and diaphragm chambers on valves and trim passed internal inspection?	Yes
In last 5 years, have gauges been checked by a calibrated gauge or replaced?	Yes	Have pressure reducing valves passed full flow test?	N/A

Report of Inspection / Test

Frequency: Annual ITM

2024-08-07

Property

KESWICK VALLEY MEMORIAL - D14
20 ROUTE 617
BURTT'S CORNER NB E6L 2X3

WO Ref #: 768424

Conducted by: Roy Barton
NB Sprinkler System Installer 10072972

Troy Life & Fire Safety Ltd
175 Henri Dunant Street
Moncton New Brunswick E1E 1E4
1-877-441-8769



Life & Fire Safety Ltd.

24 HR. SERVICE
1-877-441-8769
troylfs.com

Are valve enclosures maintaining a minimum of 4 degrees C or more?	Yes		
DRY VALVE			
Low temperature alarms are in good working condition?	N/A	Are the gauges in good condition and showing normal air and water pressure?	Yes
For freezer systems, gauge near compressor reading the same as gauge near the dry-pipe valve?	Yes	Is the dry pipe valve(s) free from physical damage?	Yes
Are trim valves in appropriate (open or closed) position?	Yes	Is there no leakage in the intermediate chamber?	Yes
Is the priming level correct?	Yes	Has the low air pressure switch passed it's test?	Yes
Has the quick opening device passed the test?	N/A	Have the strainers, filters and orifices been inspected?	Yes
In the last 3 years, was dry pipe valve full trip conducted with the control valve fully open and the quick-opening device, if provided, in service?	Yes		
BACKFLOW PREVENTERS			
Is relief port on RPZ device not discharging?	Yes	Have backflow devices passed forward flow test?	N/A
In last 5 years, have backflow preventers been internally inspected to verify all components are in good condition, operate correctly and move freely?	N/A		
ALARMS			
Is the alarm valve free from physical damage?	Yes	Is the trim in correct (open or closed) position?	Yes
Is there no leakage in the retarding chamber or drains?	Yes	Have low temperature alarms passed test?	N/A
Are alarms and supervisory devices not damaged?	Yes	Do low temperature alarms appear to be free of physical damage?	N/A
TESTING			
All control valves operated through full range and returned to normal position?	Yes	Has the piping from the fire department connection to the fire department check valve been hydrostatically tested within the last 5 years?	Yes
Mechanical waterflow alarm devices passed tests (alarms actuated and flow observed)?	Yes		
MAINTENANCE			
In the last 5 years, have the dry valve(s), strainers, filters and restricted orifices pass internal inspection?	Yes	Is interior of dry-pipe valves cleaned and in good condition?	Yes
Have auxiliary drains been drained/operated?	N/A	Have adjusted, repaired, reconditioned, or replaced components had proper tests/inspections performed? (Identify component and details)	N/A
Was a drain test conducted after opening any closed valve?	Yes	Operating stem of all OS&Y valves lubricated, completely closed and reopened?	N/A

Report of Inspection / Test

Frequency: Annual ITM

2024-08-07

Property

KESWICK VALLEY MEMORIAL - D14
 20 ROUTE 617
 BURTT'S CORNER NB E6L 2X3

WO Ref #: 768424

Conducted by: Roy Barton
 NB Sprinkler System Installer 10072972

Troy Life & Fire Safety Ltd
 175 Henri Dunant Street
 Moncton New Brunswick E1E 1E4
 1-877-441-8769



Life & Fire Safety Ltd.

24 HR. SERVICE
1-877-441-8769

troylfs.com

Have sprinklers and spray nozzles protecting commercial cooking equipment and ventilating systems been replaced annually?	N/A
---	-----

INSPECTION

Is the hydraulic name plate (calculated systems) attached securely to the riser and legible?	Yes	Is the information sign attached and legible?	Yes
--	-----	---	-----

In last 5 years, have the check valves been internally inspected?	Yes	Is the excess pressure pump free of damage and operational?	Yes
---	-----	---	-----

Report of Inspection / Test

Frequency: Annual ITM

2024-08-07

Property

KESWICK VALLEY MEMORIAL - D14
20 ROUTE 617
BURTT'S CORNER NB E6L 2X3

WO Ref #: 768424

Conducted by: Roy Barton
NB Sprinkler System Installer 10072972

Troy Life & Fire Safety Ltd
175 Henri Dunant Street
Moncton New Brunswick E1E 1E4
1-877-441-8769



Life & Fire Safety Ltd.

24 HR. SERVICE
1-877-441-8769
troylfs.com

Report of Inspection / Test for System - WET 1

WET SYSTEM MAIN DRAIN FLOW TEST

Record initial static pressure	109	Record residual pressure	Tanks
Record static pressure	N/A	Seconds to return to initial static	N/A
Is flow observed?	Yes	Are results comparable to previous test	Yes
Did waterflow alarm operate?	Yes		

Report of Inspection / Test

Frequency: Annual ITM

2024-08-07

Property

KESWICK VALLEY MEMORIAL - D14

20 ROUTE 617

BURTT'S CORNER NB E6L 2X3

WO Ref #: 768424

Conducted by: Roy Barton
NB Sprinkler System Installer 10072972

Troy Life & Fire Safety Ltd
175 Henri Dunant Street
Moncton New Brunswick E1E 1E4
1-877-441-8769



Life & Fire Safety Ltd.

24 HR. SERVICE

1-877-441-8769

troylfs.com

Report of Inspection / Test for System - DRY 1

DRY VALVE

Have automatic air maintenance devices passed test?	Yes	When refilling, did the air supply restore normal air pressure in the system within 30 minutes?	Yes
Is there an auxiliary/low point drain list on the valve riser(s)? If YES, attach picture(s) front and back.	N/A		

AIR COMPRESSORS

Is the air compressor, piping, wiring free of physical damage?	Yes	Is the air compressor anchored properly to the structure or system piping?	Yes
For oil-filled air compressors, is the level sufficient?	Yes	Does the air compressor operate as intended on the proper drop in pressure?	Yes
Does the air compressor operate without overheating?	Yes	For oil-filled air compressors, has the oil been replaced or changed?	Yes

DRY VALVE PARTIAL TRIP TEST

Dry Valve Make	Tyco	Dry Valve Model	DPV-1
Dry Valve Serial No.	1073	Dry Valve Size	4
Dry Valve Year	2004	Accelerator Make	N/A
Accelerator Model	N/A	Accelerator Serial No.	N/A
Accelerator Year	N/A	Without Accelerator: Time to Trip	N/A
Without Accelerator: Water Pressure	109	Without Accelerator: Air Pressure	35
Without Accelerator: Trip Point Air Pressure	14	Without Accelerator: Did alarm operate?	Yes
With Accelerator: Time to Trip	N/A	With Accelerator: Water Pressure	N/A
With Accelerator: Air Pressure	N/A	With Accelerator: Trip Point Air Pressure	N/A
With Accelerator: Did alarm operate?	N/A	Were results comparable to previous test?	Yes
Record low pressure activation point (psi)	26	Full trip test as required has been performed within the last 3 years?	2023

DRY SYSTEM MAIN DRAIN FLOW TEST

Record initial static pressure	106	Record residual pressure (psi)	Tank
Record static pressure (psi)	N/A	Seconds to return to initial static	ma
Is flow observed?	Yes	Are results comparable to previous test	Yes
Did waterflow alarm operate?	Yes		

Report of Inspection / Test

Frequency: Annual ITM

2024-08-07

Property

KESWICK VALLEY MEMORIAL - D14
20 ROUTE 617
BURTT'S CORNER NB E6L 2X3

WO Ref #: 768424

Conducted by: Roy Barton
NB Sprinkler System Installer 10072972

Troy Life & Fire Safety Ltd
175 Henri Dunant Street
Moncton New Brunswick E1E 1E4
1-877-441-8769



Life & Fire Safety Ltd.

24 HR. SERVICE
1-877-441-8769
troylfs.com

INSPECTORS TEST CONNECTION

System	Location	Description	Time to Alarm (seconds)	Reported?	Smooth Orifice	Easily Accessible	Signs?	Pass?
WET 1	Quiet room end of hall second floor	Globe valve	60	Yes	Yes	Yes	Yes	Yes
DRY 1	Quiet room end of hall second floor	Attic	na	Yes	Yes	Yes	Yes	Yes
WET 1	Rear exit	First Floor	60	Yes	Yes	Yes	Yes	Yes

VALVES

System	Description	Location	Valve Type	Size	Secured	Open	Easily Accessible	Signs	Exercised	Stems Lubricated	Flow Pass	Tamper Pass
WET 1	System Riser	Tank Room	Butterfly	4"	Monitored	Yes	Yes	Yes	Yes	N/A	N/A	Pass
DRY 1	Attic	Sprinkler Room	Butterfly	4"	Monitored	Yes	Yes	Yes	Yes	N/A	N/A	Pass
DRY 1	Tyco	Sprinkler Room	Dry Pipe Valve	4"	Monitored	N/A	Yes	Yes	Yes	N/A	Pass	Pass
WET 1	Bulk feed second	Sprinkler Room	Butterfly	4"	Monitored	Yes	Yes	Yes	Yes	N/A	N/A	Pass
WET 1	Gem	Sprinkler Room	Alarm Valve	4"	Monitored	N/A	Yes	Yes	Yes	N/A	Pass	Pass
WET 1	Tank 1	Sprinkler Room	Butterfly	4"	Monitored	Yes	Yes	Yes	Yes	N/A	N/A	Pass
WET 1	Tank 2	Sprinkler Room	Butterfly	4"	Monitored	Yes	Yes	Yes	Yes	N/A	N/A	Pass
WET 1	Tank room	Sprinkler Room	Butterfly	2"	Monitored	Yes	Yes	Yes	Yes	N/A	N/A	Pass
WET 1	Elevator machine room	Above ceiling outside library	Butterfly	1"	Monitored	Yes	Yes	Yes	Yes	N/A	N/A	Pass
WET 1	Elevator shaft	Top of stairs before library	Butterfly	1"	Monitored	Yes	Yes	Yes	Yes	N/A	N/A	Pass
WET 1	Second floor	Above ceiling in library	Butterfly	3"	Monitored	Yes	Yes	Yes	Yes	N/A	N/A	Pass
WET 1	Elevator pit	Tank room	Butterfly	1"	Monitored	Yes	Yes	Yes	Yes	N/A	N/A	Pass

DRAIN VALVES

System	Description	Location	Drain	Aux Drain Drained	Water Flow Observed
DRY 1	Main Drain	Tank Room		N/A	Yes

Report of Inspection / Test

Frequency: Annual ITM

2024-08-07

Property

KESWICK VALLEY MEMORIAL - D14

20 ROUTE 617

BURTT'S CORNER NB E6L 2X3

WO Ref #: 768424

Conducted by: Roy Barton
NB Sprinkler System Installer 10072972

Troy Life & Fire Safety Ltd
175 Henri Dunant Street
Moncton New Brunswick E1E 1E4
1-877-441-8769



Life & Fire Safety Ltd.

24 HR. SERVICE
1-877-441-8769
troylfs.com

Deficiencies - General Questions

None

Deficiencies - General Wet System Questions

None

Deficiencies - General Dry System Questions

None

Deficiencies - WET 1

None

Deficiencies - DRY 1

None

Deficiencies - Inspectors Test Connection

None

Deficiencies - Valves

None

Deficiencies - Drain Valves

None

Report of Inspection / Test

Frequency: Annual ITM

2024-08-07

Property

KESWICK VALLEY MEMORIAL - D14

20 ROUTE 617

BURTT'S CORNER NB E6L 2X3

WO Ref #: 768424

Conducted by: Roy Barton
NB Sprinkler System Installer 10072972

Troy Life & Fire Safety Ltd
175 Henri Dunant Street
Moncton New Brunswick E1E 1E4
1-877-441-8769



Life & Fire Safety Ltd.

24 HR. SERVICE
1-877-441-8769

troylfs.com

Inspector Signature

I state that the information on this form is correct at the time and place of my inspection, and all equipment tested at this time was left in operational condition upon completion of this inspection except as noted.

Inspector Name	Signature	Date Completed
Roy Barton NB Sprinkler System Installer 10072972		2024-08-07

Fire Alarm Inspection Report

This states that the Fire Alarm System,

Type MIRTONE SERIES 7600
Located ANGLOPHONE WEST SCHOOL DISTRICT - KESWICK RIDGE SCHOOL
167 MCKEEN ROAD - KESWICK RIDGE, NB

Was checked and WAS in proper working order on,
Date JULY 25, 2024

Deficiencies _____

Recommendations and/or comments _____
PLEASE SEE THE ATTACHED DEVICE LIST FOR
ANY RECOMMENDATIONS AND/OR COMMENTS.



Checked by GORDON GILMORE Technician National Alarm Systems (F'ton) Ltd.
Fredericton, NB E3B 4Y9
Ph: (506) 458-9433 • Fax: (506) 452-8791

In compliance with Can/ULC S536-04



Fire Inspection Report
Rapport d'inspection d'incendie

Fire Prevention Act
Loi sur la prévention des incendies

Office of the Fire Marshal
Bureau du prévôt des incendies
Justice and Public Safety
Justice et sécurité publique

Inspection No.: 6383034
N° d'inspection:
Type: Fire Periodic Inspection
Sécurité-incendie - inspection périodique

Completed Date: 2024/11/06
Date complet:

Date Scheduled: 2024/10/26
Date fixée:

Site Id: 1559-01 PID#: N/A / S/O
Owner/Tenant: Anglophone West School
Location: 20 617 Hwy
Building: Keswick Valley Memorial School
Bldg Equip: []
Usage: School, elementary & middle
Occupancy: N/A / S/O
Mailing Address: 1135 Prospect St
Tel/Télé: (506) 453-5454

Installation No.: 162187
Roof Construction: Non combustible
Wall Construction: Non combustible
No Storeys: 2
Ground Floor(m2): N/A
Basement: No/Non
Fire Walls: No/Non
Fire Alarm(Y/N): Yes/Oui
Occupant Load: 211
Year Constructed: N/A
Width (m): N/A
Standpipe: No/Non
Connected to Monitoring Station: Yes/Oui

Table with 4 columns: Details, Status, Details, Status. Rows include items like Auto hold open devices, Electrical service room, Exit signs & lights, Fire alarm test log, Fire separations, Housekeeping/storage, Safety plans, Sprinkler maintenance.

S - Satisfactory
S - Satisfaisant

U - Unsatisfactory
U - Non satisfaisant

X - Not Inspected
X - Non inspecté

VIOLATIONS/ORDERS/COMMENTS - INFRACTIONS/ORDERS/COMMENTAIRES

COMPLIANCE DATE:
DATE DE CONFORMITÉ:

Blank lines for recording violations, orders, or comments.

Received By/Reçu par: _____ Orders Issued/Ordres émis: _____
Position/Poste: _____ Signature: _____

Inspected By/Inspecté par: Burns, Charles (506) 478-3869 Date: 2024/11/06

Persons failing to comply with the New Brunswick Fire Prevention Act F-13 and Regulations are liable to the penalties and/or conditions defined in the aforementioned Act.
Quiconque contrevient à Loi sur la prévention des incendies du Nouveau-Brunswick, o.F-13, et ce règlements d'application et passible d'une peine et/ou
accusé/jeti aux conditions énoncées dans ladite Loi.

CERTIFICATE OF INSPECTION OF FIRE ALARM SYSTEM

This certifies that the **NOTIFIER** fire alarm system

Located at **20 ROUTE 617
BURTT'S CORNER, NB**

was checked and inspected by **QUALITY SOUND ALARM LTD.**

by a trained technician in accordance with the
Standard for the Inspection of a Fire Alarm System
Inspection CAN4-S536

This certificate must be validated
by AUGUST 2025 as per ULCS536.

Issued in **FREDERICTON** on the **23rd** day of **AUGUST 2024**

PETER TAYLOR
Technician

CAMERON MACDONALD
Authorized Signature





FIRE ALARM SYSTEM ANNUAL TEST AND INSPECTION REPORT

(CAN/UL-SC536-04 Reference Clause 5.1.2)

Building Name:	KESWICK VALLEY MEMORIAL SCHOOL - ASDW	Date:	AUGUST 23-2024
Address	20 ROUTE 617		
	BURTTS CORNER, NB		
System Manufacturer:	NOTIFIER	Model Number:	NSF320C

A	System provides single-stage operation	Yes	<input checked="" type="checkbox"/>	No	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
B	System provides two-stage operation	Yes	<input type="checkbox"/>	No	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
C	The entire fire alarm system has been inspected and tested in accordance with Can/ULC-S536, Inspection and testing of fire alarm systems	Yes	<input checked="" type="checkbox"/>	No	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
D	The fire alarm system documentation is on site and includes a description of the system	Yes	<input type="checkbox"/>	No	<input checked="" type="checkbox"/>	N/A	<input type="checkbox"/>
E	The fire alarm system is fully functional	Yes	<input checked="" type="checkbox"/>	No	<input type="checkbox"/>	N/A	<input type="checkbox"/>
F	The fire alarm system has deficiencies noted on the pages attached	Yes	<input type="checkbox"/>	No	<input checked="" type="checkbox"/>	N/A	<input type="checkbox"/>
G	Comments						
H	A copy of this report will be given to the following, who is the owner or owner's representative for this building: MARK REID	Yes	<input checked="" type="checkbox"/>	No	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

This is to certify that the information contained in this fire alarm system annual test and inspection report is correct and complete

PETER TAYLOR
Printed name of Primary Supervisor
Technician Conducting the test and inspection

Quality Sound Alarm Ltd
Company

506-452-0161
Telephone

Signature of Primary Supervisor
Technician Conducting the test and inspection

Identification Number of Primary or Supervising
Technician conducting the test and inspection

PETER TAYLOR
Printed name of technician conducting the test and inspection

Quality Sound Alarm Ltd
Company

506-452-0161
Telephone

PETER TAYLOR
Signature of technician conducting the test and inspection

Identification Number of technician conducting the test and inspection



E2. CONTROL UNIT OR TRANSPONDER TEST RECORD

Yes ✓ = Tested Correctly No ✓ = Did not test correctly N/A ✓ = Not applicable

E2.1 CONTROL UNIT TRANSPONDER TEST

(CAN/UL-SC536-04 Reference Clause 5.1.3, 5.2.2.1)

Control unit or transponder location	MAIN OFFICE
Control unit of transponder identification	

A	power 'ON' visual indicator operates	Yes	✓	No	N/A		
B	common visual trouble signal operates	Yes	✓	No	N/A		
C	common audible trouble signal operates	Yes	✓	No	N/A		
D	trouble signal silence switch operates	Yes	✓	No	N/A		
E	main power supply failure trouble signal operates	Yes	✓	No	N/A		
F	ground fault tested on positive and negative initiates trouble signal	Yes	✓	No	N/A		
G	alert signal operates	Yes		No	N/A	✓	
H	alarm signal operates	Yes	✓	No	N/A		
I	automatic transfer from alert signal to alarm signal operates	Yes		No	N/A	✓	
J	manual transfer from alert signal to alarm signal operates	Yes		No	N/A	✓	
K	automatic transfer from alert signal to alarm signal cancel (acknowledge) feature operates on a two stage system	Yes		No	N/A	✓	
L	alarm signal silence inhibit function operates	Yes		No	N/A	✓	
M	alarm signal manual silence operates	Yes	✓	No	N/A		
N	alarm signal silence visual indication operates	Yes	✓	No	N/A		
O	alarm signal, when silenced, automatically reinitiates upon subsequent alarm	Yes	✓	No	N/A		
P	alarm signal silence automatic cut out timer	Time:					
Q	audible and visual alert signals and alarm signals programmed and operate per design and specification; or documentation as detailed in appendix 'C', description of fire alarm system for inspection and test procedures	Yes	✓	No	N/A		
R	input circuit, alarm and supervisory operation, including audible and visual indication operates	Yes	✓	No	N/A		
S	input circuit supervision fault causes a trouble indication	Yes	✓	No	N/A		
T	output circuit alarm indicators operate	Yes	✓	No	N/A		
U	output circuit supervision fault causes a trouble indication	Yes	✓	No	N/A		
V	visual indicator test (lamp test)	Yes		No	N/A	✓	
W	coded signal sequences operate not less than the required number of times and the correct alarm signal operates thereafter	Yes		No	N/A	✓	
X	coded signal sequences are not interrupted by subsequent alarm	Yes		No	N/A	✓	
Y	ancillary device by pass will result in a trouble signal	Yes	✓	No	N/A		



continued 2.1

page 3

Z	input circuit to output circuit operation, including ancillary device circuits, for correct program operation, as per design and specification, or documentation as detailed in appendix 'C', description of fire alarm system for inspection and test procedures	Yes	✓	No	N/A	
AA	fire alarm system reset operates	Yes	✓	No	N/A	
BB	main power supply to emergency power supply transfer operates	Yes	✓	No	N/A	
CC	status change confirmation (smoke detectors only) verified. [refer subsection 5.7.4.3, status change confirmation (alarm verification feature)]	Yes		No	N/A	✓
DD	receipt of the alarm transmission to the fire signal receiving centre	Yes	✓	No	N/A	
EE	receipt of the supervisory transmission to the fire signal receiving centre	Yes	✓	No	N/A	
FF	receipt of the trouble transmission to the fire signal receiving centre	Yes	✓	No	N/A	
GG	record the name and telephone number of the fire alarm signal receiving centre: ACCOUNT #03010167	Name: ARMSTRONG Telephone: 1-800-561-5433				
HH	operation of the fire signal receiving centre disconnect means results in a specific trouble indication at the control unit or transponder and transmits a trouble signal to the fire signal receiving centre	Yes	✓	No	N/A	

E2.2 VOICE COMMUNICATION TEST

(CAN/UL-SC536-04 Reference Clause 5.1.3, 5.2.3.1)

A	power 'ON' indicator operates	Yes		No	N/A	✓
B	common visual trouble signal operates	Yes		No	N/A	✓
C	common audible trouble signal operates	Yes		No	N/A	✓
D	trouble signal silence switch operates	Yes		No	N/A	✓
E	all call voice paging, including visual indicator, operates	Yes		No	N/A	✓
F	output circuits for selective voice paging, including visual indication operates	Yes		No	N/A	✓
G	output circuits for selective voice paging trouble operator, including visual indication, operates	Yes		No	N/A	✓
H	microphone, including press to talk switch, operates	Yes		No	N/A	✓
I	operation of voice paging does not interfere with initial inhibit time of alert signal or alarm signal	Yes		No	N/A	✓
J	all call voice paging operates (on emergency power supply)	Yes		No	N/A	✓
K	upon failure of one amplifier, system automatically transfers to back up amplifier(s)	Yes		No	N/A	✓
L	circuits for emergency telephone call in operation, including audible and visual indication, operates	Yes		No	N/A	✓
M	circuits for emergency telephone trouble operation, including visual indication, operates	Yes		No	N/A	✓
N	circuits for emergency telephone trouble operation, including visual indication, operates	Yes		No	N/A	✓
O	emergency telephone verbal communication operates	Yes		No	N/A	✓
P	emergency telephone operable or in use tone at handset operates	Yes		No	N/A	✓



E2.3 CONTROL UNIT OR TRANSPONDER INSPECTION

(CAN/UL-SC536-04 Reference Clause 5.1.3, 5.3.1)

Page 4

Control unit or transponder location	MAIN OFFICE
Control unit of transponder identification	

A	input circuit designations correctly identified in relation to connected field devices	Yes	✓	No		N/A
B	output circuit designations correctly identified in relation to connected field devices	Yes	✓	No		N/A
C	correct designation for common control functions and indicators	Yes	✓	No		N/A
D	plug in components and modules securely in place	Yes	✓	No		N/A
E	plug in cables securely in place	Yes	✓	No		N/A
F	record the date, revision and version of firmware and software program	Date: _____				
		Rev: _____		Ver: _____		
G	clean and free of dust and dirt	Yes	✓	No		N/A
H	fuses in accordance with manufactures specification	Yes	✓	No		N/A
I	control unit or transponder lock functional	Yes	✓	No		N/A
J	termination points from wiring to field devices secure.	Yes	✓	No		N/A

E2.4 POWER SUPPLY INSPECTION

(CAN/UL-SC536-04 Reference Clause 5.1.3, 5.2.4.1)

Control unit or transponder location	MAIN OFFICE
Control unit of transponder identification	

A	Fused in accordance with the manufacturer's marked rating of the system	Yes	✓	No		N/A
B	Adequate to meet the requirements of the system	Yes	✓	No		N/A

E2.5 EMERGENCY POWER SUPPLY TEST AND INSPECTION

(CAN/UL-SC536-04 Reference Clause 5.1.3, 5.3.2, 5.3.3)

Control unit or transponder location	MAIN OFFICE
Control unit of transponder identification	

A	correct battery type as recommended by manufacturer	Yes	✓	No		N/A
B	correct battery rating as determined by battery calculations based on full system load	Yes	✓	No		N/A
C	battery voltage with main power supply 'ON'	V dc	26.8			



continued E2.5

Page 5

D	battery voltage and current with main power supply 'OFF' and fire alarm system in supervisory condition	voltage	25.8	V dc		
		current	0.29	A		
E	battery voltage and current with main power supply 'OFF' and fire alarm system in full load alarm conditions	voltage	24.6	V dc		
		current	1.15	A		
F	charging current		0.17	A		
G	physical damage	Yes		No	<input checked="" type="checkbox"/>	N/A
H	terminals cleaned and lubricated	Yes		No		N/A <input checked="" type="checkbox"/>
I	terminals clamped tightly	Yes	<input checked="" type="checkbox"/>	No		N/A
J	correct electrolyte levels	Yes		No		N/A <input checked="" type="checkbox"/>
K	specific gravity of electrolyte is within manufacturer's specifications	Yes		No		N/A <input checked="" type="checkbox"/>
L	electrolyte leakage	Yes		No		N/A <input checked="" type="checkbox"/>
M	adequate ventilation	Yes	<input checked="" type="checkbox"/>	No		N/A
N	battery manufacturer's date code in-service date	Date:				
O	disconnection causing trouble signal	Yes	<input checked="" type="checkbox"/>	No		N/A
P	indicate type of battery tests performance					
	(i) required supervisory load for 24 h followed by the required full load operation or	Yes		No		
	(ii) a silent test by using the load resistor method may be used for the full duration test (refer to appendix F1, silent test) or	Yes		No		
	(iii) silent accelerated test (refer to appendix F2, silent accelerated test) or	Yes		No		
	(iv) a battery capacity meter test (refer to appendix F3, battery capacity meter test) or	Yes	<input checked="" type="checkbox"/>	No		
	(v) in lieu of the above battery tests, replace the battery with a new set having a current date code, amp hour capacity and type as recommended by the manufacturer.	Yes		No		
Q	record calculated battery capacity (refer to Appendix F4.1-c)	A.h.				
R	record battery terminal voltage after completion of test	V dc				
S	battery voltage not less than 85% of its rating after the tests	Yes	<input checked="" type="checkbox"/>	No		N/A
T	generator provides power to the AC circuit serving the fire alarm system	Yes		No		N/A <input checked="" type="checkbox"/>
U	trouble condition at the emergency generator shall result in an audible common trouble signal and a visual indication at the required enunciator.	Yes		No		N/A <input checked="" type="checkbox"/>

E2.6 ANNUNCIATOR AND REMOTE TROUBLE SIGNAL UNIT TEST AND INSPECTION

(CAN/UL-SC536-04 Reference Clause 5.1.4, 5.4.1)

Annunciator or remote trouble signal unit location
Annunciator or remote trouble signal unit identification

A	power "on" indicator	Yes		No		N/A	<input checked="" type="checkbox"/>
B	individual alarm, and supervisory input zones are clearly indicated and separately designated	Yes		No		N/A	<input checked="" type="checkbox"/>
C	individual alarm, and supervisory input zone designation labels are properly identified	Yes		No		N/A	<input checked="" type="checkbox"/>



continued E2.6

D	common trouble signal operates	Yes	No	N/A	✓
E	visual indicator test (lamp test) operates	Yes	No	N/A	✓
F	input wiring from control unit or transponder is supervised	Yes	No	N/A	✓
G	alarm signal silence visual indicator operates	Yes	No	N/A	✓
H	switches for ancillary functions operate as per design and specification, or documentation as detailed in appendix C, inspection and test procedures	Yes	No	N/A	✓
I	other ancillary function visual indicators operate	Yes	No	N/A	✓
J	manual activation of alarm signal and indication operates	Yes	No	N/A	✓
K	displays are visible in installed location operates	Yes	No	N/A	✓
L	operates on emergency power	Yes	No	N/A	✓

E2.7 ANNUNCIATOR OR SEQUENTIAL DISPLAY

(CAN/UL-SC536-04 Reference Clause 5.1.4, 5.4.2)

Annunciator or sequential display location
Annunciator or sequential display identification

A	power 'on' indicator operates	Yes	No	N/A	✓
B	individual alarm and supervisory zone indication operates	Yes	No	N/A	✓
	Exception: operation of each individual alarm and supervisory zone indication gives the identical indication, or lights the identical indicators at the other annunciator(s) and sequential display (s)	Yes	No	N/A	✓
	Specific method of confirmation: Minimum of one alarm zone and one supervisory zone tested per annunciator or sequential display to confirm operation.	Yes	No	N/A	✓
C	individual alarm and supervisory zone designation labels are properly identified	Yes	No	N/A	✓
D	common trouble signal operates	Yes	No	N/A	✓
E	visual indicator test (lamp test) operates	Yes	No	N/A	✓
F	input wiring from control unit or transponder is supervised	Yes	No	N/A	✓
G	alarm signal silence visual indicator operates	Yes	No	N/A	✓
H	switches for ancillary functions operate as per design and specification, or documentation as detailed in Appendix "C", description of fire alarm system for inspection and test procedures	Yes	No	N/A	✓
I	other ancillary functions visual indicators operate	Yes	No	N/A	✓
J	manual activation of alarm signal and indication operates	Yes	No	N/A	✓
K	displays are visible in installed location	Yes		N/A	✓



E2.8 REMOTE TROUBLE SIGNAL UNIT TEST AND INSPECTION

(CAN/UL-SC536-04 Reference Clause 5.1.4, 5.4.3)

page 7

Remote trouble signal unit location:
Remote trouble signal unit identification

A	input wiring from control unit or transponder is supervised	Yes	No	N/A	✓
B	visual trouble signal operates	Yes	No	N/A	✓
C	audible trouble signal operates	Yes	No	N/A	✓
D	audible trouble signal silence operates	Yes	No	N/A	✓

E2.9 PRINTER TEST

(CAN/UL-SC536-04 Reference Clause 5.1.4, 5.5.1)

Printer location
Printer identification

A	operates as per design and specification, or documentation as detailed in Appendix 'C', description of fire alarm system for inspection and test procedures	Yes	No	N/A	✓
B	zone of each alarm initiating device is correctly printed	Yes	No	N/A	✓
C	rated voltage is present	Yes	No	N/A	✓

E2.10 DATA COMMUNICATION LINK TEST

(CAN/UL-SC536-04 Reference Clause 5.1.5, 5.6-Notes)

Control unit or transponder location
Control unit or transponder identification
Data communication link identification

A	Confirm that a trouble signal is received at the control unit or transponder under an open loop fault for each data communication link (DCL)	Yes	No	N/A	✓
B	Where fault isolation modules are installed in data communication links serving field devices, wiring shall be shorted on the isolated side, annunciation of the fault confirmed, and then a field device on the source side shall be operated, and activation confirmed at the control unit or transponder	Yes	No	N/A	✓



E3 FIELD DEVICE RECORD
(CANUL-SC536-04 Reference Clause 5.1.6)

E3.1 FIELD DEVICE TESTING - LEGEND AND NOTES
(CANUL-SC536-04 Reference Clause 5.7.4.1.3, 5.7.4.1.4, 5.7.4.1.5, 5.7.4.3.1, 5.7.4.5.1, 5.7.8.1.1, 5.7.8.2.4)

page 9

DEVICE	DESCRIPTION	TYPE	MODEL NO.
M	Manual pull station	NOTIFIER	N6 B121X
RHT	Heat detector, restorable		
HT	Heat detector, non restorable		
S	Smoke detector	Not applicable	Not applicable
	- Sensitivity test method or Test Equipment: Model / Method:SMOKE		
	- Manufacturer sensitivity range: Sensitivity range:1349		
RI	Remote indicator unit		
DS	Duct smoke detector	SYSTEM SENSOR	
	Other type of detector		
SFD	Supporting field device (monitor)		
FD	Sprinkler flow switch		
SS	Sprinkler supervisory device		
	Other supervisory devices (low pressure, low water, low temperature, power loss, etc.)		
EM	Fault isolation module		
B	Bell		
H	Horn	SYSTEM SENSOR	HRA
V	Visible signal device		
SP	Cone type speaker		
HSP	Horn type speaker		
AD	Ancillary device		
ET	Emergency telephone		
EOL	End of line resistor		

The following notes apply to Appendix E3.2, Individual Device Record:

- Note 1 Smoke detector sensitivity confirmation or measurement should be recorded in the remarks column
 Note 2 Smoke detector cleaning or replacement date should also be recorded in the remarks column



continued notes....

Page 10

- Note 3 Status change, including time delay, should be recorded in the remarks column
- Note 4 Duct smoke detector pressure differential should be confirmed and recorded in the remarks column
- Note 5 Time delay setting or water flow switch should be recorded in the remarks column
- Note 6 Sprinkler supervisory switches cause trouble condition to be annunciated but not alarm condition
- Note 7 Upper and lower pressure setting of supervisory devices should be recorded in the remarks column
- Note 8 Low temperature setting should be recorded in the remarks column
- Note 9 Identify the specific ancillary devices in the remarks column
- Note 10 Identify date field device changed in the remarks column
- Note 11 Identify correct field device operation (e.g., alarm, Trouble, supervisory, Annunciation indication)
- Note 12 Identify zone, circuit number, or address
- Note 13 Identify conventional field device locations
- Note 14 Identify active field device and supporting field device, data communication link (DCL), address and location
- Note 15 Test and confirm conventional field device supervision of wiring
- Note 16 Confirm field device free of damage
- Note 17 Confirm field device free of foreign substance (e.g. paint)
- Note 18 Confirm field device mechanically supported independently of the wiring
- Note 19 Confirm field device protection dust shields or covers removed

CAUTION: The tests reported on this form do not include the actual operational test of ancillary devices



E3 FIELD DEVICE RECORD

(CAN/UL-SC536-04 Reference Clause 5.7.1.3 E3.1)

Building Address: 20 ROUTE 617
 BURTT'S CORNER, NB
 Date: AUGUST 23-2024

Page 1 of 3

Device legends and notes are listed in Appendix E3.1, field device testing - legend and notes

DEVICE LOCATION	DEVICE	CORRECTLY INSTALLED	REQUIRES SERVICE, REPAIRS, CLEANING OR MISSING	ALARM OPERATION CONFIRMED	ANNUNCIATION INDICATION CONFIRMED	ZONE CIRCUIT NUMBER OR ADDRESS	REMARKS
MAIN ENTRANCE	PULL	✓		✓	✓		
EXIT REAR	PULL	✓		✓	✓		
FIRST FLOOR CORRIDOR	HRN/STRE	✓		✓			
GYM	HRN/STRE	✓		✓			
GYM EXIT	PULL	✓		✓	✓		
1ST FLOOR CORRIDOR	SMOKE	✓		✓	✓		
LOCKER AREA	HRN/STRE	✓		✓			
REAR EXIT	SMOKE	✓		✓	✓		
REAR EXIT	PULL	✓		✓	✓		
CAFETERIA EXIT	PULL	✓		✓	✓		
KITCHEN EXIT	PULL	✓		✓	✓		
CAFETERIA	HRN/STRE	✓		✓			
1ST FLOOR CORRIDOR	HRN/STRE	✓		✓			
1ST FLOOR CORRIDOR	SMOKE	✓		✓	✓		
FIRST FLOOR EXIT	PULL	✓		✓	✓		
1ST FLOOR CORRIDOR	SMOKE	✓		✓	✓		
MECHANICAL ROOM	DUCT	✓		✓			
MECHANICAL ROOM	PULL	✓		✓	✓		
1ST FLOOR CORRIDOR	HRN/STRE	✓		✓			
1ST FLOOR CORRIDOR	HRN/STRE	✓		✓			
1ST FLOOR CORRIDOR	SMOKE	✓		✓	✓		
1ST FLOOR EXIT	PULL	✓		✓	✓		
2ND FLOOR EXIT	SMOKE	✓		✓	✓		
2ND FLOOR CORRIDOR	PULL	✓		✓	✓		



E3 FIELD DEVICE RECORD
(CANUL-SC536-04 Reference Clause 5.7.1.3 E3.1)

Building Address: 20 ROUTE 617
BURTTS CORNER, NB
Date: AUGUST 23-2024

Page 2 of 3

Device legends and notes are listed in Appendix E3.1, field device testing - legend and notes

DEVICE LOCATION	DEVICE	CORRECTLY INSTALLED	REQUIRES SERVICE, REPAIRS, CLEANING OR MISSING	ALARM OPERATION CONFIRMED	ANNUNCIATION INDICATION CONFIRMED	ZONE CIRCUIT NUMBER OR ADDRESS	REMARKS
2ND FLOOR CORRIDOR	HRN/STRE	✓		✓			
2ND FLOOR EXIT	PULL	✓		✓	✓		
2ND FLOOR CORRIDOR	SMOKE	✓		✓	✓		
2ND FLOOR CORRIDOR	SMOKE	✓		✓	✓		
2ND FLOOR CORRIDOR	HRN/STRE	✓		✓			
2ND FLOOR MECHANICAL ROOM	DUCT	✓		✓			
2ND FLOOR CORRIDOR	HRN/STRE	✓		✓			
2ND FLOOR EXIT	PULL	✓		✓	✓		
2ND FLOOR EXIT	SMOKE	✓		✓	✓		
SPRINKLER ROOM	PULL	✓		✓	✓		
SPRINKLER ROOM	HRN/STRE	✓		✓			
STAIRWELL EAST	SMOKE	✓		✓	✓		
STAIRWELL WEST	SMOKE	✓		✓	✓		
STAIRWELL NORTH	SMOKE	✓		✓	✓		
BOYS CHANGE ROOM	HRN/STRE	✓		✓			
GIRLS CHANGE ROOM	HRN/STRE	✓		✓			
ATTIC / BASEMENT	FLOW	✓		✓	✓	6	
2ND FLOOR CLASSROOMS	FLOW	✓		✓	✓	5	
ELEVATOR BOTTOM	TAMPER	✓		✓	✓	6	
WET SYSTEM BASEMENT	TAMPER	✓		✓	✓	6	
DRY SYSTEM BASEMENT	TAMPER	✓		✓	✓		
LOW AIR DRY	LOW AIR	✓		✓	✓	6	
LOW WATER WET	LOW WTR	✓		✓	✓		
2ND FLOOR CLASSROOMS	TAMPER	✓		✓	✓	5	

Report ID: 551029-OAS
 Report Date: 28-Mar-25
 Date Received: 25-Mar-25

CERTIFICATE OF ANALYSIS
 for
 ASD-W (HZ3)
 Department of Education
 250 King Street, Place 2000
 Fredericton, NB E3B 9M9

rpc
 921 College Hill Rd
 Fredericton NB
 Canada E3B 6Z9
 Tel: 506.452.1212
 Fax: 506.452.0594
 www.rpc.ca

Attention: Contacts Education
 Project #: Not Available

Semi-Volatile Organic Compounds in Water

RPC Sample ID:				551029-1	551029-1 Dup	551029-2	551029-3	551029-4
Client Sample ID:				23223	23223	23234	23245	22855
Date Sampled:				Harvey Elementary School DWS #2	Harvey Elementary School DWS #2	Keswick Ridge School DWS	Harvey High School DWS	Keswick Valley
Matrix:				25-Mar-25	25-Mar-25	25-Mar-25	25-Mar-25	25-Mar-25
				water	water	water	water	water
Analytes	Units	RL	MAC(AO)					
Benzo(a)pyrene	mg/L	0.00001	0.00004	< 0.00001	< 0.00001	< 0.00001	< 0.00001	< 0.00001
Pentachlorophenol	mg/L	0.0002	0.06	< 0.0002	< 0.0002	< 0.0002	< 0.0002	< 0.0002
P_terphenyl_d14	%			101	101	104	105	103
2,4,6-tribromophenol	%			101	101	111	111	103

This report relates only to the sample(s) and information provided to the laboratory.
 RL = Reporting Limit



Bruce Phillips
 Department Head
 Organic Analytical Services



Angela Colford
 Lab Supervisor
 Organic Analytical Services

Report ID: 551029-OAS
Report Date: 28-Mar-25
Date Received: 25-Mar-25

CERTIFICATE OF ANALYSIS

for
ASD-W (HZ3)
Department of Education
250 King Street, Place 2000
Fredericton, NB E3B 9M9



921 College Hill Rd
Fredericton NB
Canada E3B 6Z9
Tel: 506.452.1212
Fax: 506.452.0594
www.rpc.ca

Attention: Contacts Education

Project #: Not Available

Semi-Volatile Organic Compounds in Water

RPC Sample ID:		551029-5	
Client Sample ID:		26539 Hanwell Park	
Date Sampled:		25-Mar-25	
Matrix:		water	
Analytes	Units	RL	MAC(AO)
Benzo(a)pyrene	mg/L	0.00001	0.00004
Pentachlorophenol	mg/L	0.0002	0.06
P-terphenyl_d14	%		106
2,4,6-tribromophenol	%		111

SVOC IN WATER - CWA

Page 2 of 8

Report ID: 551029-OAS
 Report Date: 28-Mar-25
 Date Received: 25-Mar-25

CERTIFICATE OF ANALYSIS
 for
 ASD-W (HZ3)
 Department of Education
 250 King Street, Place 2000
 Fredericton, NB E3B 9M9

rpc
 921 College Hill Rd
 Fredericton NB
 Canada E3B 6Z9
 Tel: 506.452.1212
 Fax: 506.452.0594
 www.rpc.ca

Attention: Contacts Education
 Project #: Not Available

Volatile Organic Compounds in Water

RPC Sample ID:				551029-1	551029-2	551029-2 Dup	551029-3	551029-4
Client Sample ID:				23223	23234	23234	23245	22855
Date Sampled:				Harvey Elementary School DWS #2	Keswick Ridge School DWS	Keswick Ridge School DWS	Harvey High School DWS	Keswick Valley
Matrix:				25-Mar-25 water	25-Mar-25 water	25-Mar-25 water	25-Mar-25 water	25-Mar-25 water
Analytes	Units	RL	MAC(AO)					
Benzene	mg/L	0.0005	0.005	< 0.0005	< 0.0005	< 0.0005	< 0.0005	< 0.0005
Bromodichloromethane	mg/L	0.0005	Note	< 0.0005	< 0.0005	< 0.0005	< 0.0005	< 0.0005
Bromoform	mg/L	0.0005	Note	< 0.0005	< 0.0005	< 0.0005	< 0.0005	< 0.0005
Carbon Tetrachloride	mg/L	0.0005	0.002	< 0.0005	< 0.0005	< 0.0005	< 0.0005	< 0.0005
Chloroform	mg/L	0.0005	Note	< 0.0005	< 0.0005	< 0.0005	< 0.0005	< 0.0005
Dibromochloromethane	mg/L	0.0005	Note	< 0.0005	< 0.0005	< 0.0005	< 0.0005	< 0.0005
1,2-dichlorobenzene	mg/L	0.0005	0.20	< 0.0005	< 0.0005	< 0.0005	< 0.0005	< 0.0005
1,4-dichlorobenzene	mg/L	0.0005	0.005	< 0.0005	< 0.0005	< 0.0005	< 0.0005	< 0.0005
1,2-dichloroethane	mg/L	0.0005	0.005	< 0.0005	< 0.0005	< 0.0005	< 0.0005	< 0.0005
Dichloromethane	mg/L	0.0010	0.05	< 0.0010	< 0.0010	< 0.0010	< 0.0010	< 0.0010
Ethylbenzene	mg/L	0.0005	0.14	< 0.0005	< 0.0005	< 0.0005	< 0.0005	< 0.0005
Tetrachloroethylene	mg/L	0.0005	0.01	< 0.0005	0.0005	0.0005	< 0.0005	< 0.0005
Toluene	mg/L	0.0005	0.06	< 0.0005	0.0040	0.0041	< 0.0005	< 0.0005
Trichloroethylene	mg/L	0.0005	0.005	< 0.0005	< 0.0005	< 0.0005	< 0.0005	< 0.0005
Vinyl Chloride	mg/L	0.0020	0.002	< 0.0020	< 0.0020	< 0.0020	< 0.0020	< 0.0020
Xylenes	mg/L	0.0005	0.09	< 0.0005	< 0.0005	< 0.0005	< 0.0005	< 0.0005
Total THM	mg/L	0.001	0.10	< 0.001	< 0.001	< 0.001	< 0.001	< 0.001
1,2-Dichloroethane-d4	%			101	101	99	102	101
Toluene-d8	%			100	101	102	99	100
4-Bromofluorobenzene	%			104	103	101	102	103

This report relates only to the sample(s) and information provided to the laboratory.
 RL = Reporting Limit

Bruce Phillips

Bruce Phillips
 Department Head
 Organic Analytical Services

Angela Colford

Angela Colford
 Lab Supervisor
 Organic Analytical Services

Report ID: 551029-OAS
 Report Date: 28-Mar-25
 Date Received: 25-Mar-25

CERTIFICATE OF ANALYSIS

for
 ASD-W (HZ3)
 Department of Education
 250 King Street, Place 2000
 Fredericton, NB E3B 9M9



921 College Hill Rd
 Fredericton NB
 Canada E3B 6Z9
 Tel: 506.452.1212
 Fax: 506.452.0594
 www.rpc.ca

Attention: Contacts Education

Project #: Not Available

Volatile Organic Compounds in Water

RPC Sample ID:				551029-5
Client Sample ID:				26539 Hanwell Park
Date Sampled:				25-Mar-25
Matrix:				water
Analytes	Units	RL	MAC(AO)	
Benzene	mg/L	0.0005	0.005	< 0.0005
Bromodichloromethane	mg/L	0.0005	Note	< 0.0005
Bromoform	mg/L	0.0005	Note	< 0.0005
Carbon Tetrachloride	mg/L	0.0005	0.002	< 0.0005
Chloroform	mg/L	0.0005	Note	< 0.0005
Dibromochloromethane	mg/L	0.0005	Note	< 0.0005
1,2-dichlorobenzene	mg/L	0.0005	0.20	< 0.0005
1,4-dichlorobenzene	mg/L	0.0005	0.005	< 0.0005
1,2-dichloroethane	mg/L	0.0005	0.005	< 0.0005
Dichloromethane	mg/L	0.0010	0.05	< 0.0010
Ethylbenzene	mg/L	0.0005	0.14	< 0.0005
Tetrachloroethylene	mg/L	0.0005	0.01	< 0.0005
Toluene	mg/L	0.0005	0.06	< 0.0005
Trichloroethylene	mg/L	0.0005	0.005	< 0.0005
Vinyl Chloride	mg/L	0.0020	0.002	< 0.0020
Xylenes	mg/L	0.0005	0.09	< 0.0005
Total THM	mg/L	0.001	0.10	< 0.001
1,2-Dichloroethane-d4	%			102
Toluene-d8	%			100
4-Bromofluorobenzene	%			104

VOC IN WATER - CWA

Page 4 of 8

Report ID: 551029-OAS
Report Date: 28-Mar-25
Date Received: 25-Mar-25

CERTIFICATE OF ANALYSIS

for
ASD-W (HZ3)
Department of Education
250 King Street, Place 2000
Fredericton, NB E3B 9M9

rpc

921 College Hill Rd
Fredericton NB
Canada E3B 6Z9
Tel: 506.452.1212
Fax: 506.452.0594
www.rpc.ca

Method Summary

OAS-HC08: The Determination of Benzo (a) Pyrene and Pentachlorophenol in Water.
OAS-HC02: Determination of Volatile Organic Compounds in Water.

General Report Comments

MAC = maximum acceptable concentration; AO = aesthetic objective (CDWQG 2017)

Note = one of the trihalomethanes (THM); MAC for total THM is expressed as a locational running annual average of quarterly samples.

Samples 551029-2, -3, and -4 - VOC vials contained a small headspace (~ 1 mL) upon receipt. Analytical results for VOC parameters should be regarded as minimum values.

COMMENTS

Page 5 of 8

Report ID: 551029-OAS
Report Date: 28-Mar-25
Date Received: 25-Mar-25

CERTIFICATE OF ANALYSIS

for
ASD-W (HZ3)
Department of Education
250 King Street, Place 2000
Fredericton, NB E3B 9M9



921 College Hill Rd
Fredericton NB
Canada E3B 6Z9
Tel: 506.452.1212
Fax: 506.452.0594
www.rpc.ca

Project #: Not Available

QA/QC Report

RPC Sample ID:			BLANKE1936	SPIKEE1936
Matrix:			water	water
Analytes	Units	RL		% Recovery
Benzo(a)pyrene	mg/L	0.00001	< 0.00001	89%
Pentachlorophenol	mg/L	0.0002	< 0.0002	90%

RL = Reporting Limit

SVOC IN WATER - CWA - QA

Page 6 of 8

Report ID: 551029-OAS
 Report Date: 28-Mar-25
 Date Received: 25-Mar-25

CERTIFICATE OF ANALYSIS

for
 ASD-W (HZ3)
 Department of Education
 250 King Street, Place 2000
 Fredericton, NB E3B 9M9



921 College Hill Rd
 Fredericton NB
 Canada E3B 6Z9
 Tel: 506.452.1212
 Fax: 506.452.0594
 www.rpc.ca

Project #: Not Available

QA/QC Report

RPC Sample ID:			BLANKE1925	SPIKEE1925
Matrix:			water	water
Analytes	Units	RL		% Recovery
Benzene	mg/L	0.0005	< 0.0005	112%
Bromodichloromethane	mg/L	0.0005	< 0.0005	109%
Bromoform	mg/L	0.0005	< 0.0005	105%
Carbon Tetrachloride	mg/L	0.0005	< 0.0005	108%
Chloroform	mg/L	0.0005	< 0.0005	113%
Dibromochloromethane	mg/L	0.0005	< 0.0005	105%
1,2-dichlorobenzene	mg/L	0.0005	< 0.0005	107%
1,4-dichlorobenzene	mg/L	0.0005	< 0.0005	107%
1,2-dichloroethane	mg/L	0.0005	< 0.0005	114%
Dichloromethane	mg/L	0.0010	< 0.0010	112%
Ethylbenzene	mg/L	0.0005	< 0.0005	105%
Tetrachloroethylene	mg/L	0.0005	< 0.0005	106%
Toluene	mg/L	0.0005	< 0.0005	112%
Trichloroethylene	mg/L	0.0005	< 0.0005	109%
Vinyl Chloride	mg/L	0.0020	< 0.0020	106%
Xylenes	mg/L	0.0005	< 0.0005	104%

RL = Reporting Limit

Report ID: 551029-OAS
Report Date: 28-Mar-25
Date Received: 25-Mar-25

CERTIFICATE OF ANALYSIS

for
ASD-W (HZ3)
Department of Education
250 King Street, Place 2000
Fredericton, NB E3B 9M9



921 College Hill Rd
Fredericton NB
Canada E3B 6Z9
Tel: 506.452.1212
Fax: 506.452.0594
www.rpc.ca

Project #: Not Available

Summary of Date Analyzed

RPC Sample ID	SVOC		VOC	
	Extracted	Analyzed	Extracted	Analyzed
551029-1	27-Mar-25	27-Mar-25	26-Mar-25	26-Mar-25
551029-1 Dup	27-Mar-25	27-Mar-25	-	-
551029-2	27-Mar-25	27-Mar-25	26-Mar-25	26-Mar-25
551029-2 Dup	-	-	27-Mar-25	27-Mar-25
551029-3	27-Mar-25	27-Mar-25	26-Mar-25	26-Mar-25
551029-4	27-Mar-25	27-Mar-25	26-Mar-25	26-Mar-25
551029-5	27-Mar-25	27-Mar-25	26-Mar-25	26-Mar-25

DATE ANALYZED SUMMARY

Page 8 of 8

CERTIFICATE OF ANALYSIS / CERTIFICAT D'ANALYSE

for/pour
 ASD-W (HZ3)
 Department of Education
 250 King Street, Place 2000
 Fredericton, NB E3B 9M9



Attention: Contacts Education / Distributions List ASD Contacts /
 Central Public Health

Microbiological Examination of Water/Qualité microbiologique de l'eau potable

RPC Sample ID/No. d'échantillon de RPC:				542488-1	542488-2	542488-3	542488-4
Client Sample ID/ID d'échantillon du client:				23223	23234	23245	22855
Date collected/Date du prélèvement				Harvey Elementary School DWS #2 26-Nov-24	Keswick Ridge School DWS 26-Nov-24	Harvey High School DWS 26-Nov-24	Keswick Valley 26-Nov-24
Time sampled/Heure du prélèvement				8:02:00 AM	8:42:00 AM	7:52:00 AM	9:13:00 AM
Analytes/Paramètre(s)	Method/Méthode	Date Analyzed/Date Analysé	Units Unités				
Heterotrophic Plate Count	MICRO58	26-Nov-24	MPN/mL	<2	4	17	12
Coliforms/Coliformes	MICRO10	26-Nov-24	P-A/100mL	a	a	a	a
E. coli	MICRO10	26-Nov-24	P-A/100mL	a	a	a	a

This report relates only to the sample(s) and information provided to the laboratory.
 Le présent rapport ne s'applique qu'aux échantillons et à l'information transmis au laboratoire.
 a = absent/absentes


 Corrie Maston
 Acting Micro Supervisor
 Applied and Experimental Bioscience


 Geoffrey Chenard
 Microbiology Technician
 Applied and Experimental Bioscience

CERTIFICATE OF ANALYSIS / CERTIFICAT D'ANALYSE

for/pour
ASD-W (HZ3)
Department of Education
250 King Street, Place 2000
Fredericton, NB E3B 9M9

Attention: Contacts Education / Distributions List ASD Contacts /
Central Public Health

Microbiological Examination of Water/Qualité microbiologique de l'eau potable

RPC Sample ID/No. d'échantillon de RPC:				542488-5
Client Sample ID/ID d'échantillon du client:				26539 Hanwell Park
Date collected/Date du prélèvement				26-Nov-24
Time sampled/Heure du prélèvement				10:13:00 AM
Analytes/Paramètre(s)	Method/Méthode	Date Analyzed Date Analysé	Units Unités	
Heterotrophic Plate Count	MICRO58	26-Nov-24	MPN/mL	48
Coliforms/Coliformes	MICRO10	26-Nov-24	P-A/100mL	a
E. coli	MICRO10	26-Nov-24	P-A/100mL	a

Report ID: 544572-ML-W1
 Report Date: 24-Dec-24
 Date Received: 23-Dec-24

CERTIFICATE OF ANALYSIS

for
 ASD-W (HZ3)
 Department of Education
 250 King Street, Place 2000
 Fredericton, NB E3B 9M9

rpc
 921 ch College Hill Rd
 Fredericton NB
 Canada E3B 6Z9
 ☎ 506.452.1212
 📠 506.452.1395
 www.rpc.ca

Attention: Contacts Education / Distributions List ASD Contacts ,
 Central Public Health

Microbiological Examination of Water

Analytes:				Coliforms/Coliformes	E. coli
Units:				P-A/100mL	P-A/100mL
Method ID:				MICRO10	MICRO10
Date Analyzed:				23-Dec-24	23-Dec-24
RPC Sample ID	Client Sample ID	Date Sampled	Time Sampled		
544572-1	23223 Harvey Elementary School DWS #2	23-Dec-24	8:17:00 AM	a	a
544572-2	23234 Keswick Ridge School DWS	23-Dec-24	8:52:00 AM	a	a
544572-3	23245 Harvey High School DWS	23-Dec-24	7:38:00 AM	a	a
544572-4	22855 Keswick Valley	23-Dec-24	9:15:00 AM	a	a
544572-5	26539 Hanwell Park	23-Dec-24	10:02:00 AM	a	a

This report relates only to the sample(s) and information provided to the laboratory.

a = absent



Corrie Maston
 Acting Micro Supervisor
 Applied and Experimental Bioscience

MICRO WATER
 Page 1 of 1



Geoffrey Chenard
 Microbiology Technician
 Applied and Experimental Bioscience

Report ID: 536878-OAS
 Report Date: 26-Sep-24
 Date Received: 24-Sep-24

CERTIFICATE OF ANALYSIS

for
 ASD-W (HZ3)
 Department of Education
 250 King Street, Place 2000
 Fredericton, NB E3B 9M9



921 College Hill Rd
 Fredericton NB
 Canada E3B 6Z9
 Tel: 506.452.1212
 Fax: 506.452.0594
 www.rpc.ca

Attention: Contacts Education
 Project #: Not Available

Semi-Volatile Organic Compounds in Water

RPC Sample ID:				536878-1	536878-2	536878-3	536878-4	536878-5
Client Sample ID:				23223 Harvey Elem. School DWS #2	23234 Keswick Ridge School DWS	23245 Harvey High School DWS	22855 Keswick Valley	26539 Hanwell Park
Date Sampled:				24-Sep-24	24-Sep-24	24-Sep-24	24-Sep-24	24-Sep-24
Matrix:				water	water	water	water	water
Analytes	Units	RL	MAC(AO)					
Benzo(a)pyrene	mg/L	0.00001	0.00004	< 0.00001	< 0.00001	< 0.00001	< 0.00001	< 0.00001
Pentachlorophenol	mg/L	0.0002	0.06	< 0.0002	< 0.0002	< 0.0002	< 0.0002	< 0.0002
P_terphenyl_d14	%			103	106	102	107	108
2,4,6-tribromophenol	%			102	103	99	101	104

This report relates only to the sample(s) and information provided to the laboratory.
 RL = Reporting Limit

Bruce Phillips
 Department Head
 Organic Analytical Services

SVOC IN WATER - CWA
 Page 1 of 7

Angela Colford
 Lab Supervisor
 Organic Analytical Services

Report ID: 536878-OAS
 Report Date: 26-Sep-24
 Date Received: 24-Sep-24

CERTIFICATE OF ANALYSIS
 for
 ASD-W (HZ3)
 Department of Education
 250 King Street, Place 2000
 Fredericton, NB E3B 9M9

rpc
 921 College Hill Rd
 Fredericton NB
 Canada E3B 6Z9
 Tel: 506.452.1212
 Fax: 506.452.0594
 www.rpc.ca

Attention: Contacts Education
Project #: Not Available

Volatile Organic Compounds in Water

RPC Sample ID:				536878-1	536878-2	536878-3	536878-3 Dup	536878-4
Client Sample ID:				23223 Harvey Elem. School DWS #2	23234 Keswick Ridge School DWS	23245 Harvey High School DWS	23245 Harvey High School DWS	22855 Keswick Valley
Date Sampled:				24-Sep-24	24-Sep-24	24-Sep-24	24-Sep-24	24-Sep-24
Matrix:				water	water	water	water	water
Analytes	Units	RL	MAC(AO)					
Benzene	mg/L	0.0005	0.005	< 0.0005	< 0.0005	< 0.0005	< 0.0005	< 0.0005
Bromodichloromethane	mg/L	0.0005	Note	< 0.0005	< 0.0005	< 0.0005	< 0.0005	< 0.0005
Bromoform	mg/L	0.0005	Note	< 0.0005	< 0.0005	< 0.0005	< 0.0005	< 0.0005
Carbon Tetrachloride	mg/L	0.0005	0.002	< 0.0005	< 0.0005	< 0.0005	< 0.0005	< 0.0005
Chloroform	mg/L	0.0005	Note	< 0.0005	< 0.0005	0.0006	0.0006	< 0.0005
Dibromochloromethane	mg/L	0.0005	Note	< 0.0005	< 0.0005	< 0.0005	< 0.0005	< 0.0005
1,2-dichlorobenzene	mg/L	0.0005	0.20	< 0.0005	< 0.0005	< 0.0005	< 0.0005	< 0.0005
1,4-dichlorobenzene	mg/L	0.0005	0.005	< 0.0005	< 0.0005	< 0.0005	< 0.0005	< 0.0005
1,2-dichloroethane	mg/L	0.0005	0.005	< 0.0005	< 0.0005	< 0.0005	< 0.0005	< 0.0005
Dichloromethane	mg/L	0.0010	0.05	< 0.0010	< 0.0010	< 0.0010	< 0.0010	< 0.0010
Ethylbenzene	mg/L	0.0005	0.14	< 0.0005	< 0.0005	< 0.0005	< 0.0005	< 0.0005
Tetrachloroethylene	mg/L	0.0005	0.01	< 0.0005	< 0.0005	< 0.0005	< 0.0005	< 0.0005
Toluene	mg/L	0.0005	0.06	< 0.0005	< 0.0005	< 0.0005	< 0.0005	< 0.0005
Trichloroethylene	mg/L	0.0005	0.005	< 0.0005	< 0.0005	< 0.0005	< 0.0005	< 0.0005
Vinyl Chloride	mg/L	0.0020	0.002	< 0.0020	< 0.0020	< 0.0020	< 0.0020	< 0.0020
Xylenes	mg/L	0.0005	0.09	< 0.0005	< 0.0005	< 0.0005	< 0.0005	< 0.0005
Total THM	mg/L	0.001	0.10	< 0.001	< 0.001	< 0.001	< 0.001	< 0.001
1,2-Dichloroethane-d4	%			99	98	99	101	100
Toluene-d8	%			100	100	99	101	98
4-Bromofluorobenzene	%			102	104	103	102	102

This report relates only to the sample(s) and information provided to the laboratory.

RL = Reporting Limit

Bruce Phillips

Bruce Phillips
 Department Head
 Organic Analytical Services

VOC IN WATER - CWA
 Page 2 of 7

Angela Colford

Angela Colford
 Lab Supervisor
 Organic Analytical Services

Report ID: 536878-OAS
 Report Date: 26-Sep-24
 Date Received: 24-Sep-24

CERTIFICATE OF ANALYSIS

for
 ASD-W (HZ3)
 Department of Education
 250 King Street, Place 2000
 Fredericton, NB E3B 9M9



921 College Hill Rd
 Fredericton NB
 Canada E3B 6Z9
 Tel: 506.452.1212
 Fax: 506.452.0594
 www.rpc.ca

Attention: Contacts Education
Project #: Not Available

Volatile Organic Compounds in Water

RPC Sample ID:				536878-5
Client Sample ID:				26539 Hanwell Park
Date Sampled:				24-Sep-24
Matrix:				water
Analytes	Units	RL	MAC(AO)	
Benzene	mg/L	0.0005	0.005	< 0.0005
Bromodichloromethane	mg/L	0.0005	Note	< 0.0005
Bromoform	mg/L	0.0005	Note	< 0.0005
Carbon Tetrachloride	mg/L	0.0005	0.002	< 0.0005
Chloroform	mg/L	0.0005	Note	< 0.0005
Dibromochloromethane	mg/L	0.0005	Note	< 0.0005
1,2-dichlorobenzene	mg/L	0.0005	0.20	< 0.0005
1,4-dichlorobenzene	mg/L	0.0005	0.005	< 0.0005
1,2-dichloroethane	mg/L	0.0005	0.005	< 0.0005
Dichloromethane	mg/L	0.0010	0.05	< 0.0010
Ethylbenzene	mg/L	0.0005	0.14	< 0.0005
Tetrachloroethylene	mg/L	0.0005	0.01	< 0.0005
Toluene	mg/L	0.0005	0.06	< 0.0005
Trichloroethylene	mg/L	0.0005	0.005	< 0.0005
Vinyl Chloride	mg/L	0.0020	0.002	< 0.0020
Xylenes	mg/L	0.0005	0.09	< 0.0005
Total THM	mg/L	0.001	0.10	< 0.001
1,2-Dichloroethane-d4	%			99
Toluene-d8	%			98
4-Bromofluorobenzene	%			102

Report ID: 536878-OAS
Report Date: 26-Sep-24
Date Received: 24-Sep-24

CERTIFICATE OF ANALYSIS

for
ASD-W (HZ3)
Department of Education
250 King Street, Place 2000
Fredericton, NB E3B 9M9

rpc

921 College Hill Rd
Fredericton NB
Canada E3B 6Z9
Tel: 506.452.1212
Fax: 506.452.0594
www.rpc.ca

Method Summary

OAS-HC08: The Determination of Benzo (a) Pyrene and Pentachlorophenol in Water.
OAS-HC02: Determination of Volatile Organic Compounds in Water.

General Report Comments

MAC = maximum acceptable concentration; AO = aesthetic objective (CDWQG 2017)

Note = one of the trihalomethanes (THM); MAC for total THM is expressed as a locational running annual average of quarterly samples.

COMMENTS

Page 4 of 7

Report ID: 536878-OAS
Report Date: 26-Sep-24
Date Received: 24-Sep-24

CERTIFICATE OF ANALYSIS

for
ASD-W (HZ3)
Department of Education
250 King Street, Place 2000
Fredericton, NB E3B 9M9



921 College Hill Rd
Fredericton NB
Canada E3B 6Z9
Tel: 506.452.1212
Fax: 506.452.0594
www.rpc.ca

Project #: Not Available

QA/QC Report

RPC Sample ID:			BLANKE0665	SPIKEE0665
Matrix:			water	water
Analytes	Units	RL		% Recovery
Benzo(a)pyrene	mg/L	0.00001	< 0.00001	84%
Pentachlorophenol	mg/L	0.0002	< 0.0002	97%

RL = Reporting Limit

Report ID: 536878-OAS
Report Date: 26-Sep-24
Date Received: 24-Sep-24

CERTIFICATE OF ANALYSIS

for
ASD-W (HZ3)
Department of Education
250 King Street, Place 2000
Fredericton, NB E3B 9M9



921 College Hill Rd
Fredericton NB
Canada E3B 6Z9
Tel: 506.452.1212
Fax: 506.452.0594
www.rpc.ca

Project #: Not Available

QA/QC Report

RPC Sample ID:			BLANKE0660	SPIKEE0660
Matrix:			water	water
Analytes	Units	RL		% Recovery
Benzene	mg/L	0.0005	< 0.0005	107%
Bromodichloromethane	mg/L	0.0005	< 0.0005	98%
Bromoform	mg/L	0.0005	< 0.0005	98%
Carbon Tetrachloride	mg/L	0.0005	< 0.0005	98%
Chloroform	mg/L	0.0005	< 0.0005	104%
Dibromochloromethane	mg/L	0.0005	< 0.0005	95%
1,2-dichlorobenzene	mg/L	0.0005	< 0.0005	109%
1,4-dichlorobenzene	mg/L	0.0005	< 0.0005	107%
1,2-dichloroethane	mg/L	0.0005	< 0.0005	107%
Dichloromethane	mg/L	0.0010	< 0.0010	104%
Ethylbenzene	mg/L	0.0005	< 0.0005	109%
Tetrachloroethylene	mg/L	0.0005	< 0.0005	105%
Toluene	mg/L	0.0005	< 0.0005	112%
Trichloroethylene	mg/L	0.0005	< 0.0005	103%
Vinyl Chloride	mg/L	0.0020	< 0.0020	112%
Xylenes	mg/L	0.0005	< 0.0005	113%

RL = Reporting Limit

Report ID: 536878-OAS
Report Date: 26-Sep-24
Date Received: 24-Sep-24

CERTIFICATE OF ANALYSIS

for
ASD-W (HZ3)
Department of Education
250 King Street, Place 2000
Fredericton, NB E3B 9M9



921 College Hill Rd
Fredericton NB
Canada E3B 6Z9
Tel: 506.452.1212
Fax: 506.452.0594
www.rpc.ca

Project #: Not Available

Summary of Date Analyzed

RPC Sample ID	SVOC		VOC	
	Extracted	Analyzed	Extracted	Analyzed
536878-1	25-Sep-24	25-Sep-24	24-Sep-24	24-Sep-24
536878-2	25-Sep-24	25-Sep-24	24-Sep-24	24-Sep-24
536878-3	25-Sep-24	26-Sep-24	24-Sep-24	24-Sep-24
536878-3 Dup	-	-	25-Sep-24	25-Sep-24
536878-4	25-Sep-24	26-Sep-24	24-Sep-24	24-Sep-24
536878-5	25-Sep-24	26-Sep-24	24-Sep-24	24-Sep-24

DATE ANALYZED SUMMARY

Preventive Maintenance of Elevators in N.B. School
Bi-Monthly / Semi-Annual / Annual Report

Permit Date: Apr 11/24
 Date: Mar 11/24
 School Name: Keweenaw Valley Memorial
 Date: Sept 5/23 / Mar 11/24

Unit Number: 1170
 Unit Manufacturer: Dave
 Unit Type: Hydraulic Passenger
 Date Testing Completed: Sept 5/23 / Mar 11/24

Bi-Monthly Report	Complete	N/A	Semi Annual Report	Complete	N/A
Check in at School Office	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Vacuum-controllers, Check relays, contacts & selectors.	<input type="checkbox"/>	<input type="checkbox"/>
Ride unit, check speed and leveling. Adjust if needed.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Check for proper Fuse Sizing, check main power connections	<input type="checkbox"/>	<input type="checkbox"/>
Verify all safety circuits & scheduling devices	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Check & adjust voltage of rectifier and record	<input type="checkbox"/>	<input type="checkbox"/>
Lubricate, clean & adjust all components	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Check fastings, Operating rollers, cams of H-way limits & safety switches	<input type="checkbox"/>	<input type="checkbox"/>
Check all lamps & signals. Replace bulbs as required.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Check selector tape, wire ropes & cables	<input type="checkbox"/>	<input type="checkbox"/>
Check fan and car interior	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Inspect, adjust & Lubricate: door closers arms & reel and air cords	<input type="checkbox"/>	<input type="checkbox"/>
Confirm phone & emergency communication	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Adjust lower guides on car & doors.	<input type="checkbox"/>	<input type="checkbox"/>
Adjust & lubricate door operation, speed, hangers & track	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Check car counterweight run-up	<input type="checkbox"/>	<input type="checkbox"/>
Check door protection, hanger rollers and relating cable tension	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Check, clean & lubricate: governor, idler & tape sheaves	<input type="checkbox"/>	<input type="checkbox"/>
Verify door Gibbs and retainers, visual panels.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Inspect brakes, clean linings & pulleys. Lubricate pins, hangers & rails	<input type="checkbox"/>	<input type="checkbox"/>
Check and adjust hydraulic packing, valves, couplings	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Demonstrates emergency lowering operation	<input type="checkbox"/>	<input type="checkbox"/>
Check hydraulic levels and top up. Report any loss to Supervisor immediately	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Discuss any notes with Facility Manager/ representative	<input type="checkbox"/>	<input type="checkbox"/>
Clean pit and check pit can	<input checked="" type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>
Check motor, M/G Brushes, oil level. Top up if needed	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Annual Report	Complete	N/A
Inspect and Adjust loose guides on car	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Change oil in Generators, motors and geared equipment	<input type="checkbox"/>	<input type="checkbox"/>
Verify Hoist way lockouts and access switch. (interlocks)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Check Sheaves & rope for wear Travelling cable & hangers	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Clean Machine Rm. & Machine Rm Equipment	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Clean generators & motors; Check wire connections	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Clean top of car and equipment	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Check under car & counterweight safety devices	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Read and Fill out log book	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Clean switches, check for wear breakage & Corrosion	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Note any adjustments, deficiencies and suggested repairs	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Complete hydrostatic test for in-ground and above-ground units	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Discuss any notes with Facility Manager/representative	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Discuss any notes with Facility Manager / Representative	<input checked="" type="checkbox"/>	<input type="checkbox"/>

S.R.P. School Signature
J.R.H. Mechanic Signature

Important Notes:

- All the items in the checklist should be checked with your initials and not only signed at the end.
- Refer to specification for complete list of work to be performed

Comments:

Semi Annual Reference Guide:

- Jan-Jul
- Feb-Aug
- Mar-Sep
- Apr-Oct
- May-Nov
- Jun-Dec

Keswick Valley Memorial School

**ELEVATING DEVICE CONDITION REPORT
RAPPORT SUR L'ETAT DES APPAREILS ÉLEVATEURS**

03/16

The form must be completed by the licensed elevator tractor who performs the maintenance on the device within your building. Please send this completed form to the attention of Keith Steeves by email at keith.steeves@gnb.ca or by fax at (506) 856-3078. If you have any questions, please contact Keith Steeves at (506) 856-3080.

Le formulaire doit être rempli par l'entrepreneur d'appareils élévateurs titulaire d'un permis qui est chargé à l'entretien de l'appareil se trouvant dans votre édifice. Veuillez faire parvenir le formulaire dûment rempli à Keith Steeves par courriel à l'adresse keith.steeves@gnb.ca ou par télécopieur au 506-856-3078. Si vous avez des questions, veuillez communiquer avec lui par téléphone au 506-856-3080.

Owner / Propriétaire

Civic No. / N° de voirie	Street or Hwy / Rue ou route	Municipality / Municipalité
Postal code Code postal	Telephone Téléphone	Install Date/ Date de L'installation
Device No/No de l'appareil	Manufacturer / Fabricant	Number of Floors/Nombre d' etages

1985
1170 Dover 2

Type

Freight / Monte-charge Passenger / Ascenseur B355 Devices/ Appareils B355

Hydraulic / Ascenseur hydraulique Escalator/ Escaliers mécaniques

Traction / Ascenseur à traction Dumbwaiter/Petite monte-charge

Licensed Contractor /
Entrepreneur titulaire d'un permis

KONE Inc.

Licence No. /
N° de permis

31760

This elevating device is presently maintained by the above-named licensed contractor and is being maintained in accordance with the New Brunswick Elevators and Lifts Act and its regulations.

Cet appareil d'élévateur fait présentement l'objet d'entretien par l'entrepreneur titulaire d'un permis susmentionné et son entretien se conforme aux exigences de la Loi sur les ascenseurs et monte-charge du Nouveau-Brunswick et de ses règlements.

Type of Contract and No. of Visits /
Type de contrat et nombre de visites

Name of person representing contractor with maintenance on this unit /
Nom de la personne représentant l'entrepreneur responsable d'entretien de cet appareil.

Cheryl Howells

(Print Name / Nom en lettres moulées)

(Signature)

(Date)

All applicable annual tests completed for elevators as per ASME A17.1-2016/CSA-B44-16 for elevators (CAT 1) /
Tous les tests applicables qui doivent être menés tous les ans sur les ascenseurs ont été effectués conformément à la norme ASME A17.1-2016/CSA-B44-16 (CAT 1).

Yes / Oui No / Non

All applicable Category 5 tests completed for elevators as per ASME A17.1-2016/CSA-B44-16 (CAT5)
Tous les tests de catégorie 5 applicables pour les ascenseurs selon ASME 17.1-2016/CSA-B44-16 (CAT5)

Yes / Oui No / Non

Date Category 5 testing last completed _____ Maintenance Control Program
Date a les tests de catégorie 5 sont terminés On site / sur place

Yes / Oui No / Non

All applicable annual tests completed for lifts for persons with physical disabilities as per CSAB355-15 ANNEX B /
Tous les tests applicables qui doivent être menés tous les ans sur les appareils élévateurs pour personnes handicapées ont été effectués conformément à la norme CSAB355-15, ANNEXE B.

Yes / Oui No / Non

Licensed Mechanic testing unit /
Mécanicien agréé testant l'appareil

Licence No. / N° de permis

67773

Shane Dorey

(Print Name / Nom en lettres moulées)

(Signature)

(Date)

Public Safety
Telephone: (506) 856-3080
Fax: (506) 856-3078
Email: keith.steeves@gnb.ca



Ministère de la Sécurité publique
Téléphone : 506-856-3080
Télécopieur : 506-856-3078
Courriel : keith.steeves@gnb.ca

Testing and Inspection Report

Double Check Valve Assembly / Pressure Vacuum Breaker / Reduced Pressure Principle 06/21

Distribution Copies Regional Plumbing Inspector (Photocopy) Occupant or Owner (Original) Licensed Tester (Photocopy)	OFFICE USE ONLY		
Site No.	Permit No.	Device No.	

PLEASE PRINT CLEARLY

Site Name / Occupancy: <u>Heswick Valley Memorial</u>			
Civic Number: <u>20</u>	Street: <u>Route 617</u>	City: <u>Heswick</u>	Site Usage: <u>School</u>
Postal Code:	Prov.: <u>NB</u>	Telephone:	

Site Owner		Site Owner's email	
Civic Number:	Street:	City:	
Postal Code:	Prov.:	Telephone:	

Certified Tester: <u>Ray Barston</u>	Company Name: <u>Impulse</u>	License No.: <u>71583</u>	Telephone: <u>8579224</u>
--------------------------------------	------------------------------	---------------------------	---------------------------

Make of Test Kit: <u>A Mako</u>	Model No.: <u>MK3</u>	Serial No.: <u>024821010011</u>	Calibration Due Date: <u>2024 09 26</u>
---------------------------------	-----------------------	---------------------------------	---

<input type="checkbox"/> Double Check Valve Assembly	<input checked="" type="checkbox"/> Reduced Pressure Principle	<input type="checkbox"/> Pressure Vacuum Breaker (Spill Resistant)	<input type="checkbox"/> Yes
Make of Assembly: <u>Watts</u>	Model No.: <u>909</u>	Serial No.: <u>105565</u>	Size: <u>2"</u>
Location of Assembly in Building: <u>Jack Room in Basement</u>			
Level of Protection: <input type="checkbox"/> Premise <input type="checkbox"/> Area <input checked="" type="checkbox"/> Zone <input type="checkbox"/> Individual			
Type of Test: <input checked="" type="checkbox"/> Initial <input type="checkbox"/> Repair	Date of Test: <u>2024 08 07</u>	Line Pressure: <u>48</u> kPa / <u>700</u> psi	Initial Test: <input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail

Tests	Step Component	Test	Requirement	Initial Test	Final Test
REDUCED PRESSURE	1. Relief Valve	Differential pressure relief valve opened at	(2 PSID minimum)	3.7	
	2. Shut Off Valve # 2	<input type="checkbox"/> Leaked <input type="checkbox"/> Closed Tight			
	3. Check Valve # 2	Positive flow <input type="checkbox"/> Leaked <input type="checkbox"/> Closed Tight			
	4. Check Valve # 1	<input type="checkbox"/> Leaked <input type="checkbox"/> Closed Tight			
	5. Check Valve # 1	Pressure differential across 1" check		8.1	
	6. Buffer	(Pressure drop across 1" check minus opening point of relief valve) (min. 3 psi)		4.4	
DOUBLE CHECK VALVE ASSEMBLY	1. Check Valve # 1	Differential pressure in direction of flow	1.0 PSID min		
	2. Check Valve # 2	Differential pressure in direction of flow	1.0 PSID min		
PRESSURE VACUUM BREAKER	1. Air Inlet Valve	Opening Differential	1.0 PSID min		
	2. Check Valve	Closes tight in direction of flow	1.0 PSID min		

If the assembly fails the initial test for any reason, complete this section and note repair below

Comments - Reason for failure (if apparent): E-MAILED Aug 8 2024

NOTE: PLEASE CONTACT YOUR MUNICIPALITY TO DETERMINE WHETHER THEY ALSO REQUIRE A COPY OF THIS REPORT

REPAIRS	REDUCED PRESSURE PRINCIPLE								
	Differential Pressure Relief Valve			Check Valve No. 1		Check Valve No. 2		Shut Off Valve No. 2	
	<input type="checkbox"/> Cleaned	Replaced		<input type="checkbox"/> Cleaned	Replaced	<input type="checkbox"/> Cleaned	Replaced	<input type="checkbox"/> Cleaned	Replaced
<input type="checkbox"/> Disc Upper	<input type="checkbox"/> Diaphragm Sm	<input type="checkbox"/> Diaphragm Lg	<input type="checkbox"/> Disc	<input type="checkbox"/> Pin Retainer	<input type="checkbox"/> Disc	<input type="checkbox"/> Pin Retainer	<input type="checkbox"/> Disc	<input type="checkbox"/> Disc	<input type="checkbox"/> Seat
<input type="checkbox"/> Disc Lower	<input type="checkbox"/> Upper	<input type="checkbox"/> Upper	<input type="checkbox"/> Spring	<input type="checkbox"/> Hinged Pin	<input type="checkbox"/> Spring	<input type="checkbox"/> Hinged Pin	<input type="checkbox"/> Seat	<input type="checkbox"/> Seat	<input type="checkbox"/> Other
<input type="checkbox"/> Spring	<input type="checkbox"/> Spacer	<input type="checkbox"/> Lower	<input type="checkbox"/> Guide	<input type="checkbox"/> Diaphragm	<input type="checkbox"/> Guide	<input type="checkbox"/> Diaphragm	<input type="checkbox"/> Other	<input type="checkbox"/> Other	<input type="checkbox"/> Other
<input type="checkbox"/> Seat	<input type="checkbox"/> Other		<input type="checkbox"/> Seat	<input type="checkbox"/> Other	<input type="checkbox"/> Seat	<input type="checkbox"/> Other			

REPAIRS	DOUBLE CHECK VALVE ASSEMBLY						PRESSURE VACUUM BREAKER					
	Check Valve No. 1			Check Valve No. 2			Cleaned		Replaced			
	<input type="checkbox"/> Cleaned	Replaced		<input type="checkbox"/> Cleaned	Replaced		<input type="checkbox"/> Cleaned	Replaced	<input type="checkbox"/> Cleaned	Replaced	<input type="checkbox"/> Cleaned	Replaced
<input type="checkbox"/> Spring	<input type="checkbox"/> Guide	<input type="checkbox"/> Pin Retainer	<input type="checkbox"/> Spring	<input type="checkbox"/> Guide	<input type="checkbox"/> Pin Retainer	<input type="checkbox"/> Vent Spring	<input type="checkbox"/> Poppet	<input type="checkbox"/> Retainer	<input type="checkbox"/> Vent Spring	<input type="checkbox"/> Disc	<input type="checkbox"/> Guide	
<input type="checkbox"/> Hinged Pin	<input type="checkbox"/> Seat	<input type="checkbox"/> Diaphragm	<input type="checkbox"/> Hinged Pin	<input type="checkbox"/> Seat	<input type="checkbox"/> Diaphragm	<input type="checkbox"/> Spring	<input type="checkbox"/> Disc	<input type="checkbox"/> Guide	<input type="checkbox"/> Vent Disc	<input type="checkbox"/> Disc	<input type="checkbox"/> Other	
<input type="checkbox"/> Disc	<input type="checkbox"/> Other		<input type="checkbox"/> Disc	<input type="checkbox"/> Other								

I certify that I have tested the above device in accordance with New Brunswick Regulation 84-187 under the Plumbing Installation and Inspection Act.

Signature of Tester: [Signature] Year: 2024 Month: 08 Day: 07