

Report of Inspection / Test

Frequency: Annual ITM

07-16-2025

Property

KESWICK VALLEY MEMORIAL - D14
20 ROUTE 617
BURTT'S CORNER NB E6L 2X3

WO Ref #: 6578530

Conducted by: Roy Barton
NB Sprinkler System Installer 10072972

Troy Life & Fire Safety Ltd
175 Henri Dunant Street
Moncton New Brunswick E1E 1E4
1-877-441-8769



Life & Fire Safety Ltd.

24 HR. SERVICE
1-877-441-8769

troylfs.com

Report of Inspection / Test General Questions

OWNER SECTION

Is the building occupied?	Yes	Has the occupancy classification, hazard of contents, and/or storage method remained the same since the last inspection?	Yes
Are all fire protection systems in service?	Yes	Has the system remained in service without modification since the last inspection?	Yes
Was the system free of actuations of devices or alarms since the last inspection?	Yes	Name of owner representative who provided the information?	Mike
Does the property owner maintain records per NFPA 25 4.3.3?	Yes	Is the building/owner able to supply as-built drawings for the system(s)?	No

CONTROL VALVE AREA

Are the control valves in correct (open or closed) position?	Yes	Are the control valves locked or is supervision in place?	Yes
Are the control valves accessible?	Yes	Are the control valves free from leaks?	Yes
Are appropriate wrenches available for the control valves?	Yes	Are the control valves properly identified?	Yes

VALVE AREA

Are all check valves externally inspected, operating properly, and are in good condition?	Yes	Are the gauges in good condition and showing normal air and water pressure?	Yes
Are Pressure reducing valves (sprinkler system) in open position and not leaking?	N/A	Are Pressure reducing valves (sprinkler system) with downstream pressure per the design?	N/A
Are Pressure reducing valves in good condition including no handwheels broken?	N/A	Do valve supervisory switches indicate movement?	Yes
The electrical waterflow alarm devices passed test by opening inspector's test connection/bypass connection with alarms actuating and flow observed?	Yes	Have post indicating valves been opened until spring or torsion felt in the rod and then closed back 1/4 turn?	N/A
All control valves operated through full range and returned to normal position?	Yes	In last 5 years, have pressure reducing valves passed partial flow test?	N/A
In last 5 years, have alarm valves and associated strainers, filters, and restricted orifices passed an internal inspection?	No	In last 5 years, have strainers, filters, restricted orifices and diaphragm chambers on valves and trim passed internal inspection?	No
In last 5 years, have gauges been checked by a calibrated gauge or replaced?	Yes	Have pressure reducing valves passed full flow test?	N/A
Are valve enclosures maintaining a minimum of 4 degrees C or more?	Yes		

BACKFLOW PREVENTERS

Is relief port on RPZ device not discharging?	N/A	Have backflow devices passed forward flow test?	N/A
---	-----	---	-----

Report of Inspection / Test

Frequency: Annual ITM

07-16-2025

Property

KESWICK VALLEY MEMORIAL - D14
20 ROUTE 617
BURTT'S CORNER NB E6L 2X3

WO Ref #: 6578530

Conducted by: Roy Barton
NB Sprinkler System Installer 10072972

Troy Life & Fire Safety Ltd
175 Henri Dunant Street
Moncton New Brunswick E1E 1E4
1-877-441-8769



Life & Fire Safety Ltd.

24 HR. SERVICE
1-877-441-8769

troylfs.com

In last 5 years, have backflow preventers been internally inspected to verify all components are in good condition, operate correctly and move freely?	N/A
--	-----

ALARMS

Have low temperature alarms passed test?	N/A	Are alarms and supervisory devices not damaged?	Yes
--	-----	---	-----

Do low temperature alarms appear to be free of physical damage?	N/A
---	-----

FIRE DEPARTMENT CONNECTION

Are the FDC caps and plugs in place and undamaged?	Yes	Is the FDC check valve free of leaks?	Yes
--	-----	---------------------------------------	-----

Has the interior of the FDC been inspected for obstructions?	Yes	Is the visible piping supplying the FDC undamaged?	Yes
--	-----	--	-----

If locking caps/plugs are in place, has an internal inspections been conducted?	Yes	Are the fire department connections visible and accessible?	Yes
---	-----	---	-----

Are gaskets in place and in good condition?	Yes	Is the fire department connection clapper(s) in place and operating properly?	Yes
---	-----	---	-----

Are identification signs in place?	Yes	Is the automatic drain valve in place and operating properly?	Yes
------------------------------------	-----	---	-----

PIPES

Are the visible pipe and fittings in good condition with no external corrosion?	Yes	Do visible pipe and fittings have no mechanical damage or leaks?	Yes
---	-----	--	-----

Does visible pipe have no external loads?	Yes	Are visible pipe hangers and seismic braces not damaged or loose?	Yes
---	-----	---	-----

If system pipe flushing was identified (as required during previous 5 year internal) was it completed?	N/A	In the last 5 years, has an internal pipe inspection been performed?	No
--	-----	--	----

SPRINKLER HEADS

Are visible sprinklers in the proper position: upright, pendent, sidewall?	Yes	Are visible sprinklers free of corrosion and physical damage?	Yes
--	-----	---	-----

Is there proper clearance below the sprinklers?	Yes	Are visible sprinklers free of foreign materials including foreign paint?	Yes
---	-----	---	-----

Is there liquid in all visible glass bulb sprinklers?	Yes	Are all the sprinklers dated 1920 or later?	Yes
---	-----	---	-----

Have fast-response sprinklers 20 or more years old been replaced or successfully sample tested within last 10 years?	N/A	Have standard response sprinklers 50 or more years old been replaced or successfully sample tested within last 10 years?	N/A
--	-----	--	-----

In the last 10 years, have dry-type sprinklers been replaced or successfully sample tested?	N/A	Have standard response sprinklers 75 or more years old been replaced or successfully sample tested within last 5 years?	N/A
---	-----	---	-----

In the last 5 years, have sprinklers subject to harsh environments been replaced or successfully sample tested?	N/A	If any sprinklers failed a multiyear representative sample test, were all sprinklers within the area represented by that sample replaced?	N/A
---	-----	---	-----

Report of Inspection / Test

Frequency: Annual ITM

07-16-2025

Property

KESWICK VALLEY MEMORIAL - D14
20 ROUTE 617
BURTT'S CORNER NB E6L 2X3

WO Ref #: 6578530

Conducted by: Roy Barton
NB Sprinkler System Installer 10072972

Troy Life & Fire Safety Ltd
175 Henri Dunant Street
Moncton New Brunswick E1E 1E4
1-877-441-8769



Life & Fire Safety Ltd.

24 HR. SERVICE
1-877-441-8769

troylfs.com

In last 5 years, have solder-type sprinkler with temperature classification of extra high [325deg F (163 deg C)] or greater been tested?	N/A	Are there the correct number and type of spare sprinklers as required?	Yes
Is there a list of spare sprinklers?	Yes	Is there a sprinkler wrench for each type of sprinkler?	Yes
Do all installed recessed, flush, and concealed sprinklers appear to have their listed escutcheon or coverplate installed?	Yes	Were all areas accessible for visual sprinkler inspection?	Yes
MAINTENANCE			
Have auxiliary drains been drained/operated?	N/A	Have adjusted, repaired, reconditioned, or replaced components had proper tests/inspections performed? (Identify component and details)	N/A
Was a drain test conducted after opening any closed valve?	Yes	Operating stem of all OS&Y valves lubricated, completely closed and reopened?	N/A
Have sprinklers and spray nozzles protecting commercial cooking equipment and ventilating systems been replaced annually?	N/A		
TESTING			
All control valves operated through full range and returned to normal position?	Yes	Has the piping from the fire department connection to the fire department check valve been hydrostatically tested within the last 5 years?	No
Mechanical waterflow alarm devices passed tests (alarms actuated and flow observed)?	Yes		
INSPECTION			
Is the hydraulic name plate (calculated systems) attached securely to the riser and legible?	Yes	Is the information sign attached and legible?	Yes
In last 5 years, have the check valves been internally inspected?	No		
ALARMS			
Is the alarm valve free from physical damage?	Yes	Is the trim in correct (open or closed) position?	Yes
Is there no leakage in the retarding chamber or drains?	Yes		
INSPECTION			
Is the excess pressure pump free of damage and operational?	Yes		
DRY VALVE			
Low temperature alarms are in good working condition?	N/A	Are the gauges in good condition and showing normal air and water pressure?	Yes
For freezer systems, gauge near compressor reading the same as gauge near the dry-pipe valve?	N/A	Is the dry pipe valve(s) free from physical damage?	Yes
Are trim valves in appropriate (open or closed) position?	Yes	Is there no leakage in the intermediate chamber?	Yes

Report of Inspection / Test

Frequency: Annual ITM

07-16-2025

Property

KESWICK VALLEY MEMORIAL - D14
20 ROUTE 617
BURTT'S CORNER NB E6L 2X3

WO Ref #: 6578530

Conducted by: Roy Barton
NB Sprinkler System Installer 10072972

Troy Life & Fire Safety Ltd
175 Henri Dunant Street
Moncton New Brunswick E1E 1E4
1-877-441-8769



Life & Fire Safety Ltd.

24 HR. SERVICE
1-877-441-8769

troylfs.com

Is the priming level correct?	Yes	Has the low air pressure switch passed it's test?	Yes
Has the quick opening device passed the test?	N/A	Have the strainers, filters and orifices been inspected?	Yes
In the last 3 years, was dry pipe valve full trip conducted with the control valve fully open and the quick-opening device, if provided, in service?	Yes		
MAINTENANCE			
In the last 5 years, have the dry valve(s), strainers, filters and restricted orifices pass internal inspection?	No	Is interior of dry-pipe valves cleaned and in good condition?	Yes
PIPES			
Did dry pipe system piping protecting or passing through refrigerated spaces pass internal inspection for ice obstruction?	N/A	If yes, was additional pipe examined to ensure that no additional ice obstructions or ice blockages exist on dry system?	N/A
Have dry systems passed air leakage test within the last 3 years?	Yes		

Report of Inspection / Test

Frequency: Annual ITM

07-16-2025

Property

KESWICK VALLEY MEMORIAL - D14
20 ROUTE 617
BURTT'S CORNER NB E6L 2X3

WO Ref #: 6578530

Conducted by: Roy Barton
NB Sprinkler System Installer 10072972

Troy Life & Fire Safety Ltd
175 Henri Dunant Street
Moncton New Brunswick E1E 1E4
1-877-441-8769



Life & Fire Safety Ltd.

24 HR. SERVICE
1-877-441-8769

troylfs.com

Report of Inspection / Test for System - WET 1

WET SYSTEM MAIN DRAIN FLOW TEST

Record initial static pressure	105	Record residual pressure	Tanks
Record static pressure	N/A	Seconds to return to initial static	N/A
Is flow observed?	Yes	Are results comparable to previous test	Yes
Did waterflow alarm operate?	Yes		

Report of Inspection / Test

Frequency: Annual ITM

07-16-2025

Property

KESWICK VALLEY MEMORIAL - D14
20 ROUTE 617
BURTT'S CORNER NB E6L 2X3

WO Ref #: 6578530

Conducted by: Roy Barton
NB Sprinkler System Installer 10072972

Troy Life & Fire Safety Ltd
175 Henri Dunant Street
Moncton New Brunswick E1E 1E4
1-877-441-8769



Life & Fire Safety Ltd.

24 HR. SERVICE
1-877-441-8769

troylfs.com

Report of Inspection / Test for System - DRY 1

DRY VALVE

Have automatic air maintenance devices passed test?	Yes	When refilling, did the air supply restore normal air pressure in the system within 30 minutes?	Yes
Is there an auxiliary/low point drain list on the valve riser(s)? If YES, attach picture(s) front and back.	N/A		

AIR COMPRESSORS

Is the air compressor, piping, wiring free of physical damage?	Yes	Is the air compressor anchored properly to the structure or system piping?	Yes
For oil-filled air compressors, is the level sufficient?	Yes	Does the air compressor operate as intended on the proper drop in pressure?	Yes
Does the air compressor operate without overheating?	Yes	For oil-filled air compressors, has the oil been replaced or changed?	No

DRY VALVE PARTIAL TRIP TEST

Dry Valve Make	Tyco	Dry Valve Model	DPV-1
Dry Valve Serial No.	1074	Dry Valve Size	4
Dry Valve Year	2004	Accelerator Make	N/A
Accelerator Model	N/A	Accelerator Serial No.	N/A
Accelerator Year	N/A	Without Accelerator: Time to Trip	N/A
Without Accelerator: Water Pressure	105	Without Accelerator: Air Pressure	35
Without Accelerator: Trip Point Air Pressure	8	Without Accelerator: Did alarm operate?	Yes
With Accelerator: Time to Trip	N/A	With Accelerator: Water Pressure	N/A
With Accelerator: Air Pressure	N/A	With Accelerator: Trip Point Air Pressure	N/A
With Accelerator: Did alarm operate?	N/A	Were results comparable to previous test?	Yes
Record low pressure activation point (psi)	26	Full trip test as required has been performed within the last 3 years?	Due 2026

DRY SYSTEM MAIN DRAIN FLOW TEST

Record initial static pressure	105	Record residual pressure (psi)	Tanks
Record static pressure (psi)	N/A	Seconds to return to initial static	N/A
Is flow observed?	Yes	Are results comparable to previous test	Yes
Did waterflow alarm operate?	Yes		

INSPECTORS TEST CONNECTION

Report of Inspection / Test

Frequency: Annual ITM

07-16-2025

Property

KESWICK VALLEY MEMORIAL - D14

20 ROUTE 617

BURTT'S CORNER NB E6L 2X3

WO Ref #: 6578530

Conducted by: Roy Barton
NB Sprinkler System Installer 10072972

Troy Life & Fire Safety Ltd
175 Henri Dunant Street
Moncton New Brunswick E1E 1E4
1-877-441-8769



Life & Fire Safety Ltd.

24 HR. SERVICE
1-877-441-8769

troylfs.com

WET 1 (Wet)

Location	Description	Time to Alarm (seconds)	Reported?	Smooth Orifice	Easily Accessible	Signs?	Pass?
Quiet room end of hall second floor	Globe valve	60	Yes	Yes	Yes	Yes	Yes
Rear exit	First Floor	60	Yes	Yes	Yes	Yes	Yes

DRY 1 (Dry)

Location	Description	Time to Alarm (seconds)	Reported?	Smooth Orifice	Easily Accessible	Signs?	Pass?
Quiet room end of hall second floor	Attic	na	N/A	Yes	Yes	Yes	Yes

VALVES

WET 1 (Wet)

Description	Location	Valve Type	Size	Secured	Open	Easily Accessible	Signs	Exercised	Stems Lubricated	Flow Pass	Tamper Pass
System Riser	Tank Room	Butterfly	4 "	Monitored	Yes	Yes	Yes	Yes	N/A	N/A	Pass
Bulk feed second	Sprinkler Room	Butterfly	4 "	Monitored	Yes	Yes	Yes	Yes	N/A	N/A	Pass
Gem	Sprinkler Room	Alarm Valve	4 "	Monitored	N/A	Yes	Yes	Yes	N/A	N/A	N/A
Tank 1	Sprinkler Room	Butterfly	4 "	Monitored	Yes	Yes	Yes	Yes	N/A	N/A	Pass
Tank 2	Sprinkler Room	Butterfly	4 "	Monitored	Yes	Yes	Yes	Yes	N/A	N/A	Pass
Tank room	Sprinkler Room	Butterfly	2 "	Monitored	Yes	Yes	Yes	Yes	N/A	N/A	Pass
Elevator machine room	Above ceiling outside library	Butterfly	1 "	Monitored	Yes	Yes	Yes	Yes	N/A	N/A	Pass
Elevator shaft	Top of stairs before library	Butterfly	1 "	Monitored	Yes	Yes	Yes	Yes	N/A	N/A	Pass
Second floor	Above ceiling in library	Butterfly	3 "	Monitored	Yes	Yes	Yes	Yes	N/A	N/A	Pass
Elevator pit	Tank room	Butterfly	1 "	Monitored	Yes	Yes	Yes	Yes	N/A	N/A	Pass

DRY 1 (Dry)

Description	Location	Valve Type	Size	Secured	Open	Easily Accessible	Signs	Exercised	Stems Lubricated	Flow Pass	Tamper Pass
Attic	Sprinkler Room	Butterfly	4 "	Monitored	Yes	Yes	Yes	Yes	N/A	N/A	Pass
Tyco	Sprinkler Room	Dry Pipe Valve	4 "	Monitored	N/A	Yes	Yes	Yes	N/A	Pass	N/A

DRAIN VALVES

DRY 1 (Dry)

Report of Inspection / Test

Frequency: Annual ITM

07-16-2025

Property

KESWICK VALLEY MEMORIAL - D14

20 ROUTE 617

BURTT'S CORNER NB E6L 2X3

WO Ref #: 6578530

Conducted by: Roy Barton
NB Sprinkler System Installer 10072972

Troy Life & Fire Safety Ltd
175 Henri Dunant Street
Moncton New Brunswick E1E 1E4
1-877-441-8769



Life & Fire Safety Ltd.

24 HR. SERVICE
1-877-441-8769

troylfs.com

Description	Location	Drain	Aux Drain Drained	Water Flow Observed
Main Drain	Tank Room		N/A	Yes

Report of Inspection / Test

Frequency: Annual ITM

07-16-2025

Property

KESWICK VALLEY MEMORIAL - D14
20 ROUTE 617
BURTT'S CORNER NB E6L 2X3

WO Ref #: 6578530

Conducted by: Roy Barton
NB Sprinkler System Installer 10072972

Troy Life & Fire Safety Ltd
175 Henri Dunant Street
Moncton New Brunswick E1E 1E4
1-877-441-8769



Life & Fire Safety Ltd.

24 HR. SERVICE
1-877-441-8769

troylfs.com

Deficiencies - General Questions

Deficiency #1

In last 5 years, have alarm valves and associated strainers, filters, and restricted orifices passed an internal inspection? - 13.4.1.2: No

Status: Critical

Notes:

Deficiency #2

In last 5 years, have the check valves been internally inspected? - 13.4.2.1: No

Status: Critical

Notes:

Deficiency #3

In last 5 years, have strainers, filters, restricted orifices and diaphragm chambers on valves and trim passed internal inspection? - 13.4.1.2: No

Status: Critical

Notes:

Deficiency #4

In the last 5 years, has an internal pipe inspection been performed? - 14.2.1: No

Status: Critical

Notes:

Deficiency #5

Has the piping from the fire department connection to the fire department check valve been hydrostatically tested within the last 5 years?: No

Status: Critical

Notes:

Deficiencies - General Wet System Questions

None

Deficiencies - General Dry System Questions

Deficiency #6

In the last 5 years, have the dry valve(s), strainers, filters and restricted orifices pass internal inspection? - 13.4.5.1.5: No

Status: Critical

Notes:

Deficiencies - WET 1

None

Deficiencies - DRY 1

Report of Inspection / Test

Frequency: Annual ITM

07-16-2025

Property

KESWICK VALLEY MEMORIAL - D14
20 ROUTE 617
BURTT'S CORNER NB E6L 2X3

WO Ref #: 6578530

Conducted by: Roy Barton
NB Sprinkler System Installer 10072972

Troy Life & Fire Safety Ltd
175 Henri Dunant Street
Moncton New Brunswick E1E 1E4
1-877-441-8769



Life & Fire Safety Ltd.

24 HR. SERVICE
1-877-441-8769

troylfs.com

Deficiency #7

Sprinkler Type: Dry

For oil-filled air compressors, has the oil been replaced or changed? - 13.10.4:

No

Status: Critical

Notes:

Deficiencies - Inspectors Test Connection

None

Deficiencies - Valves

None

Deficiencies - Drain Valves

None

Report of Inspection / Test

Frequency: Annual ITM

07-16-2025

Property

KESWICK VALLEY MEMORIAL - D14
20 ROUTE 617
BURTT'S CORNER NB E6L 2X3

WO Ref #: 6578530

Conducted by: Roy Barton
NB Sprinkler System Installer 10072972

Troy Life & Fire Safety Ltd
175 Henri Dunant Street
Moncton New Brunswick E1E 1E4
1-877-441-8769




Life & Fire Safety Ltd.

24 HR. SERVICE
1-877-441-8769

troylfs.com

Inspector Signature

I state that the information on this form is correct at the time and place of my inspection, and all equipment tested at this time was left in operational condition upon completion of this inspection except as noted.

Inspector Name	Signature	Date Completed
Roy Barton NB Sprinkler System Installer 10072972		2025-07-16

Testing and Inspection Report

Double Check Valve Assembly / Pressure Vacuum Breaker / Reduced Pressure Principle

06/21

Distribution Copies: Regional Plumbing Inspector (Photocopy), Occupant or Owner (Original), Licensed Tester (Photocopy)

OFFICE USE ONLY
 Site No. Permit No. Device No.

PLEASE PRINT CLEARLY

Site Name / Occupancy: Keswick Valley Memorial
Civic Number: 20 **Street:** Route 617 **City:** Burtons Corner
Postal Code: **Prov.:** N.B. **Telephone:** **Site Usage:** School

Site Owner: **Site Owner's email:**
Civic Number: **Street:** **City:**
Postal Code: **Prov.:** **Telephone:**

Certified Tester: Roy Banta **Company Name:** Jay Rite Fire **Licence No.:** 71583 **Telephone:** 8579224

Make of Test Kit: Mako **Model No.:** MK3 **Serial No.:** 02AB21010011 **Calibration Due Date:** 2025 10 22

Double Check Valve Assembly Reduced Pressure Principle Pressure Vacuum Breaker (Spill Resistant Yes)

Make of Assembly: Watts **Model No.:** 909 **Serial No.:** 105565 **Size:** 2"

Location of Assembly in Building: Jack Room

Level of Protection: Premise Area Zone Individual

Type of Test: Initial Repair Annual **Date of Test:** 2025 07 16 **Line Pressure at Time of Test:** 47 kPa psi Initial Test Final Test Pass Fail Pass Fail

Tests	Step Component	Test	Requirement	Initial Test	Final Test
REDUCED PRESSURE	1: Relief Valve	Differential pressure relief valve opened at	(2 PSID minimum)	2.7	
	2: Shut Off Valve # 2	<input type="checkbox"/> Leaked <input checked="" type="checkbox"/> Closed Tight			
	3: Check Valve # 2	Reverse flow <input type="checkbox"/> Leaked <input checked="" type="checkbox"/> Closed Tight			
	4: Check Valve # 1	<input type="checkbox"/> Leaked <input checked="" type="checkbox"/> Closed Tight			
	5: Check Valve # 1	Pressure differential across 1 st check		6.1	
	6: Buffer	(Pressure drop across 1 st check minus opening point of relief valve) (min. 3 psi)		3.4	
DOUBLE CHECK VALVE ASSEMBLY	1: Check Valve # 1	Differential pressure in direction of flow	1.0 PSID min		
	2: Check Valve # 2	Differential pressure in direction of flow	1.0 PSID min		
PRESSURE VACUUM BREAKER	1: Air Inlet Valve	Opening Differential	1.0 PSID min		
	2: Check Valve	Closes tight in direction of flow	1.0 PSID min		

If the assembly fails the initial test for any reason, complete this section and note repair below

Comments - Reason for failure (if apparent)

NOTE: PLEASE CONTACT YOUR MUNICIPALITY TO DETERMINE WHETHER THEY ALSO REQUIRE A COPY OF THIS REPORT

REDUCED PRESSURE PRINCIPLE

REPAIRS	Differential Pressure Relief Valve			Check Valve No. 1		Check Valve No. 2		Shut Off Valve No. 2	
	<input type="checkbox"/> Cleaned	Replaced		<input type="checkbox"/> Cleaned	Replaced	<input type="checkbox"/> Cleaned	Replaced	<input type="checkbox"/> Cleaned	Replaced
	<input type="checkbox"/> Disc Upper	<input type="checkbox"/> Diaphragm Sm	<input type="checkbox"/> Diaphragm Lg	<input type="checkbox"/> Disc	<input type="checkbox"/> Pin Retainer	<input type="checkbox"/> Disc	<input type="checkbox"/> Pin Retainer	<input type="checkbox"/> Disc	<input type="checkbox"/> Replaced
	<input type="checkbox"/> Disc Lower	<input type="checkbox"/> Upper	<input type="checkbox"/> Upper	<input type="checkbox"/> Spring	<input type="checkbox"/> Hinged Pin	<input type="checkbox"/> Spring	<input type="checkbox"/> Hinged Pin	<input type="checkbox"/> Seat	<input type="checkbox"/> Replaced
	<input type="checkbox"/> Spring	<input type="checkbox"/> Spacer	<input type="checkbox"/> Lower	<input type="checkbox"/> Guide	<input type="checkbox"/> Diaphragm	<input type="checkbox"/> Guide	<input type="checkbox"/> Diaphragm	<input type="checkbox"/> Other	<input type="checkbox"/> Replaced
	<input type="checkbox"/> Seat	<input type="checkbox"/> Other		<input type="checkbox"/> Seat	<input type="checkbox"/> Other	<input type="checkbox"/> Seat	<input type="checkbox"/> Other		

DOUBLE CHECK VALVE ASSEMBLY

REPAIRS	Check Valve No. 1			Check Valve No. 2			PRESSURE VACUUM BREAKER		
	<input type="checkbox"/> Cleaned	Replaced		<input type="checkbox"/> Cleaned	Replaced		<input type="checkbox"/> Cleaned	Replaced	
	<input type="checkbox"/> Spring	<input type="checkbox"/> Guide	<input type="checkbox"/> Pin Retainer	<input type="checkbox"/> Spring	<input type="checkbox"/> Guide	<input type="checkbox"/> Pin Retainer	<input type="checkbox"/> Vent Spring	<input type="checkbox"/> Poppet	<input type="checkbox"/> Retainer
	<input type="checkbox"/> Hinged Pin	<input type="checkbox"/> Seat	<input type="checkbox"/> Diaphragm	<input type="checkbox"/> Hinged Pin	<input type="checkbox"/> Seat	<input type="checkbox"/> Diaphragm	<input type="checkbox"/> Spring	<input type="checkbox"/> Disc	<input type="checkbox"/> Guide
		<input type="checkbox"/> Disc	<input type="checkbox"/> Other	<input type="checkbox"/> Disc	<input type="checkbox"/> Other		<input type="checkbox"/> Vent Disc	<input type="checkbox"/> Other	

I certify that I have tested the above device in accordance with New Brunswick Regulation 84-187 under the Plumbing Installation and Inspection Act.

Signature of Tester:  **Year:** 2025 **Month:** 07 **Day:** 16



CERTIFICATE OF ANALYSIS / CERTIFICAT D'ANALYSE

for/pour
ASD-W (HZ3)
Department of Education
250 King Street, Place 2000
Fredericton, NB E3B 9M9



921 ch College Hill Rd
Fredericton NB
Canada E3B 6Z9
☎ 506.452.1212
☎ 506.452.1395
www.rpc.ca

Attention: Contacts Education / Distributions List ASD Contacts /
Central Public Health

Microbiological Examination of Water/Qualité microbiologique de l'eau potable

RPC Sample ID/No. d'échantillon de RPC:				560964-1
Client Sample ID/ID d'échantillon du client:				22855 Keswick Valley School
Date collected/Date du prélèvement				29-Jul-25
Time sampled/Heure du prélèvement				2:05:00 PM
Analytes/Paramètre(s)	Method/Méthode	Date Analyzed Date Analysé	Units Unités	
Coliforms/Coliformes	MICRO10	29-Jul-25	P-A/100mL	a
E. coli	MICRO10	29-Jul-25	P-A/100mL	a

This report relates only to the sample(s) and information provided to the laboratory.

Le présent rapport ne s'applique qu'aux échantillons et à l'information transmis au laboratoire.

a = absent/absentes

Cathy Hay
Microbiology Supervisor
Applied and Experimental Bioscience

Josie Michaud
Microbiology Technician
Applied and Experimental Bioscience



FIRE ALARM SYSTEM ANNUAL TEST AND INSPECTION REPORT

CAN/ULC-S536:2019

20.1 Fire Alarm System Annual Test and Inspection Report

NOTE: Refer to 7.1

Inspection Date (DD/MMM/YYYY):	8/11/25		
Report Revision Date (DD/MMM/YYYY)			
Building Name:	KESWICK VALLEY MEMORIAL SCHOOL - ASDW		
Address:	20 ROUTE 617		
City, Province, Postal Code:	BURTTS CORNER, NB		
Building Owner or Representatives Name:	MARK REID		
System Manufacturer:	NOTIFIER	Model:	NSF320C
System Provides:	Single Stage Operation	<input checked="" type="checkbox"/>	
NOTES:	Two Stage Operation	<input type="checkbox"/>	
	Other	<input type="checkbox"/>	
	Describe Special Operation:		

The <i>fire alarm system</i> is connected to a <i>fire signal receiving centre</i> :	Yes	<input checked="" type="checkbox"/>	No	<input type="checkbox"/>	
--	-----	-------------------------------------	----	--------------------------	--

Name, if applicable: ARMSTRONGS

The Report Comprises of:	18	pages
--------------------------	----	-------

The entire <i>fire alarm system</i> has been inspected and tested in accordance with CAN/ULC-S536:2019, Inspection and Testing of Fire Alarm Systems.	Yes	<input checked="" type="checkbox"/>	No	<input type="checkbox"/>	
---	-----	-------------------------------------	----	--------------------------	--

The <i>fire alarm system</i> is fully functional:	Yes	<input checked="" type="checkbox"/>	No	<input type="checkbox"/>	
---	-----	-------------------------------------	----	--------------------------	--

During the Annual Inspection and Test were any Recommendations Identified? See Page 4 if Applicable	Yes	<input type="checkbox"/>	No	<input checked="" type="checkbox"/>	
---	-----	--------------------------	----	-------------------------------------	--

The following person is responsible for ensuring that the information contained in this Test and Inspection Report is correct and complete:	
Printed Name:	PETER TAYLOR
Certificate/ID Number (short formed):	N/A
Signature: (This certifies that the information contained in this Fire Alarm System Annual Test and Inspection Report is correct and complete)	
Company Conducting Test:	QUALITY SOUND ALARM
Company Phone Number:	506-452-0161

Was there a secondary person who conducted the Test and Inspection?	Yes	<input type="checkbox"/>	No	<input checked="" type="checkbox"/>	
Printed Name:					

20.4 Technician Attendance Log

NOTE: See 7.4

Date (MM/DD/YY)	Time In / Time Out	Notes (for the day)	Primary technician printed name	Primary technician certificate no.
8/11/25	1:00 PM - 2:00 PM		PETER TAYLOR	

21 Documentation

NOTE: See Section 7, Documentation.

21.1 Documentation for the *fire alarm system* is available or accessible on site and includes the following description of the *fire alarm system*:

A	Instructions for resetting the system and silencing <i>alarm signals</i> .	Yes	✓	No		
B	Instructions for silencing the <i>trouble signal</i> and action to be taken with the <i>trouble signal</i> sounds.	Yes	✓	No		
C	Description of the function of each operating control and indicator on the fire alarm unit.	Yes	✓	No		
D	Description of the area or fire zone protected by each alarm detection circuit (this may be in the form of a list or	Yes	✓	No		
E	Description of <i>alarm signal</i> operation.	Yes	✓	No		
F	Description of ancillary equipment controlled by the <i>fire alarm</i> system.	Yes	✓	No		
G	In systems that provide logical control of a smoke control system, documentation is on site and includes a sequence of operation of the smoke control system.	Yes		No	✓	
H	Building diagrams are on site that clearly indicate the type and location of all smoke-control equipment (fans, dampers, etc.)	Yes		No	✓	
I	Description of fire alarm system:					
	i) Sequence of operation (See Annex D)	Yes	✓	No		
	ii) Operating instructions (See Annex D)	Yes	✓	No		
	iii) Description of each type of <i>field device</i>	Yes	✓	No		
	iv) Details of input to programmed output functions for programmed systems	Yes	✓	No		
	v) Connection to a fire signal receiving centre, if required by applicable codes and regulations	Yes	✓	No		
	vi) Previous verification report(s) and all documentation related to any modification showing approval of such modifications by the AHJ, if applicable.	Yes		No	✓	N/A
	vii) The as-built drawings of the building fire alarm system (See Annex D)	Yes		No	✓	
	vii) Copy of the site specific software (if applicable)	Yes		No	✓	N/A

J	Indicate location(s) and media type(s) of documentation:

22 Control Unit or Transponder Test Record

YES <input checked="" type="checkbox"/> = Operated Correctly	NO <input type="checkbox"/> = Did no operate correctly (Refer to Deficiencies 20.2)	N/A <input type="checkbox"/> = Not applicable Function or feature not provided on this fire alarm system
--	--	---

22.1 Control Unit or Transponder Inspection

NOTE 1: See 8.2

NOTE 2: Complete section for each control until or transponder

Control Unit or transponder Location:	MAIN OFFICE						
Control Unit or transponder identification:							
A	Input circuit designations correctly identified in relation to connected field devices	Yes	<input checked="" type="checkbox"/>	No	<input type="checkbox"/>	N/A	<input type="checkbox"/>
B	Output circuit designations correctly identified in relation to connected field devices	Yes	<input checked="" type="checkbox"/>	No	<input type="checkbox"/>	N/A	<input type="checkbox"/>
C	Correct designation for common control functions and indicators	Yes	<input checked="" type="checkbox"/>	No	<input type="checkbox"/>	N/A	<input type="checkbox"/>
D	Plug in components and modules securely in place	Yes	<input checked="" type="checkbox"/>	No	<input type="checkbox"/>	N/A	<input type="checkbox"/>
E	Plug in cables securely in place	Yes	<input checked="" type="checkbox"/>	No	<input type="checkbox"/>	N/A	<input type="checkbox"/>
F	(i) Record the date, revision and version of firmware	Date: _____ Rev: _____ Ver: _____					
	(ii) Record the date, revision and version of software program	Date: _____ Rev: _____ Ver: _____					
G	Clean and free of dust and dirt	Yes	<input checked="" type="checkbox"/>	No	<input type="checkbox"/>	N/A	<input type="checkbox"/>
H	Fuses in accordance with manufacture's specification	Yes	<input checked="" type="checkbox"/>	No	<input type="checkbox"/>	N/A	<input type="checkbox"/>
I	Control unit or transponder lock functional	Yes	<input checked="" type="checkbox"/>	No	<input type="checkbox"/>	N/A	<input type="checkbox"/>
J	Termination points from wiring to field devices secure.	Yes	<input checked="" type="checkbox"/>	No	<input type="checkbox"/>	N/A	<input type="checkbox"/>

22.2 Control Unit or Transponder Test Record

NOTE 1: See 8.3

NOTE 2: Complete section for each control until or transponder

Control unit or transponder location	MAIN OFFICE						
Control unit of transponder identification							
A	Power 'ON' visual indicator operates	Yes	<input checked="" type="checkbox"/>	No	<input type="checkbox"/>		<input type="checkbox"/>
B	Time and date indication corresponds with local time and date	Yes	<input checked="" type="checkbox"/>	No	<input type="checkbox"/>	N/A	<input type="checkbox"/>
C	Common visual trouble signal operates	Yes	<input checked="" type="checkbox"/>	No	<input type="checkbox"/>		<input type="checkbox"/>
D	Common audible trouble signal operates	Yes	<input checked="" type="checkbox"/>	No	<input type="checkbox"/>		<input type="checkbox"/>
E	Trouble signal silence switch operates	Yes	<input checked="" type="checkbox"/>	No	<input type="checkbox"/>		<input type="checkbox"/>
F	Main power supply failure trouble signal operates	Yes	<input checked="" type="checkbox"/>	No	<input type="checkbox"/>	N/A	<input type="checkbox"/>

G	Trouble signal operates during positive and negative ground fault tests	Yes	✓	No		N/A	
H	Alert signal operates	Yes		No		N/A	✓
I	Alarm signal operates	Yes	✓	No		N/A	
J	Automatic transfer from alert signal to alarm signal operates	Yes		No		N/A	✓
	Time: _____	Yes		No		N/A	✓
K	Manual transfer from alert signal to alarm signal operates	Yes		No		N/A	✓
L	Automatic transfer from alert signal to alarm signal cancel (acknowledge) feature operates on a two-stage system.	Yes		No		N/A	✓
M	Alarm signal silence inhibit function operates	Yes	✓	No		N/A	
N	Alarm signal manual silence operates.	Yes	✓	No		N/A	
O	Alarm signal silence visual indication operates	Yes	✓	No		N/A	
P	Alarm signals when silenced, automatically reinitiate only upon subsequent alarm from another NBC required fire alarm zone.	Yes	✓	No		N/A	
Q	Duration of alarm signal prior to automatic silence	Time		No		N/A	✓
R	Audible and visual alert signals and alarm signals programmed and operate per design and specification; mor documentation as provided in Section 21.	Time: _____				N/A	✓
S	Input circuit, alarm and supervisory operation, including audible and visual indication operates	Yes	✓	No			
T	Input circuit supervision fault causes a trouble indication	Yes	✓	No		N/A	
U	Output circuit alarm indicators operate	Yes	✓	No		N/A	
V	Output circuit supervision fault causes a trouble indication	Yes	✓	No		N/A	
W	Visual indicator test (lamp test) operates	Yes		No		N/A	✓
X	Coded signal sequences operate not less than the required number of times and the correct alarm signal operates thereafter	Yes		No		N/A	✓
Y	Coded signal sequences are not interrupted by subsequent alarm	Yes		No		N/A	✓
Z	Ancillary device by pass will result in a trouble signal	Yes		No		N/A	✓
AA	Input circuit to output circuit operation, including ancillary device circuits, for correct program operation, as per design and specification, or documentation as detailed in D. Description of Fire Alarm System for Inspection and Test Procedures.	Yes		No		N/A	✓
BB	System Reset Operates	Yes	✓	No			
CC	Main power supply to emergency power supply transfer operates.	Yes	✓	No		N/A	
DD	Smoke detector alarm verification (status change confirmation) verified. [Refer to 14.4.3, Smoke Detector Alarm Verification (Status Change Confirmation)]	Yes		No		N/A	✓

22.3 Voice Communication Test

NOTE: See Subsection 8.5

There are no Voice Communication Capabilities on this system. <input checked="" type="checkbox"/>							
A	Power 'ON' indicator operates	Yes		No		N/A	
B	Common visual trouble signal operates	Yes		No		N/A	
C	Common audible trouble signal operates	Yes		No		N/A	
D	Trouble signal silence switch operates	Yes		No		N/A	

E	All call voice paging, including visual indicator, operates	Yes		No		N/A	
F	Output circuits for selective voice paging, including visual indication operates	Yes		No		N/A	
G	Output circuits for selective voice paging trouble operator, including visual indication, operates	Yes		No		N/A	
H	Microphone, including press to talk switch, operates	Yes		No		N/A	
I	Operation of voice paging does not interfere with initial inhibit time of alert signal or alarm signal	Yes		No		N/A	
J	All-call voice paging operates (on emergency power supply)	Yes		No		N/A	
K	Where systems use back-up amplifiers, the automatic transfer feature operates	Yes		No		N/A	
L	Circuits for emergency telephone call-in operation, including audible and visual indication operates	Yes		No		N/A	
M	Circuits for emergency telephones for operation, including two-way voice communication operates	Yes		No		N/A	
N	Circuits for emergency telephone trouble operation, including visual indication operates	Yes		No		N/A	
O	Emergency telephone verbal communication operates	Yes		No		N/A	
P	Emergency telephone operable or in-use tone at handset operates.	Yes		No		N/A	
Q	In standby mode, a short, or open on a paging alert, alarm, or emergency telephone voice communication buss results in a buss specific trouble condition.	Yes		No		N/A	

22.4 Power Supply Inspection

NOTE: See 9. Power Supplies

Control unit or transponder location		MAIN OFFICE					
Control unit of transponder identification							
Circuit disconnect means or breaker location:		PANEL DP2 ELECTRICAL ROOM					
Circuit disconnect means or breaker identification:		BREAKER #18					
A	Fused in accordance with the manufacturer's marked rating of the system.	Yes	✓	No		N/A	
B	The primary supply is equipped with the identified disconnect means.	Yes	✓	No		N/A	
C	Adequate to meet the requirements of the system.	Yes	✓	No		N/A	
D	A short on the isolated side of each power isolation module results in a trouble condition	Yes		No		N/A	✓
E	Operation of a device on the source side of each shorted power isolation module is confirmed.	Yes		No		N/A	✓
F	Power for ancillary devices is taken form a source separate from the fire alarm system control unit or transponder power supply.	Yes		No		N/A	✓
G	Power for ancillary devices is taken from the control unit or transponder that is designed to provide such power.	Yes		No		N/A	✓
H	Ancillary devices, which are powered from control unit or transponder, are recorded	Yes		No		N/A	✓

22.5 Emergency Power Supply Test and Inspection

NOTE 1: SEE 9.2, 9.3, 9.4 AND Annex C, Battery Tests

NOTE 2: Complete section for each emergency power supply.

Emergency power supply location:		MAIN PANEL					
Emergency power supply identification:							
Emergency power supply provided by:		BATTERIES					

Batteries	<input checked="" type="checkbox"/>	Generator:	<input type="checkbox"/>	UPS:	<input type="checkbox"/>	Combination:	<input type="checkbox"/>
NBC required full load operation time		2 Hour	<input checked="" type="checkbox"/>	1 Hour	<input type="checkbox"/>	30 min	<input type="checkbox"/>
						5 min	<input type="checkbox"/>
Installed batteries	Quantity:	2	V dc:	12	A-h:	18	
BATTERY TESTS (Reference 9.2)							
A	Correct battery type as recommended by manufacturer:	Yes	<input checked="" type="checkbox"/>	No	<input type="checkbox"/>	N/A	<input type="checkbox"/>
B	Correct battery rating as determined by battery calculations based on full system load	Yes	<input checked="" type="checkbox"/>	No	<input type="checkbox"/>	N/A	<input type="checkbox"/>
D	Battery voltage with main power supply 'ON':	Voltage:	27	V dc			
		Current:	2.08	A			
D	Battery voltage and current with main power supply 'OFF' and fire alarm system in supervisory condition	Voltage:	25.8	V dc			
		Current:	0.29	A			
E	Battery voltage and current with main power supply 'OFF' and fire alarm system in full load alarm conditions	Voltage:	25.1	V dc			
		Current:	1.53	A			
F	Battery free of physical damage	Yes	<input checked="" type="checkbox"/>	No	<input type="checkbox"/>	N/A	<input type="checkbox"/>
G	Battery terminals cleaned and lubricated	Yes	<input type="checkbox"/>	No	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
H	Battery terminals clamped tightly	Yes	<input checked="" type="checkbox"/>	No	<input type="checkbox"/>	N/A	<input type="checkbox"/>
I	Correct electrolyte levels	Yes	<input type="checkbox"/>	No	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
J	Specific gravity of electrolyte is within manufacturer's specifications	Yes	<input type="checkbox"/>	No	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
K	Battery free of electrolyte leakage	Yes	<input type="checkbox"/>	No	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
L	Battery adequately ventilated	Yes	<input checked="" type="checkbox"/>	No	<input type="checkbox"/>	N/A	<input type="checkbox"/>
M	Battery manufacturer's date code:	Date:	Aug-25				
N	Disconnection of battery causes trouble signal at the fire alarm control unit.	Yes	<input checked="" type="checkbox"/>	No	<input type="checkbox"/>	N/A	<input type="checkbox"/>
O	Indicate type of battery tests performed:						
	(i) required supervisory load for 24 h followed by the required full load operation or	Yes	<input type="checkbox"/>	No	<input type="checkbox"/>		
	(ii) Silent accelerated test. (Refer to Annex C1, New Silent Accelerated Test Method); or	Yes	<input type="checkbox"/>	No	<input type="checkbox"/>		
	(iii) Battery manufacturer's method. Specify: BATTERY TESTER	Yes	<input checked="" type="checkbox"/>	No	<input type="checkbox"/>		
P	Record calculated battery capacity (Refer to Annex C2)	A.h.					
Q	Record battery terminal voltage after completion of tests.	25.1	V dc				
R	Confirm battery voltage not less than 85% omits rating after the tests.	Yes	<input checked="" type="checkbox"/>	No	<input type="checkbox"/>	N/A	<input type="checkbox"/>
S	Battery Charging Current	2.08	A				
EMERGENCY POWER GENERATOR TESTS (Reference: 9.3)							
A	Generator provides power to AC circuit serving the fire alarm system.	Yes	<input type="checkbox"/>	No	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
B	Trouble condition at the emergency generator shall result in an audible common trouble signal and a visual indication at the required annunciator:	Yes	<input type="checkbox"/>	No	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
C	Generator run condition at the emergency generator shall result in an audible common trouble signal and a visual indication at the required annunciator:	Yes	<input type="checkbox"/>	No	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>

22.6 Annunciator, Remote Trouble Signal Unit, Display and Contr4ol Centre Test and Inspection

NOTE 1: See Section 10

NOTE 2: Complete section for each device.

There are no annunciators or sequential displays on this system. <input checked="" type="checkbox"/>						
Annunciator or sequential display location:						
Annunciator or sequential display identification:						
A	Power "on" indicator operates	Yes		No		N/A
B	Individual alarm, and supervisory input zone designation labels are properly identify	Yes		No		N/A
C	Where individual devices are annunciated confirm the individual alarm and supervisory indication are property identified	Yes		No		N/A
D	Where active and supporting field devices are utilized, the device location and programming device label/descriptor shall be confirmed.	Yes		No		N/A
E	Common trouble signal operates	Yes		No		N/A
F	Visual indicator test (lamp test) operates	Yes		No		N/A
G	Input wiring from control unit or transponder is supervised	Yes		No		N/A
H	Alarm signal silence visual indicator operates	Yes		No		N/A
I	Switches for ancillary functions operate as per design and specification, or in accordance with documentation in Annex D. Description of Fire Alarm Systems for Inspection and Test Procedures	Yes		No		N/A
J	Other ancillary function visual indicators operate	Yes		No		N/A
K	Manual activation of alarm signal and indication operates	Yes		No		N/A
L	Displays are visible in installed location	Yes		No		N/A
M	Operates on emergency power	Yes		No		N/A

22.7 Annunciator or Sequential Display

NOTE 1: See Section 10.2

NOTE 2: If the fire alarm system DOES utilize remove annunciators complete 22.7 for each annunciator or sequential display

There are no annunciators or sequential displays on this system. <input type="checkbox"/>						
Annunciator or sequential display location		MAIN ENTRANCE				
Annunciator or sequential display identification:						
A	Power 'on' indicator operates	Yes	✓	No		N/A
B	Individual alarm and supervisory zone designation labels are properly identified	Yes		No		N/A ✓
C	Where individual devices are also annunciated confirm the individual alarm and supervisory identifications are properly identified.	Yes	✓	No		N/A
D	Where active and supporting field devices are utilized the device location and programmed device label/descriptor shall be confirmed.	Yes		No		N/A ✓
E	Common trouble signal operates	Yes	✓	No		
F	Visual indicator test (lamp test) operates	Yes		No		N/A ✓
G	Input wiring from control until or transponder is supervised	Yes	✓	No		N/A

H	Alarm signal silence visual indicator operates	Yes	<input checked="" type="checkbox"/>	No	<input type="checkbox"/>	N/A	<input type="checkbox"/>
I	Switches for ancillary functions operate as per design and specification, or in accordance with documentation as detailed in section 21 (See section 7)	Yes	<input type="checkbox"/>	No	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
J	Ancillary function visual indicators operate	Yes	<input type="checkbox"/>	No	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
K	Manual activation of alarm signal and indication operates	Yes	<input type="checkbox"/>	No	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
L	Displays are visible in installed location	Yes	<input checked="" type="checkbox"/>	No	<input type="checkbox"/>	N/A	<input type="checkbox"/>
M	Multi-line sequential display operates as per 10.2, where utilized.	Yes	<input checked="" type="checkbox"/>	No	<input type="checkbox"/>	N/A	<input type="checkbox"/>

22.8 Remote Trouble Signal Unit Test and Inspection

NOTE 2: If the fire alarm system DOES utilize remote trouble signal unit, complete 22.8 for each remote trouble unit

There are no remote trouble signal units on this system. <input checked="" type="checkbox"/>							
Remote trouble signal unit location							
Remote trouble signal unit identification							
A	Input wiring from control unit or transponder is supervised	Yes	<input type="checkbox"/>	No	<input type="checkbox"/>	N/A	<input type="checkbox"/>
B	Visual trouble signal operates	Yes	<input type="checkbox"/>	No	<input type="checkbox"/>	N/A	<input type="checkbox"/>
C	Audible trouble signal operates	Yes	<input type="checkbox"/>	No	<input type="checkbox"/>	N/A	<input type="checkbox"/>
D	Audible trouble signal silence operates	Yes	<input type="checkbox"/>	No	<input type="checkbox"/>	N/A	<input type="checkbox"/>

22.9 Printer Test

NOTE: If the fire alarm system DOES utilize printers, complete 22.9 for each printer unit

There are no printers on this system. <input checked="" type="checkbox"/>							
Printer location							
Printer identification							
A	Operates as per design and specification, or in accordance with documentation as detailed in Annex D. Description of Fire Alarm System for Inspection and Test Procedures.	Yes	<input type="checkbox"/>	No	<input type="checkbox"/>	N/A	<input type="checkbox"/>
B	Zone of each alarm initiating device is correctly printed	Yes	<input type="checkbox"/>	No	<input type="checkbox"/>	N/A	<input type="checkbox"/>

22.10 Ancillary Device Circuit Test

Specify type of ancillary circuit	Ancillary circuit powered by:		Operation of ancillary circuit confirmed			Method of Confirmation See Annex A A22.10
	FACU* Check if Applicable	Others Specify:	Yes	No	N/A	
DOOR HOLDERS	<input checked="" type="checkbox"/>		Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>		ACTUAL ALARM
	<input type="checkbox"/>		Yes <input type="checkbox"/>	No <input type="checkbox"/>		

*FCAU - Fire Alarm Control Unit

NOTE: The tests reported on this Form may not include the actual operational test of ancillary devices, except when noted in the Method of Confirmation column. See Annex A A22.10

22.11 Interconnection to the Fire Signal Receiving Centre

NOTE: If the fire alarm system DOES have an interconnection to the fire signal receiving centre, complete 22.11 for each transmitter

There are no interconnections to a Fire Signal Receiving Centre on this system. <input type="checkbox"/>						
A	The fire signal receiving centre transmitter is integral to the fire alarm control unit.	Yes	<input type="checkbox"/>	No	<input checked="" type="checkbox"/>	
B	Receipt of the alarm transmission to the fire signal receiving centre	Yes	<input checked="" type="checkbox"/>	No	<input type="checkbox"/>	
C	Receipt of the supervisory transmission to the fire signal receiving centre	Yes	<input checked="" type="checkbox"/>	No	<input type="checkbox"/>	N/A
D	Receipt of the trouble transmission to the fire signal receiving centre	Yes	<input checked="" type="checkbox"/>	No	<input type="checkbox"/>	
E	Disabling or disconnecting the fire signal receiving centre transmitter results in a specific trouble signal at the control unit or transmitter and also transmits a trouble signal to the fire signal receiving centre	Yes	<input checked="" type="checkbox"/>	No	<input type="checkbox"/>	
F	Disabling or disconnecting the fire signal receiving centre transmitter transmits a trouble signal to the fire signal receiving centre	Yes	<input checked="" type="checkbox"/>	No	<input type="checkbox"/>	
G	Record the company name and telephone number of the fire signal receiving centre: Monitoring Account Number: 03010167	Name:		ARMSTRONGS		
		Telephone:		1-800-561-5433		
H	Operation of the fire signal receiving centre disconnect means transmits trouble to the fire signal receiving centre.	Yes	<input checked="" type="checkbox"/>	No	<input type="checkbox"/>	

23 Field Device Records

23.1 Field Device Testing - Legend and Notes

NOTE: Add additional line items for each additional type and/or model number of devices forming part of the fire alarm system as necessary

Device Type	Description	Type	Model No.
M	Manual pull station	NOTIFIER	N6 B121X
RHT	Heat detector, restorable		
HT	Heat detector, non restorable		
S	Smoke detector	Not applicable	Not applicable
	Sensitivity Test Method or Test Equipment:		
	Model/Method:		
	Manufacturer Sensitivity Range:		
	Note: CAN/ULC-SS29 required range is 0.5 to 4.0 %/ft obscuration. Recorded sensitivity measurement units may not be in %/ft depend upon the testing method		
SB	Sounder base		
RI	Remote indicator unit		
DS	Duct smoke detector	SYSTEM SENSOR	
-	Other type of detector		
SFD	Supporting field device (monitor)		
FS	Sprinkler flow switch		
SS	Sprinkler supervisory device		
-	Other supervisory devices (low pressure, low water, low temperature, power loss, etc.)		
EM	Fault isolator		
B	Bell		
H	Horn	SYSTEM SENSOR	HRA
HSP	Horn/Strobe		
V	Visible signal device		
SP	Cone type speaker		
HSP	Horn type speaker		
SSS	Suite Silencing Switch		
SSAD	Suite Silencing Audible Device		
AD	Ancillary Device		
ET	Emergency Telephone		
EOL	End-of-Line Device		

NOTE: Refer to Section 14. Field Devices

23.1.1 The following notes apply to 23.2. Individual Device Record:

- Note 1 Smoke detector sensitivity reading confirmed by the control panel or measurement obtained through testing to be recorded in the measurements column.
- Note 2 Smoke detector cleaning or replacement date to also be recorded in the measurements column
- Note 3 Status Change, including time delay, to be recorded in the measurements column. Refer to Annex A3.73 and Annex F
- Note 4 Duct smoke detectors pressure differential to be confirmed and recorded in the measurement column.
- Note 5 Transport time of air sampling type detector to be confirmed and recorded in the measurements column
- Note 6 Time delay setting of water flow device to be recorded in the measurements column
- Note 7 Sprinkler supervisory switches cause trouble conditions to be annunciated but not an alarm condition
- Note 8 Upper and Lower pressure setting of supervisory devices to be recorded in the measurements column
- Note 9 Low temperature setting to be recorded in the measurements column
- Note 10 Identify the specific ancillary devices in the comments column
- Note 11 The date and any field devices is changed should be recorded in the comments column
- Note 12 Identify correct field device operation (e.g. alarm, trouble, supervisory, annunciation indication)
- Note 13 Identify zone, circuit number or address
- Note 14 Identify conventional field device locations.
- Note 15 Identify active field device and supporting field device, data communication link (DCL) address and location.
- Note 16 Confirm field device free of damage
- Note 17 Confirm field device free of foreign substance
- Note 18 Confirm field device mechanically supported independently of the wiring
- Note 19 Confirm field device protection dust shields or covers removed
- Note 20 "Correctly installed" refers to the version of CAN/ULC-S524, Standard for Installation of Fire Alarm Systems, applicable at
- Note 21 Smoke detectors that employ sounder bases or activate local audible signaling device(s) used in lieu of smoke alarms, to be tested to confirm the local sounder operation and annunciation at the control panel, including visible device operation, as applicable, and individually recorded.
- Note 22 When batteries are replaced in the short-range radio frequency (wireless) devices, battery replacement date to be identified in the common section.



23.3 Circuit Fault Tolerance Test Sheet

NOTE 1: Refer to Section 12 and 13

NOTE 2: Refer to Annex A A3.96 for an explanation regarding the National Building Code (NBC) Fire Alarm (FA) Zone.

Circuit Fault Tolerance Test Sheet

Building Name: _____ Date: _____ Page ___ of ___

Circuit fault test location	Type of fault (Record response time or indicate N/A.)			Isolation Results	Non-faulted circuit location	
	Short	Open	Ground		Identify Individual device tested for operation located in Non Faulted NBC Fire Alarm zone or area.	Pass/Fail
Identify Device Location where circuit fault was introduced and description of affected NBC Fire Alarm zone or area.				Identify NBC Fire Alarm Zone or area location where devices failed due to fault condition.		

MONTHLY FIRE ALARM SYSTEM TEST AND INSPECTION REPORT

24 MONTHLY FIRE ALARM SYSTEM TEST AND INSPECTION REPORT

23.2 Individual Device Record

Device Location	Annunciated Device Label/LCD Text (if applicable)	Device Type (Or Abbreviation)	Requires Service or Missing	Circuit Number or Device Address	Annunciated FIRE ZONE	Correctly Installed	Measurements	Alarm/Activation Confirmed	Annunciator Indication	Supervised Circuit Trouble Signal	General Alarm Circuit (if Applicable)	Comments
MAIN ENTRANCE		PULL		2	✓	✓		✓		✓		
EXIT REAR		PULL		2	✓	✓		✓		✓		
FIRST FLOOR CORRIDOR		HSP		1		✓		✓		✓		
GYM		HSP		1		✓		✓		✓		
GYM EXIT		PULL		2	✓	✓		✓		✓		
1ST FLOOR CORRIDOR		SMOKE		2	✓	✓		✓		✓		
LOCKER AREA		HSP		1		✓		✓		✓		
REAR EXIT		SMOKE		2	✓	✓		✓		✓		
REAR EXIT		PULL		2	✓	✓		✓		✓		
CAFETERIA EXIT		PULL		3	✓	✓		✓		✓		
KITCHEN EXIT		PULL		3	✓	✓		✓		✓		
CAFETERIA		HSP		1		✓		✓		✓		
1ST FLOOR CORRIDOR		HSP		1		✓		✓		✓		
1ST FLOOR CORRIDOR		SMOKE		2	✓	✓		✓		✓		
FIRST FLOOR EXIT		PULL		2	✓	✓		✓		✓		
1ST FLOOR CORRIDOR		SMOKE		3	✓	✓		✓		✓		
MECHANICAL ROOM		DUCT		7	✓	✓		✓		✓		
MECHANICAL ROOM		PULL		2	✓	✓		✓		✓		
1ST FLOOR CORRIDOR		HSP		1		✓		✓		✓		
1ST FLOOR CORRIDOR		HSP		1		✓		✓		✓		
1ST FLOOR CORRIDOR		SMOKE		2	✓	✓		✓		✓		
1ST FLOOR EXIT		PULL		2	✓	✓		✓		✓		
2ND FLOOR EXIT		SMOKE		5	✓	✓		✓		✓		

Device Location	Annunciated Device Label/LCD Text (if applicable)	Device Type (Or Abbreviation)	Requires Service or Missing	Circuit Number or Device Address	Annunciated FIRE ZONE	Correctly Installed	Measurements	Alarm/Activation Confirmed	Annunciator Indication	Supervised Circuit Trouble Signal	General Alarm Circuit (if Applicable)	Comments
2ND FLOOR CORRIDOR		PULL		5	✓	✓		✓		✓		
2ND FLOOR CORRIDOR		HSP		2		✓		✓		✓		
2ND FLOOR EXIT		PULL		5	✓	✓		✓		✓		
2ND FLOOR CORRIDOR		SMOKE		5	✓	✓		✓		✓		
2ND FLOOR CORRIDOR		SMOKE		5	✓	✓		✓		✓		
2ND FLOOR CORRIDOR		HSP		2		✓		✓		✓		
2ND FLOOR MECHANICAL ROOM		DUCT		5	✓	✓		✓		✓		
2ND FLOOR CORRIDOR		HSP		2		✓		✓		✓		
2ND FLOOR EXIT		PULL		5	✓	✓		✓		✓		
2ND FLOOR EXIT		SMOKE		5	✓	✓		✓		✓		
SPRINKLER ROOM		PULL		5	✓	✓		✓		✓		
SPRINKLER ROOM		HSP		2		✓		✓		✓		
STAIRWELL EAST		SMOKE			✓	✓		✓		✓		
STAIRWELL WEST		SMOKE			✓	✓		✓		✓		
STAIRWELL NORTH		SMOKE			✓	✓		✓		✓		
BOYS CHANGE ROOM		HSP		1		✓		✓		✓		
GIRLS CHANGE ROOM		HSP		1		✓		✓		✓		
ATTIC / BASEMENT		FLOW		6								TESTED BY OTHERS
2ND FLOOR CLASSROOMS		FLOW		5								TESTED BY OTHERS
ELEVATOR BOTTOM		TAMPER		6								TESTED BY OTHERS
WET SYSTEM BASEMENT		TAMPER		6								TESTED BY OTHERS
DRY SYSTEM BASEMENT		TAMPER										TESTED BY OTHERS
LOW AIR DRY		LOW AIR		6								TESTED BY OTHERS
LOW WATER WET		LOW WTR										TESTED BY OTHERS
2ND FLOOR CLASSROOMS		TAMPER		5								TESTED BY OTHERS

Report ID: 562933-IAS
 Report Date: 09-Sep-25
 Date Received: 25-Aug-25

CERTIFICATE OF ANALYSIS

for
 ASD-W (HZ3)
 Department of Education
 250 King Street, Place 2000
 Fredericton, NB E3B 9M9



921 College Hill Rd
 Fredericton NB
 Canada E3B 6Z9
 Tel: 506.452.1212
 Fax: 506.452.0594
 www.rpc.ca

Attention: Contacts Education
Project #: Not Available

Analysis of Potable Water

RPC Sample ID:					562933-1
Client Sample ID:					23223 Harvey Elementary School DWS #2
Date Sampled:					25-Aug-25
Analyses	Units	RL	MAC	AO	
Alkalinity (as CaCO ₃)	mg/L	2	-	-	150
Chloride	mg/L	0.5	-	250	53.2
Colour	TCU	5	-	15	< 5
Conductivity	µS/cm	1	-	-	475
Fluoride	mg/L	0.05	1.5	-	1.7
Nitrate + Nitrite (as N)	mg/L	0.05	10	-	1.57
Nitrate (as N)	mg/L	0.05	10	-	1.57
Nitrite (as N)	mg/L	0.05	1	-	< 0.05
pH	units	-	-	-	7.4
Phosphorus	mg/L	0.02	-	-	< 0.02
Sulfate	mg/L	1	-	500	9
Turbidity	NTU	0.1	-	-	0.3
Calculated Parameters					
Hardness (as CaCO ₃)	mg/L	0.2	-	-	170
TDS (calc)	mg/L	-	-	500	266
Saturation pH (5°C)	units	-	-	-	7.7
Langelier Index (5°C)	-	-	-	-	-0.29

This report relates only to the sample(s) and information provided to the laboratory.

RL = Reporting Limit; MAC = Maximum Acceptable Concentration; AO = Aesthetic Objective

Guidelines are from Guidelines for Canadian Drinking Water Quality (February 2017).

Troy Smith
 Supervisor
 Inorganic Analytical Services

Krista Skinner
 Senior Chemical Technician
 Inorganic Analytical Services

Report ID: 562933-IAS
 Report Date: 09-Sep-25
 Date Received: 25-Aug-25

CERTIFICATE OF ANALYSIS

for
 ASD-W (HZ3)
 Department of Education
 250 King Street, Place 2000
 Fredericton, NB E3B 9M9



921 College Hill Rd
 Fredericton NB
 Canada E3B 6Z9
 Tel: 506.452.1212
 Fax: 506.452.0594
 www.rpc.ca

Attention: Contacts Education

Project #: Not Available

Analysis of Potable Water

RPC Sample ID:					562933-2
Client Sample ID:					23234 Keswick Ridge School DWS
Date Sampled:					25-Aug-25
Analytes	Units	RL	MAC	AO	
Alkalinity (as CaCO ₃)	mg/L	2	-	-	170
Chloride	mg/L	0.5	-	250	1.5
Colour	TCU	5	-	15	< 5
Conductivity	µS/cm	1	-	-	367
Fluoride	mg/L	0.05	1.5	-	0.12
Nitrate + Nitrite (as N)	mg/L	0.05	10	-	< 0.05
Nitrate (as N)	mg/L	0.05	10	-	< 0.05
Nitrite (as N)	mg/L	0.05	1	-	< 0.05
pH	units	-	-	-	7.6
Phosphorus	mg/L	0.02	-	-	< 0.02
Sulfate	mg/L	1	-	500	13
Turbidity	NTU	0.1	-	-	0.2
Calculated Parameters					
Hardness (as CaCO ₃)	mg/L	0.2	-	-	189
TDS (calc)	mg/L	-	-	500	195
Saturation pH (5°C)	units	-	-	-	7.6
Langelier Index (5°C)	-	-	-	-	0.04

This report relates only to the sample(s) and information provided to the laboratory.

RL = Reporting Limit; MAC = Maximum Acceptable Concentration; AO = Aesthetic Objective

Guidelines are from Guidelines for Canadian Drinking Water Quality (February 2017).

Report ID: 562933-IAS
 Report Date: 09-Sep-25
 Date Received: 25-Aug-25

CERTIFICATE OF ANALYSIS

for
 ASD-W (HZ3)
 Department of Education
 250 King Street, Place 2000
 Fredericton, NB E3B 9M9



921 College Hill Rd
 Fredericton NB
 Canada E3B 6Z9
 Tel: 506.452.1212
 Fax: 506.452.0594
 www.rpc.ca

Attention: Contacts Education

Project #: Not Available

Analysis of Potable Water

RPC Sample ID:					562933-3
Client Sample ID:					23245 Harvey High School DWS
Date Sampled:					25-Aug-25
Analytes	Units	RL	MAC	AO	
Alkalinity (as CaCO ₃)	mg/L	2	-	-	170
Chloride	mg/L	0.5	-	250	342
Colour	TCU	5	-	15	< 5
Conductivity	µS/cm	1	-	-	1480
Fluoride	mg/L	0.05	1.5	-	0.33
Nitrate + Nitrite (as N)	mg/L	0.05	10	-	0.55
Nitrate (as N)	mg/L	0.05	10	-	0.55
Nitrite (as N)	mg/L	0.05	1	-	< 0.05
pH	units	-	-	-	7.3
Phosphorus	mg/L	0.02	-	-	< 0.04
Sulfate	mg/L	1	-	500	17
Turbidity	NTU	0.1	-	-	< 0.1
Calculated Parameters					
Hardness (as CaCO ₃)	mg/L	0.2	-	-	495
TDS (calc)	mg/L	-	-	500	733
Saturation pH (5°C)	units	-	-	-	7.3
Langelier Index (5°C)	-	-	-	-	0.03

This report relates only to the sample(s) and information provided to the laboratory.

RL = Reporting Limit; MAC = Maximum Acceptable Concentration; AO = Aesthetic Objective

Guidelines are from Guidelines for Canadian Drinking Water Quality (February 2017).

Report ID: 562933-IAS
 Report Date: 09-Sep-25
 Date Received: 25-Aug-25

CERTIFICATE OF ANALYSIS

for
 ASD-W (HZ3)
 Department of Education
 250 King Street, Place 2000
 Fredericton, NB E3B 9M9



921 College Hill Rd
 Fredericton NB
 Canada E3B 6Z9
 Tel: 506.452.1212
 Fax: 506.452.0594
 www.rpc.ca

Attention: Contacts Education
Project #: Not Available

Analysis of Potable Water

RPC Sample ID:					562933-4
Client Sample ID:					22855 Keswick Valley School
Date Sampled:					25-Aug-25
Analytes	Units	RL	MAC	AO	
Alkalinity (as CaCO ₃)	mg/L	2	-	-	140
Chloride	mg/L	0.5	-	250	10
Colour	TCU	5	-	15	< 5
Conductivity	µS/cm	1	-	-	296
Fluoride	mg/L	0.05	1.5	-	0.80
Nitrate + Nitrite (as N)	mg/L	0.05	10	-	< 0.05
Nitrate (as N)	mg/L	0.05	10	-	< 0.05
Nitrite (as N)	mg/L	0.05	1	-	< 0.05
pH	units	-	-	-	8.0
Phosphorus	mg/L	0.02	-	-	< 0.02
Sulfate	mg/L	1	-	500	7
Turbidity	NTU	0.1	-	-	0.2
Calculated Parameters					
Hardness (as CaCO ₃)	mg/L	0.2	-	-	77.0
TDS (calc)	mg/L	-	-	500	166
Saturation pH (5°C)	units	-	-	-	8.1
Langelier Index (5°C)	-	-	-	-	-0.11

This report relates only to the sample(s) and information provided to the laboratory.

RL = Reporting Limit; MAC = Maximum Acceptable Concentration; AO = Aesthetic Objective

Guidelines are from Guidelines for Canadian Drinking Water Quality (February 2017).

Report ID: 562933-IAS
 Report Date: 09-Sep-25
 Date Received: 25-Aug-25

CERTIFICATE OF ANALYSIS

for
 ASD-W (HZ3)
 Department of Education
 250 King Street, Place 2000
 Fredericton, NB E3B 9M9



921 College Hill Rd
 Fredericton NB
 Canada E3B 6Z9
 Tel: 506.452.1212
 Fax: 506.452.0594
 www.rpc.ca

Attention: Contacts Education
Project #: Not Available

Analysis of Potable Water

RPC Sample ID:					562933-5
Client Sample ID:					26539 Hanwell Park Academy
Date Sampled:					25-Aug-25
Analytes	Units	RL	MAC	AO	
Alkalinity (as CaCO ₃)	mg/L	2	-	-	100
Chloride	mg/L	0.5	-	250	2.6
Colour	TCU	5	-	15	< 5
Conductivity	µS/cm	1	-	-	210
Fluoride	mg/L	0.05	1.5	-	0.22
Nitrate + Nitrite (as N)	mg/L	0.05	10	-	< 0.05
Nitrate (as N)	mg/L	0.05	10	-	< 0.05
Nitrite (as N)	mg/L	0.05	1	-	< 0.05
pH	units	-	-	-	8.0
Phosphorus	mg/L	0.02	-	-	< 0.02
Sulfate	mg/L	1	-	500	8
Turbidity	NTU	0.1	-	-	0.3
Calculated Parameters					
Hardness (as CaCO ₃)	mg/L	0.2	-	-	83.2
TDS (calc)	mg/L	-	-	500	115
Saturation pH (5°C)	units	-	-	-	8.1
Langelier Index (5°C)	-	-	-	-	-0.12

This report relates only to the sample(s) and information provided to the laboratory.

RL = Reporting Limit; MAC = Maximum Acceptable Concentration; AO = Aesthetic Objective

Guidelines are from Guidelines for Canadian Drinking Water Quality (February 2017).

Report ID: 562933-IAS
 Report Date: 09-Sep-25
 Date Received: 25-Aug-25

CERTIFICATE OF ANALYSIS

for
 ASD-W (HZ3)
 Department of Education
 250 King Street, Place 2000
 Fredericton, NB E3B 9M9



921 College Hill Rd
 Fredericton NB
 Canada E3B 6Z9
 Tel: 506.452.1212
 Fax: 506.452.0594
 www.rpc.ca

Attention: Contacts Education

Project #: Not Available

Analysis of Metals in Potable Water

RPC Sample ID:					562933-1
Client Sample ID:					23223 Harvey Elementary School DWS #2
Date Sampled:					25-Aug-25
Analytes	Units	RL	MAC	AO	
Aluminum	mg/L	0.001	-	-	0.005
Antimony	mg/L	0.0001	0.006	-	0.0029
Arsenic	mg/L	0.001	0.01	-	0.323
Barium	mg/L	0.001	1	-	< 0.001
Beryllium	mg/L	0.0001	-	-	0.0006
Bismuth	mg/L	0.001	-	-	< 0.001
Boron	mg/L	0.001	5	-	0.018
Cadmium	mg/L	0.00001	0.005	-	0.00007
Calcium	mg/L	0.05	-	-	59.1
Chromium	mg/L	0.001	0.05	-	< 0.001
Cobalt	mg/L	0.0001	-	-	< 0.0001
Copper	mg/L	0.001	-	1	0.027
Iron	mg/L	0.02	-	0.3	< 0.02
Lead	mg/L	0.0001	0.01	-	0.0005
Lithium	mg/L	0.0001	-	-	0.415
Magnesium	mg/L	0.01	-	-	5.46
Manganese	mg/L	0.001	-	0.05	< 0.001
Mercury	mg/L	0.000025	0.001	-	< 0.000025
Molybdenum	mg/L	0.0001	-	-	0.0062
Nickel	mg/L	0.001	-	-	< 0.001
Potassium	mg/L	0.02	-	-	1.03
Rubidium	mg/L	0.0001	-	-	0.0061
Selenium	mg/L	0.001	0.05	-	< 0.001
Silver	mg/L	0.0001	-	-	< 0.0001
Sodium	mg/L	0.05	-	200	37.9
Strontium	mg/L	0.001	-	-	0.627
Tellurium	mg/L	0.0001	-	-	< 0.0001
Thallium	mg/L	0.0001	-	-	< 0.0001
Tin	mg/L	0.0001	-	-	< 0.0001
Uranium	mg/L	0.0001	0.02	-	0.0765
Vanadium	mg/L	0.001	-	-	< 0.001
Zinc	mg/L	0.001	-	5	0.013

Report ID: 562933-IAS
 Report Date: 09-Sep-25
 Date Received: 25-Aug-25

CERTIFICATE OF ANALYSIS

for
 ASD-W (HZ3)
 Department of Education
 250 King Street, Place 2000
 Fredericton, NB E3B 9M9



921 College Hill Rd
 Fredericton NB
 Canada E3B 6Z9
 Tel: 506.452.1212
 Fax: 506.452.0594
 www.rpc.ca

Attention: Contacts Education
Project #: Not Available

Analysis of Metals in Potable Water

RPC Sample ID:					562933-2
Client Sample ID:					23234 Keswick Ridge School DWS
Date Sampled:					25-Aug-25
Analytes	Units	RL	MAC	AO	
Aluminum	mg/L	0.001	-	-	< 0.001
Antimony	mg/L	0.0001	0.006	-	0.0002
Arsenic	mg/L	0.001	0.01	-	< 0.001
Barium	mg/L	0.001	1	-	0.232
Beryllium	mg/L	0.0001	-	-	< 0.0001
Bismuth	mg/L	0.001	-	-	< 0.001
Boron	mg/L	0.001	5	-	0.005
Cadmium	mg/L	0.00001	0.005	-	< 0.00001
Calcium	mg/L	0.05	-	-	69.4
Chromium	mg/L	0.001	0.05	-	< 0.001
Cobalt	mg/L	0.0001	-	-	0.0002
Copper	mg/L	0.001	-	1	0.026
Iron	mg/L	0.02	-	0.3	< 0.02
Lead	mg/L	0.0001	0.01	-	0.0004
Lithium	mg/L	0.0001	-	-	0.0025
Magnesium	mg/L	0.01	-	-	3.84
Manganese	mg/L	0.001	-	0.05	0.019
Mercury	mg/L	0.000025	0.001	-	< 0.000025
Molybdenum	mg/L	0.0001	-	-	0.0004
Nickel	mg/L	0.001	-	-	< 0.001
Potassium	mg/L	0.02	-	-	0.58
Rubidium	mg/L	0.0001	-	-	0.0007
Selenium	mg/L	0.001	0.05	-	< 0.001
Silver	mg/L	0.0001	-	-	< 0.0001
Sodium	mg/L	0.05	-	200	2.64
Strontium	mg/L	0.001	-	-	0.368
Tellurium	mg/L	0.0001	-	-	< 0.0001
Thallium	mg/L	0.0001	-	-	< 0.0001
Tin	mg/L	0.0001	-	-	< 0.0001
Uranium	mg/L	0.0001	0.02	-	0.0008
Vanadium	mg/L	0.001	-	-	< 0.001
Zinc	mg/L	0.001	-	5	0.011

Report ID: 562933-IAS
 Report Date: 09-Sep-25
 Date Received: 25-Aug-25

CERTIFICATE OF ANALYSIS

for
 ASD-W (HZ3)
 Department of Education
 250 King Street, Place 2000
 Fredericton, NB E3B 9M9



921 College Hill Rd
 Fredericton NB
 Canada E3B 6Z9
 Tel: 506.452.1212
 Fax: 506.452.0594
 www.rpc.ca

Attention: Contacts Education
Project #: Not Available

Analysis of Metals in Potable Water

RPC Sample ID:					562933-3
Client Sample ID:					23245 Harvey High School DWS
Date Sampled:					25-Aug-25
Analytes	Units	RL	MAC	AO	
Aluminum	mg/L	0.001	-	-	< 0.002
Antimony	mg/L	0.0001	0.006	-	< 0.0002
Arsenic	mg/L	0.001	0.01	-	< 0.002
Barium	mg/L	0.001	1	-	0.387
Beryllium	mg/L	0.0001	-	-	< 0.0002
Bismuth	mg/L	0.001	-	-	< 0.002
Boron	mg/L	0.001	5	-	0.017
Cadmium	mg/L	0.00001	0.005	-	< 0.00002
Calcium	mg/L	0.05	-	-	169.
Chromium	mg/L	0.001	0.05	-	< 0.002
Cobalt	mg/L	0.0001	-	-	< 0.0002
Copper	mg/L	0.001	-	1	0.036
Iron	mg/L	0.02	-	0.3	< 0.04
Lead	mg/L	0.0001	0.01	-	0.0018
Lithium	mg/L	0.0001	-	-	0.0555
Magnesium	mg/L	0.01	-	-	17.8
Manganese	mg/L	0.001	-	0.05	0.004
Mercury	mg/L	0.000025	0.001	-	< 0.000025
Molybdenum	mg/L	0.0001	-	-	0.0019
Nickel	mg/L	0.001	-	-	< 0.002
Potassium	mg/L	0.02	-	-	3.02
Rubidium	mg/L	0.0001	-	-	0.0131
Selenium	mg/L	0.001	0.05	-	< 0.002
Silver	mg/L	0.0001	-	-	< 0.0002
Sodium	mg/L	0.05	-	200	77.9
Strontium	mg/L	0.001	-	-	1.64
Tellurium	mg/L	0.0001	-	-	< 0.0002
Thallium	mg/L	0.0001	-	-	< 0.0002
Tin	mg/L	0.0001	-	-	< 0.0002
Uranium	mg/L	0.0001	0.02	-	0.0002
Vanadium	mg/L	0.001	-	-	< 0.002
Zinc	mg/L	0.001	-	5	0.098

Report ID: 562933-IAS
 Report Date: 09-Sep-25
 Date Received: 25-Aug-25

CERTIFICATE OF ANALYSIS

for
 ASD-W (HZ3)
 Department of Education
 250 King Street, Place 2000
 Fredericton, NB E3B 9M9



921 College Hill Rd
 Fredericton NB
 Canada E3B 6Z9
 Tel: 506.452.1212
 Fax: 506.452.0594
 www.rpc.ca

Attention: Contacts Education

Project #: Not Available

Analysis of Metals in Potable Water

RPC Sample ID:					562933-4
Client Sample ID:					22855 Keswick Valley School
Date Sampled:					25-Aug-25
Analytes	Units	RL	MAC	AO	
Aluminum	mg/L	0.001	-	-	< 0.001
Antimony	mg/L	0.0001	0.006	-	< 0.0001
Arsenic	mg/L	0.001	0.01	-	< 0.001
Barium	mg/L	0.001	1	-	0.045
Beryllium	mg/L	0.0001	-	-	< 0.0001
Bismuth	mg/L	0.001	-	-	< 0.001
Boron	mg/L	0.001	5	-	0.015
Cadmium	mg/L	0.00001	0.005	-	< 0.00001
Calcium	mg/L	0.05	-	-	22.4
Chromium	mg/L	0.001	0.05	-	< 0.001
Cobalt	mg/L	0.0001	-	-	< 0.0001
Copper	mg/L	0.001	-	1	0.006
Iron	mg/L	0.02	-	0.3	0.10
Lead	mg/L	0.0001	0.01	-	0.0006
Lithium	mg/L	0.0001	-	-	0.0032
Magnesium	mg/L	0.01	-	-	5.12
Manganese	mg/L	0.001	-	0.05	0.133
Mercury	mg/L	0.000025	0.001	-	< 0.000025
Molybdenum	mg/L	0.0001	-	-	0.0092
Nickel	mg/L	0.001	-	-	< 0.001
Potassium	mg/L	0.02	-	-	1.19
Rubidium	mg/L	0.0001	-	-	0.0002
Selenium	mg/L	0.001	0.05	-	< 0.001
Silver	mg/L	0.0001	-	-	< 0.0001
Sodium	mg/L	0.05	-	200	33.4
Strontium	mg/L	0.001	-	-	0.211
Tellurium	mg/L	0.0001	-	-	< 0.0001
Thallium	mg/L	0.0001	-	-	< 0.0001
Tin	mg/L	0.0001	-	-	< 0.0001
Uranium	mg/L	0.0001	0.02	-	0.0019
Vanadium	mg/L	0.001	-	-	< 0.001
Zinc	mg/L	0.001	-	5	0.055

Report ID: 562933-IAS
 Report Date: 09-Sep-25
 Date Received: 25-Aug-25

CERTIFICATE OF ANALYSIS

for
 ASD-W (HZ3)
 Department of Education
 250 King Street, Place 2000
 Fredericton, NB E3B 9M9



921 College Hill Rd
 Fredericton NB
 Canada E3B 6Z9
 Tel: 506.452.1212
 Fax: 506.452.0594
 www.rpc.ca

Attention: Contacts Education

Project #: Not Available

Analysis of Metals in Potable Water

RPC Sample ID:					562933-5
Client Sample ID:					26539 Hanwell Park Academy
Date Sampled:					25-Aug-25
Analytes	Units	RL	MAC	AO	
Aluminum	mg/L	0.001	-	-	0.013
Antimony	mg/L	0.0001	0.006	-	< 0.0001
Arsenic	mg/L	0.001	0.01	-	0.003
Barium	mg/L	0.001	1	-	0.034
Beryllium	mg/L	0.0001	-	-	< 0.0001
Bismuth	mg/L	0.001	-	-	< 0.001
Boron	mg/L	0.001	5	-	0.012
Cadmium	mg/L	0.00001	0.005	-	< 0.00001
Calcium	mg/L	0.05	-	-	29.3
Chromium	mg/L	0.001	0.05	-	< 0.001
Cobalt	mg/L	0.0001	-	-	0.0002
Copper	mg/L	0.001	-	1	0.099
Iron	mg/L	0.02	-	0.3	< 0.02
Lead	mg/L	0.0001	0.01	-	< 0.0001
Lithium	mg/L	0.0001	-	-	0.0069
Magnesium	mg/L	0.01	-	-	2.43
Manganese	mg/L	0.001	-	0.05	< 0.001
Mercury	mg/L	0.000025	0.001	-	< 0.000025
Molybdenum	mg/L	0.0001	-	-	0.0014
Nickel	mg/L	0.001	-	-	< 0.001
Potassium	mg/L	0.02	-	-	0.94
Rubidium	mg/L	0.0001	-	-	0.0019
Selenium	mg/L	0.001	0.05	-	< 0.001
Silver	mg/L	0.0001	-	-	< 0.0001
Sodium	mg/L	0.05	-	200	10.7
Strontium	mg/L	0.001	-	-	0.654
Tellurium	mg/L	0.0001	-	-	< 0.0001
Thallium	mg/L	0.0001	-	-	< 0.0001
Tin	mg/L	0.0001	-	-	< 0.0001
Uranium	mg/L	0.0001	0.02	-	0.0012
Vanadium	mg/L	0.001	-	-	0.002
Zinc	mg/L	0.001	-	5	0.007

Report ID: 562933-IAS
Report Date: 09-Sep-25
Date Received: 25-Aug-25

CERTIFICATE OF ANALYSIS

for
ASD-W (HZ3)
Department of Education
250 King Street, Place 2000
Fredericton, NB E3B 9M9

rpc

921 College Hill Rd
Fredericton NB
Canada E3B 6Z9
Tel: 506.452.1212
Fax: 506.452.0594
www.rpc.ca

Methods

<u>Analyte</u>	<u>RPC SOP #</u>	<u>Method Reference</u>	<u>Method Principle</u>
pH	IAS-M03	APHA 4500-H ⁺ B	pH Electrode - Electrometric
Alkalinity (as CaCO ₃)	IAS-M43	EPA 310.2	Methyl Orange Colourimetry
Chloride	IAS-M44	APHA 4500-CL E	Ferricyanide Colourimetry
Fluoride	IAS-M30	APHA 4500-F- D	SPADNS Colourimetry
Sulfate	IAS-M45	APHA 4500-SO ₄ E	Turbidimetry
Nitrate + Nitrite (as N)	IAS-M48	APHA 4500-NO ₃ H	Hydrazine Red., Derivitization, Colourimetry
Nitrite (as N)	IAS-M49	APHA 4500-NO ₂ - B	NED/sulfanilamide Colourimetry
Turbidity	IAS-M06	APHA 2130 B	Nephelometry
Colour	IAS-M55	APHA 2120 Color (A,C)	Single Wavelength Spectrophotometry
Conductivity	IAS-M04	APHA 2510 B	Conductivity Meter - Electrode
Trace Metals	IAS-M01/IAS-M29	EPA 200.8/EPA 200.7	ICP-MS/ICP-ES
Mercury	IAS-M52	EPA 245.1	Cold Vapor AAS

CERTIFICATE OF ANALYSIS / CERTIFICAT D'ANALYSE

for/pour
 ASD-W (HZ3)
 Department of Education
 250 King Street, Place 2000
 Fredericton, NB E3B 9M9



921 ch College Hill Rd
 Fredericton NB
 Canada E3B 6Z9
 ☎ 506.452.1212
 📠 506.452.1395
 www.rpc.ca

Attention: Contacts Education / Distributions List ASD Contacts /
 Central Public Health

Microbiological Examination of Water/Qualité microbiologique de l'eau potable

RPC Sample ID/No. d'échantillon de RPC:				562933-1	562933-2	562933-3	562933-4
Client Sample ID/ID d'échantillon du client:				23223 Harvey Elementary School DWS #2	23234 Keswick Ridge School DWS	23245 Harvey High School DWS	22855 Keswick Valley School
Date collected/Date du prélèvement				25-Aug-25	25-Aug-25	25-Aug-25	25-Aug-25
Time sampled/Heure du prélèvement				7:39:00 AM	9:48:00 AM	7:26:00 AM	10:20:00 AM
Analytes/Paramètre(s)	Method/Méthode	Date Analyzed Date Analysé	Units Unités				
Heterotrophic Plate Count	MICRO58	25-Aug-25	MPN/mL	8	4	<2	<2
Coliforms/Coliformes	MICRO10	25-Aug-25	P-A/100mL	a	a	a	a
E. coli	MICRO10	25-Aug-25	P-A/100mL	a	a	a	a

This report relates only to the sample(s) and information provided to the laboratory.

Le présent rapport ne s'applique qu'aux échantillons et à l'information transmis au laboratoire.

a = absent/absentes

Cathy Hay
 Microbiology Supervisor
 Applied and Experimental Bioscience

Gillian Travis
 Microbiology Technician
 Applied and Experimental Bioscience

CERTIFICATE OF ANALYSIS / CERTIFICAT D'ANALYSE

for/pour
 ASD-W (HZ3)
 Department of Education
 250 King Street, Place 2000
 Fredericton, NB E3B 9M9



921 ch College Hill Rd
 Fredericton NB
 Canada E3B 6Z9
 ☎ 506.452.1212
 📠 506.452.1395
 www.rpc.ca

Attention: Contacts Education / Distributions List ASD Contacts /
 Central Public Health

Microbiological Examination of Water/Qualité microbiologique de l'eau potable

RPC Sample ID/No. d'échantillon de RPC:				562933-5
Client Sample ID/ID d'échantillon du client:				26539 Hanwell Park Academy
Date collected/Date du prélèvement				25-Aug-25
Time sampled/Heure du prélèvement				8:58:00 AM
Analytes/Paramètre(s)	Method/Méthode	Date Analyzed Date Analysé	Units Unités	
Heterotrophic Plate Count	MICRO58	25-Aug-25	MPN/mL	299
Coliforms/Coliformes	MICRO10	25-Aug-25	P-A/100mL	a
E. coli	MICRO10	25-Aug-25	P-A/100mL	a

Preventive Maintenance of Elevators in N.B. School
 Bi-Monthly / Semi-Annual / Annual Report

Permit Date: 10/26/11

Date: 10/26/11

School Name: Kawartha Valley Memorial School

Unit Number: 1170
 Unit Manufacturer: Overlander
 Unit Type: Hydraulic Hoisting
 Date Testing Completed:

Bi-Monthly Report	Complete	N/A	Semi Annual Report	Complete	N/A
Check in at School Office	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Vacuum controllers, Check relays, contacts & selectors.	<input type="checkbox"/>	<input type="checkbox"/>
Ride unit, check speed and leveling. Adjust if needed.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Check for proper Fuse Sizing, check main power connections	<input type="checkbox"/>	<input type="checkbox"/>
Verify all safety circuits & scheduling devices	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Check & adjust voltage of rectifier and record	<input type="checkbox"/>	<input type="checkbox"/>
Lubricate, clean & adjust all components	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Check fastings, Operating rollers, cams of H-way limits & safety switches	<input type="checkbox"/>	<input type="checkbox"/>
Check all lamps & signals. Replace bulbs as required.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Check selector tape, wire ropes & cables	<input type="checkbox"/>	<input type="checkbox"/>
Check fan and car interior	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Inspect, adjust & Lubricate: door closers arms & reel and air cords	<input type="checkbox"/>	<input type="checkbox"/>
Confirm phone & emergency communication	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Adjust lower guides on car & doors.	<input type="checkbox"/>	<input type="checkbox"/>
Adjust & lubricate door operation, speed, hangers & track	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Check car counterweight run-up	<input type="checkbox"/>	<input type="checkbox"/>
Check door protection, hanger rollers and relating cable tension	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Check, clean & lubricate, governor, idler & tape sheaves	<input type="checkbox"/>	<input type="checkbox"/>
Verify door Gibbs and retainers, visual panels.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Inspect brakes, clean linings & pulleys, Lubricate pins, hangers & rails	<input type="checkbox"/>	<input type="checkbox"/>
Check and adjust hydraulic packing, valves, couplings	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Demonstrates emergency lowering operation	<input type="checkbox"/>	<input type="checkbox"/>
Check hydraulic levels and top up. Report any loss to Supervisor immediately	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Discuss any notes with Facility Manager/ representative	<input type="checkbox"/>	<input type="checkbox"/>
Clean pit and check pit can	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Annual Report	Complete	N/A
Check motor, MG Brushes, oil level. Top up if needed	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Change oil In Generators, motors and geared equipment	<input type="checkbox"/>	<input type="checkbox"/>
Inspect and Adjust loose guides on car	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Check Sheaves & rope for wear Travelling cable & hangers	<input type="checkbox"/>	<input type="checkbox"/>
Verify Hoist waylockouts and access switch. (Interlocks)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Clean Generators & motors; Check wire connections	<input type="checkbox"/>	<input type="checkbox"/>
Clean Machine Rm. & Machine Rm Equipment	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Check under car & counterweight safety devices	<input type="checkbox"/>	<input type="checkbox"/>
Clean top of car and equipment	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Clean switches, check for wear breakage & Corrosion	<input type="checkbox"/>	<input type="checkbox"/>
Read and Fill out log book	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Complete hydrostatic test for in-ground and above-ground units	<input type="checkbox"/>	<input type="checkbox"/>
Note any adjustments, deficiencies and suggested repairs	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Discuss any notes with Facility Manager / Representative	<input type="checkbox"/>	<input type="checkbox"/>
Discuss any notes with Facility Manager/representative	<input checked="" type="checkbox"/>	<input type="checkbox"/>			

Patty Yupee
 School Signature

[Signature]
 Mechanic Signature

Report ID: 565068-OAS
 Report Date: 08-Oct-25
 Date Received: 23-Sep-25

CERTIFICATE OF ANALYSIS

for
 ASD-W (HZ3)
 Department of Education
 250 King Street, Place 2000
 Fredericton, NB E3B 9M9



921 College Hill Rd
 Fredericton NB
 Canada E3B 6Z9
 Tel: 506.452.1212
 Fax: 506.452.0594
 www.rpc.ca

Attention: Contacts Education

Project #: Not Available

Semi-Volatile Organic Compounds in Water

RPC Sample ID:				565068-1	565068-1 Dup	565068-2	565068-3	565068-4
Client Sample ID:				23223	23223	23234	23245	22855
Date Sampled:				Harvey Elementary School DWS #2	Harvey Elementary School DWS #2	Keswick Ridge School DWS	Harvey High School DWS	Keswick Valley
Matrix:				23-Sep-25 water	23-Sep-25 water	23-Sep-25 water	23-Sep-25 water	23-Sep-25 water
Analytes	Units	RL	MAC(AO)					
Benzo(a)pyrene	mg/L	0.00001	0.00004	< 0.00001	< 0.00001	< 0.00001	< 0.00001	< 0.00001
Pentachlorophenol	mg/L	0.0002	0.06	< 0.0002	< 0.0002	< 0.0002	< 0.0002	< 0.0002
P_terphenyl_d14	%			90	94	93	93	94
2,4,6-tribromophenol	%			97	100	95	94	98

This report relates only to the sample(s) and information provided to the laboratory.

RL = Reporting Limit

Angela Colford
 Lab Supervisor
 Organic Analytical Services

SVOC IN WATER - CWA

Page 1 of 7

Steven Davenport
 Senior Technician
 Organic Analytical Services

Report ID: 565068-OAS
Report Date: 08-Oct-25
Date Received: 23-Sep-25

CERTIFICATE OF ANALYSIS

for
ASD-W (HZ3)
Department of Education
250 King Street, Place 2000
Fredericton, NB E3B 9M9



921 College Hill Rd
Fredericton NB
Canada E3B 6Z9
Tel: 506.452.1212
Fax: 506.452.0594
www.rpc.ca

Attention: Contacts Education

Project #: Not Available

Semi-Volatile Organic Compounds in Water

RPC Sample ID:				565068-5
Client Sample ID:				26539 Hanwell Park
Date Sampled:				23-Sep-25
Matrix:				water
Analytes	Units	RL	MAC(AO)	
Benzo(a)pyrene	mg/L	0.00001	0.00004	< 0.00001
Pentachlorophenol	mg/L	0.0002	0.06	< 0.0002
P_terphenyl_d14	%			92
2,4,6-tribromophenol	%			94

Report ID: 565068-OAS
 Report Date: 08-Oct-25
 Date Received: 23-Sep-25

CERTIFICATE OF ANALYSIS

for
 ASD-W (HZ3)
 Department of Education
 250 King Street, Place 2000
 Fredericton, NB E3B 9M9



921 College Hill Rd
 Fredericton NB
 Canada E3B 6Z9
 Tel: 506.452.1212
 Fax: 506.452.0594
 www.rpc.ca

Attention: Contacts Education
Project #: Not Available

Volatile Organic Compounds in Water

RPC Sample ID:				565068-1	565068-2	565068-3	565068-4	565068-5
Client Sample ID:				23223 Harvey Elementary School DWS #2	23234 Keswick Ridge School DWS	23245 Harvey High School DWS	22855 Keswick Valley	26539 Hanwell Park
Date Sampled:				23-Sep-25	23-Sep-25	23-Sep-25	23-Sep-25	23-Sep-25
Matrix:				water	water	water	water	water
Analytes	Units	RL	MAC(AO)					
Benzene	mg/L	0.0005	0.005	< 0.0005	< 0.0005	< 0.0005	< 0.0005	< 0.0005
Bromodichloromethane	mg/L	0.0005	Note	< 0.0005	< 0.0005	< 0.0005	< 0.0005	< 0.0005
Bromoform	mg/L	0.0005	Note	< 0.0005	< 0.0005	< 0.0005	< 0.0005	< 0.0005
Carbon Tetrachloride	mg/L	0.0005	0.002	< 0.0005	< 0.0005	< 0.0005	< 0.0005	< 0.0005
Chloroform	mg/L	0.0005	Note	< 0.0005	< 0.0005	< 0.0005	< 0.0005	< 0.0005
Dibromochloromethane	mg/L	0.0005	Note	< 0.0005	< 0.0005	< 0.0005	< 0.0005	< 0.0005
1,2-dichlorobenzene	mg/L	0.0005	0.20	< 0.0005	< 0.0005	< 0.0005	< 0.0005	< 0.0005
1,4-dichlorobenzene	mg/L	0.0005	0.005	< 0.0005	< 0.0005	< 0.0005	< 0.0005	< 0.0005
1,2-dichloroethane	mg/L	0.0005	0.005	< 0.0005	< 0.0005	< 0.0005	< 0.0005	< 0.0005
Dichloromethane	mg/L	0.0010	0.05	< 0.0010	< 0.0010	< 0.0010	< 0.0010	< 0.0010
Ethylbenzene	mg/L	0.0005	0.14	< 0.0005	< 0.0005	< 0.0005	< 0.0005	< 0.0005
Tetrachloroethylene	mg/L	0.0005	0.01	< 0.0005	< 0.0005	< 0.0005	< 0.0005	< 0.0005
Toluene	mg/L	0.0005	0.06	< 0.0005	< 0.0005	< 0.0005	< 0.0005	< 0.0005
Trichloroethylene	mg/L	0.0005	0.005	< 0.0005	< 0.0005	< 0.0005	< 0.0005	< 0.0005
Vinyl Chloride	mg/L	0.0020	0.002	< 0.0020	< 0.0020	< 0.0020	< 0.0020	< 0.0020
Xylenes	mg/L	0.0005	0.09	< 0.0005	< 0.0005	< 0.0005	< 0.0005	< 0.0005
Total THM	mg/L	0.001	0.10	< 0.001	< 0.001	< 0.001	< 0.001	< 0.001
1,2-Dichloroethane-d4	%			102	101	101	104	103
Toluene-d8	%			101	101	101	99	102
4-Bromofluorobenzene	%			101	103	103	101	102

This report relates only to the sample(s) and information provided to the laboratory.

RL = Reporting Limit

Angela Colford
 Lab Supervisor
 Organic Analytical Services

Steven Davenport
 Senior Technician
 Organic Analytical Services

Report ID: 565068-OAS
Report Date: 08-Oct-25
Date Received: 23-Sep-25

CERTIFICATE OF ANALYSIS

for
ASD-W (HZ3)
Department of Education
250 King Street, Place 2000
Fredericton, NB E3B 9M9

rpc

921 College Hill Rd
Fredericton NB
Canada E3B 6Z9
Tel: 506.452.1212
Fax: 506.452.0594
www.rpc.ca

Method Summary

OAS-HC08: The Determination of Benzo (a) Pyrene and Pentachlorophenol in Water.
OAS-HC02: Determination of Volatile Organic Compounds in Water.

General Report Comments

MAC = maximum acceptable concentration; AO = aesthetic objective (CDWQG 2017)

Note = one of the trihalomethanes (THM); MAC for total THM is expressed as a locational running annual average of quarterly samples.

COMMENTS

Page 4 of 7

Report ID: 565068-OAS
Report Date: 08-Oct-25
Date Received: 23-Sep-25

CERTIFICATE OF ANALYSIS

for
ASD-W (HZ3)
Department of Education
250 King Street, Place 2000
Fredericton, NB E3B 9M9



921 College Hill Rd
Fredericton NB
Canada E3B 6Z9
Tel: 506.452.1212
Fax: 506.452.0594
www.rpc.ca

Project #: Not Available

QA/QC Report

RPC Sample ID:			BLANKE3709	SPIKEE3709
Matrix:			water	water
Analytes	Units	RL		% Recovery
Benzo(a)pyrene	mg/L	0.00001	< 0.00001	100%
Pentachlorophenol	mg/L	0.0002	< 0.0002	88%

RL = Reporting Limit

Report ID: 565068-OAS
 Report Date: 08-Oct-25
 Date Received: 23-Sep-25

CERTIFICATE OF ANALYSIS

for
 ASD-W (HZ3)
 Department of Education
 250 King Street, Place 2000
 Fredericton, NB E3B 9M9



921 College Hill Rd
 Fredericton NB
 Canada E3B 6Z9
 Tel: 506.452.1212
 Fax: 506.452.0594
 www.rpc.ca

Project #: Not Available

QA/QC Report

RPC Sample ID:			BLANKE3601	SPIKEE3601
Matrix:			water	water
Analytes	Units	RL		% Recovery
Benzene	mg/L	0.0005	< 0.0005	106%
Bromodichloromethane	mg/L	0.0005	< 0.0005	102%
Bromoform	mg/L	0.0005	< 0.0005	93%
Carbon Tetrachloride	mg/L	0.0005	< 0.0005	101%
Chloroform	mg/L	0.0005	< 0.0005	104%
Dibromochloromethane	mg/L	0.0005	< 0.0005	98%
1,2-dichlorobenzene	mg/L	0.0005	< 0.0005	109%
1,4-dichlorobenzene	mg/L	0.0005	< 0.0005	110%
1,2-dichloroethane	mg/L	0.0005	< 0.0005	106%
Dichloromethane	mg/L	0.0010	< 0.0010	105%
Ethylbenzene	mg/L	0.0005	< 0.0005	102%
Tetrachloroethylene	mg/L	0.0005	< 0.0005	105%
Toluene	mg/L	0.0005	< 0.0005	108%
Trichloroethylene	mg/L	0.0005	< 0.0005	102%
Vinyl Chloride	mg/L	0.0020	< 0.0020	110%
Xylenes	mg/L	0.0005	< 0.0005	102%

RL = Reporting Limit

Report ID: 565068-OAS
Report Date: 08-Oct-25
Date Received: 23-Sep-25

CERTIFICATE OF ANALYSIS

for
ASD-W (HZ3)
Department of Education
250 King Street, Place 2000
Fredericton, NB E3B 9M9



921 College Hill Rd
Fredericton NB
Canada E3B 6Z9
Tel: 506.452.1212
Fax: 506.452.0594
www.rpc.ca

Project #: Not Available

Summary of Date Analyzed

RPC Sample ID	SVOC		VOC	
	Extracted	Analyzed	Extracted	Analyzed
565068-1	3-Oct-25	7-Oct-25	23-Sep-25	23-Sep-25
565068-1 Dup	3-Oct-25	7-Oct-25	-	-
565068-2	3-Oct-25	7-Oct-25	23-Sep-25	23-Sep-25
565068-3	3-Oct-25	7-Oct-25	23-Sep-25	23-Sep-25
565068-4	3-Oct-25	7-Oct-25	23-Sep-25	23-Sep-25
565068-5	3-Oct-25	7-Oct-25	24-Sep-25	24-Sep-25

CERTIFICATE OF ANALYSIS / CERTIFICAT D'ANALYSE

for/pour
 ASD-W (HZ3)
 Department of Education
 250 King Street, Place 2000
 Fredericton, NB E3B 9M9

rpc
 921 ch College Hill Rd
 Fredericton NB
 Canada E3B 6Z9
 ☎ 506.452.1212
 📠 506.452.1395
 www.rpc.ca

Attention: Contacts Education / Distributions List ASD Contacts /
 Central Public Health


Microbiological Examination of Water/Qualité microbiologique de l'eau potable

RPC Sample ID/No. d'échantillon de RPC:				565068-1	565068-2	565068-3	565068-4
Client Sample ID/ID d'échantillon du client:				23223 Harvey Elementary School DWS #2	23234 Keswick Ridge School DWS	23245 Harvey High School DWS	22855 Keswick Valley
Date collected/Date du prélèvement				23-Sep-25	23-Sep-25	23-Sep-25	23-Sep-25
Time sampled/Heure du prélèvement				7:33:00 AM	8:22:00 AM	7:20:00 AM	9:03:00 AM
Analytes/Paramètre(s)	Method/Méthode	Date Analyzed Date Analysé	Units Unités				
Heterotrophic Plate Count	MICRO58	23-Sep-25	MPN/mL	<2	4	4	<2
Coliforms/Coliformes	MICRO10	23-Sep-25	P-A/100mL	a	a	a	a
E. coli	MICRO10	23-Sep-25	P-A/100mL	a	a	a	a


This report relates only to the sample(s) and information provided to the laboratory.

Le présent rapport ne s'applique qu'aux échantillons et à l'information transmis au laboratoire.

a = absent/absentes



Cathy Hay
 Microbiology Supervisor
 Applied and Experimental Bioscience



Adrienne Fortin
 Microbiology Technician
 Applied and Experimental Bioscience

CERTIFICATE OF ANALYSIS / CERTIFICAT D'ANALYSE

for/pour
ASD-W (HZ3)
Department of Education
250 King Street, Place 2000
Fredericton, NB E3B 9M9



921 ch College Hill Rd
Fredericton NB
Canada E3B 6Z9
☎ 506.452.1212
☎ 506.452.1395
www.rpc.ca

Attention: Contacts Education / Distributions List ASD Contacts /
Central Public Health

Microbiological Examination of Water/Qualité microbiologique de l'eau potable

RPC Sample ID/No. d'échantillon de RPC:				565068-5
Client Sample ID/ID d'échantillon du client:				26539 Hanwell Park
Date collected/Date du prélèvement				23-Sep-25
Time sampled/Heure du prélèvement				10:02:00 AM
Analytes/Paramètre(s)	Method/Méthode	Date Analyzed Date Analysé	Units Unités	
Heterotrophic Plate Count	MICRO58	23-Sep-25	MPN/mL	35
Coliforms/Coliformes	MICRO10	23-Sep-25	P-A/100mL	a
E. coli	MICRO10	23-Sep-25	P-A/100mL	a

**ELEVATING DEVICE CONDITION REPORT
RAPPORT SUR L'ETAT DES APPAREILS ÉLEVATEURS**

03/16

The form must be completed by the licensed elevator contractor who performs the maintenance on the device within your building. Please send this completed form to the attention of Keith Steeves by email at keith.steeves@gnb.ca or by fax at (506) 856-3078. If you have any questions, please contact Keith Steeves at (506) 856-3080.

Le formulaire doit être rempli par l'entrepreneur d'appareils élévateurs titulaire d'un permis qui est chargé à l'entretien de l'appareil se trouvant dans votre édifice. Veuillez faire parvenir le formulaire dûment rempli à Keith Steeves par courriel à l'adresse keith.steeves@gnb.ca ou par télécopieur au 506-856-3078. Si vous avez des questions, veuillez communiquer avec lui par téléphone au 506-856-3080.

Owner / Propriétaire					
Civic No. / N° de voirie		Street or Hwy / Rue ou route		Municipality / Municipalité	
Postal code / Code postal		Telephone / Téléphone		Install Date / Date de L'installation	
Device No/No de l'appareil	# 1170	Manufacturer / Fabricant	Dover Elevator	Number of Floors/Nombre d' etages	# 2

Type

Freight / Monte-charge
 Passenger / Ascenseur
 B355 Devices/ Appareils B355
 Hydraulic / Ascenseur hydraulique
 Escalator/ Escaliers mécaniques
 Traction / Ascenseur à traction
 Dumbwaiter/Petite monte-charge

Licensed Contractor / Entrepreneur titulaire d'un permis	KONE Inc.	Licence No. / N° de permis	31760
---	-----------	-----------------------------------	-------

This elevating device is presently maintained by the above-named licensed contractor and is being maintained in accordance with the New Brunswick Elevators and Lifts Act and its regulations.
 Cet appareil d'élévateur fait présentement l'objet d'entretien par l'entrepreneur titulaire d'un permis susmentionné et son entretien se conforme aux exigences de la Loi sur les ascenseurs et monte-charge du Nouveau-Brunswick et de ses règlements.

Type of Contract and No. of Visits / Type de contrat et nombre de visites	Oil & Grease / 5
--	------------------

Name of person representing contractor with maintenance on this unit / Nom de la personne représentant l'entrepreneur responsable d'entretien de cet appareil.		
Cheryl Howells Carla Countway	<i>Carla Countway</i>	January 28, 2025
(Print Name / Nom en lettres moulées)	(Signature)	(Date)

All applicable annual tests completed for elevators as per ASME A17.1-2016/CSA-B44-16 for elevators (CAT 1) / Tous les tests applicables qui doivent être menés tous les ans sur les ascenseurs ont été effectués conformément à la norme ASME A17.1-2016/CSA-B44-16 (CAT 1). Yes / Oui No / Non

All applicable Category 5 tests completed for elevators as per ASME A17.1-2016/CSA-B44-16 (CAT5) / Tous les tests de catégorie 5 applicables pour les ascenseurs selon ASME 17.1-2016/CSA-B44-16 (CAT5) Yes / Oui No / Non

Date Category 5 testing last completed _____ Maintenance Control Program On site / sur place Yes / Oui No / Non

All applicable annual tests completed for lifts for persons with physical disabilities as per CSAB355-15 ANNEX B / Tous les tests applicables qui doivent être menés tous les ans sur les appareils élévateurs pour personnes handicapées ont été effectués conformément à la norme CSAB355-15, ANNEXE B. Yes / Oui No / Non

Licensed Mechanic testing unit / Mécanicien agréé testant l'appareil	Licence No. / N° de permis	67766
Brad Thomas	<i>Brad Thomas</i>	January 23rd / 2025
(Print Name / Nom en lettres moulées)	(Signature)	(Date)

Public Safety
 Telephone: (506) 856-3080
 Fax: (506) 856-3078
 Email: keith.steeves@gnb.ca



Ministère de la Sécurité publique
 Téléphone : 506-856-3080
 Télécopieur : 506-856-3078
 Courriel : keith.steeves@gnb.ca

Report ID: 567368-ML-W1
 Report Date: 28-Oct-25
 Date Received: 27-Oct-25

CERTIFICATE OF ANALYSIS

for
 ASD-W (HZ3)
 Department of Education
 250 King Street, Place 2000
 Fredericton, NB E3B 9M9



921 ch College Hill Rd
 Fredericton NB
 Canada E3B 6Z9
 ☎ 506.452.1212
 📠 506.452.1395
 www.rpc.ca

Attention: Contacts Education / Distributions List ASD Contacts ,
 Central Public Health

Microbiological Examination of Water

Analytes:				Coliforms/Coliformes	E. coli
Units:				P-A/100mL	P-A/100mL
Method ID:				MICRO10	MICRO10
Date Analyzed:				27-Oct-25	27-Oct-25
RPC Sample ID	Client Sample ID	Date Sampled	Time Sampled		
567368-1	23223 Harvey Elementary School DWS #2	27-Oct-25	7:20:00 AM	a	a
567368-2	23234 Keswick Ridge School DWS	27-Oct-25	8:18:00 AM	a	a
567368-3	23245 Harvey High School DWS	27-Oct-25	7:10:00 AM	a	a
567368-4	22855 Keswick Valley	27-Oct-25	8:46:00 AM	a	a
567368-5	26539 Hanwell Park	27-Oct-25	9:42:00 AM	a	a

This report relates only to the sample(s) and information provided to the laboratory.

a = absent

Cathy Hay
 Microbiology Supervisor
 Applied and Experimental Bioscience

Adrienne Fortin
 Microbiology Technician
 Applied and Experimental Bioscience

Report of Inspection / Test

Frequency: Quarterly ITM

11-17-2025

Property

KESWICK VALLEY MEMORIAL - D14
20 ROUTE 617
BURTT'S CORNER NB E6L 2X3

WO Ref #: 6620563

Conducted by: Roy Barton
NB Sprinkler System Installer 10072972

Troy Life & Fire Safety Ltd
175 Henri Dunant Street
Moncton New Brunswick E1E 1E4
1-877-441-8769



Life & Fire Safety Ltd.

24 HR. SERVICE
1-877-441-8769

troylfs.com

Inspection Summary

The system(s) listed below have been inspected and tested by qualified personnel. This summary is only valid together with the enclosed inspection report.

The noted inspection(s) and tests(s) do not address the adequacy of design criteria or capability of the fire protection system(s), but rather address the operating condition at time of inspection only and in accordance with the Fire Code. Impairments and deficiencies are required to be corrected by the Customer and/or Owner.

SPRINKLER SUMMARY

SYSTEM	TECHNICIAN	QTY INSPECTED	QTY FAILED	DATE INSPECTED
General	Roy Barton	1	0	11-17-2025
General Wet	Roy Barton	1	0	11-17-2025
General Dry	Roy Barton	1	0	11-17-2025
Wet	Roy Barton	1	0	11-17-2025
Dry	Roy Barton	1	1	11-17-2025
Butterfly	Roy Barton	10	0	11-17-2025
Dry Pipe Valve	Roy Barton	1	0	11-17-2025
Alarm Valve	Roy Barton	1	0	11-17-2025
Drain Valve	Roy Barton	1	0	11-17-2025
ITV	Roy Barton	3	0	11-17-2025

Report of Inspection / Test

Frequency: Quarterly ITM

11-17-2025

Property

KESWICK VALLEY MEMORIAL - D14
20 ROUTE 617
BURTT'S CORNER NB E6L 2X3

WO Ref #: 6620563

Conducted by: Roy Barton
NB Sprinkler System Installer 10072972

Troy Life & Fire Safety Ltd
175 Henri Dunant Street
Moncton New Brunswick E1E 1E4
1-877-441-8769



Life & Fire Safety Ltd.

24 HR. SERVICE
1-877-441-8769

troylfs.com

Report of Inspection / Test General Questions

OWNER SECTION

Is the building occupied?	Yes	Has the occupancy classification, hazard of contents, and/or storage method remained the same since the last inspection?	Yes
Are all fire protection systems in service?	Yes	Has the system remained in service without modification since the last inspection?	Yes
Was the system free of actuations of devices or alarms since the last inspection?	Yes	Name of owner representative who provided the information?	Patty
Does the property owner maintain records per NFPA 25 4.3.3?	Yes	Is the building/owner able to supply as-built drawings for the system(s)?	Yes

CONTROL VALVE AREA

Are the control valves in correct (open or closed) position?	Yes	Are the control valves locked or is supervision in place?	Yes
Are the control valves accessible?	Yes	Are the control valves free from leaks?	Yes
Are appropriate wrenches available for the control valves?	Yes	Are the control valves properly identified?	Yes

VALVE AREA

Are all check valves externally inspected, operating properly, and are in good condition?	Yes	Are the gauges in good condition and showing normal air and water pressure?	Yes
Are Pressure reducing valves (sprinkler system) in open position and not leaking?	N/A	Are Pressure reducing valves (sprinkler system) with downstream pressure per the design?	N/A
Are Pressure reducing valves in good condition including no handwheels broken?	N/A	The electrical waterflow alarm devices passed test by opening inspector's test connection/bypass connection with alarms actuating and flow observed?	Yes
Are valve enclosures maintaining a minimum of 4 degrees C or more?	Yes		

BACKFLOW PREVENTERS

Is relief port on RPZ device not discharging?	Yes		
---	-----	--	--

ALARMS

Have low temperature alarms passed test?	N/A	Are alarms and supervisory devices not damaged?	Yes
--	-----	---	-----

FIRE DEPARTMENT CONNECTION

Are the FDC caps and plugs in place and undamaged?	Yes	Is the FDC check valve free of leaks?	Yes
Has the interior of the FDC been inspected for obstructions?	Yes	Is the visible piping supplying the FDC undamaged?	Yes
Are the fire department connections visible and accessible?	Yes	Are gaskets in place and in good condition?	Yes

Report of Inspection / Test

Frequency: Quarterly ITM

11-17-2025

Property

KESWICK VALLEY MEMORIAL - D14
20 ROUTE 617
BURTT'S CORNER NB E6L 2X3

WO Ref #: 6620563

Conducted by: Roy Barton
NB Sprinkler System Installer 10072972

Troy Life & Fire Safety Ltd
175 Henri Dunant Street
Moncton New Brunswick E1E 1E4
1-877-441-8769



Life & Fire Safety Ltd.

24 HR. SERVICE
1-877-441-8769

troylfs.com

Is the fire department connection clapper(s) in place and operating properly?	Yes	Are identification signs in place?	Yes
Is the automatic drain valve in place and operating properly?	Yes		
PIPES			
Do visible pipe and fittings have no mechanical damage or leaks?	Yes		
MAINTENANCE			
Have auxiliary drains been drained/operated?	N/A	Have adjusted, repaired, reconditioned, or replaced components had proper tests/inspections performed? (Identify component and details)	N/A
Was a drain test conducted after opening any closed valve?	Yes		
TESTING			
Mechanical waterflow alarm devices passed tests (alarms actuated and flow observed)?	Yes		
ALARMS			
Is the alarm valve free from physical damage?	Yes	Is the trim in correct (open or closed) position?	Yes
Is there no leakage in the retarding chamber or drains?	Yes		
INSPECTION			
Is the excess pressure pump free of damage and operational?	Yes		
DRY VALVE			
Are the gauges in good condition and showing normal air and water pressure?	Yes	For freezer systems, gauge near compressor reading the same as gauge near the dry-pipe valve?	N/A
Is the dry pipe valve(s) free from physical damage?	Yes	Are trim valves in appropriate (open or closed) position?	Yes
Is there no leakage in the intermediate chamber?	Yes	Is the priming level correct?	Yes
Has the quick opening device passed the test?	N/A	Have the strainers, filters and orifices been inspected?	Yes

Report of Inspection / Test

Frequency: Quarterly ITM

11-17-2025

Property

KESWICK VALLEY MEMORIAL - D14
20 ROUTE 617
BURTT'S CORNER NB E6L 2X3

WO Ref #: 6620563

Conducted by: Roy Barton
NB Sprinkler System Installer 10072972

Troy Life & Fire Safety Ltd
175 Henri Dunant Street
Moncton New Brunswick E1E 1E4
1-877-441-8769



Life & Fire Safety Ltd.

24 HR. SERVICE
1-877-441-8769

troylfs.com

Report of Inspection / Test for System - WET 1

WET SYSTEM MAIN DRAIN FLOW TEST

Record initial static pressure	85	Record residual pressure	tanks
Record static pressure	N/A	Seconds to return to initial static	N/A
Is flow observed?	Yes	Are results comparable to previous test	Yes
Did waterflow alarm operate?	Yes		

Report of Inspection / Test

Frequency: Quarterly ITM

11-17-2025

Property

KESWICK VALLEY MEMORIAL - D14
20 ROUTE 617
BURTT'S CORNER NB E6L 2X3

WO Ref #: 6620563

Conducted by: Roy Barton
NB Sprinkler System Installer 10072972

Troy Life & Fire Safety Ltd
175 Henri Dunant Street
Moncton New Brunswick E1E 1E4
1-877-441-8769



Life & Fire Safety Ltd.

24 HR. SERVICE
1-877-441-8769

troylfs.com

Report of Inspection / Test for System - DRY 1

AIR COMPRESSORS

Is the air compressor, piping, wiring free of physical damage?	Yes	Is the air compressor anchored properly to the structure or system piping?	Yes
For oil-filled air compressors, is the level sufficient?	Yes	Does the air compressor operate as intended on the proper drop in pressure?	Yes
Does the air compressor operate without overheating?	Yes	For oil-filled air compressors, has the oil been replaced or changed?	No

DRY SYSTEM MAIN DRAIN FLOW TEST

Record initial static pressure	85	Record residual pressure (psi)	Tanks
Record static pressure (psi)	N/A	Seconds to return to initial static	N/A
Is flow observed?	Yes	Are results comparable to previous test	Yes
Did waterflow alarm operate?	Yes		

INSPECTORS TEST CONNECTION

WET 1 (Wet)

Location	Description	Time to Alarm (seconds)	Reported?	Smooth Orifice	Easily Accessible	Signs?	Pass?
Quiet room end of hall second floor	Globe valve	60	Yes	Yes	Yes	Yes	Yes
Rear exit	First Floor	60	Yes	Yes	Yes	Yes	Yes

DRY 1 (Dry)

Location	Description	Time to Alarm (seconds)	Reported?	Smooth Orifice	Easily Accessible	Signs?	Pass?
Quiet room end of hall second floor	Attic	ns	N/A	Yes	Yes	Yes	Yes

VALVES

WET 1 (Wet)

Description	Location	Valve Type	Size	Secured	Open	Easily Accessible	Signs	Exercised	Stems Lubricated	Flow Pass	Tamper Pass
System Riser	Tank Room	Butterfly	4 "	Monitored	Yes	Yes	Yes	Yes	N/A	N/A	Pass
Bulk feed second	Sprinkler Room	Butterfly	4 "	Monitored	Yes	Yes	Yes	Yes	N/A	N/A	Pass
Gem	Sprinkler Room	Alarm Valve	4 "	Monitored	N/A	Yes	Yes	Yes		Pass	Pass

Report of Inspection / Test

Frequency: Quarterly ITM

11-17-2025

Property

KESWICK VALLEY MEMORIAL - D14
20 ROUTE 617
BURTT'S CORNER NB E6L 2X3

WO Ref #: 6620563

Conducted by: Roy Barton
NB Sprinkler System Installer 10072972

Troy Life & Fire Safety Ltd
175 Henri Dunant Street
Moncton New Brunswick E1E 1E4
1-877-441-8769



Life & Fire Safety Ltd.

24 HR. SERVICE
1-877-441-8769

troylfs.com

Description	Location	Valve Type	Size	Secured	Open	Easily Accessible	Signs	Exercised	Stems Lubricated	Flow Pass	Tamper Pass
Tank 1	Sprinkler Room	Butterfly	4 "	Monitored	Yes	Yes	Yes	Yes	N/A	N/A	Pass
Tank 2	Sprinkler Room	Butterfly	4 "	Monitored	Yes	Yes	Yes	Yes	N/A	N/A	Pass
Tank room	Sprinkler Room	Butterfly	2 "	Monitored	Yes	Yes	Yes	Yes	N/A	N/A	Pass
Elevator machine room	Above ceiling outside library	Butterfly	1 "	Monitored	Yes	Yes	Yes	Yes	N/A	N/A	Pass
Elevator shaft	Top of stairs before library	Butterfly	1 "	Monitored	Yes	Yes	Yes	Yes	N/A	N/A	Pass
Second floor	Above ceiling in library	Butterfly	3 "	Monitored	Yes	Yes	Yes	Yes	N/A	N/A	Pass
Elevator pit	Tank room	Butterfly	1 "	Monitored	Yes	Yes	Yes	Yes		N/A	Pass

DRY 1 (Dry)

Description	Location	Valve Type	Size	Secured	Open	Easily Accessible	Signs	Exercised	Stems Lubricated	Flow Pass	Tamper Pass
Attic	Sprinkler Room	Butterfly	4 "	Monitored	Yes	Yes	Yes	Yes	N/A	N/A	Pass
Tyco	Sprinkler Room	Dry Pipe Valve	4 "	Monitored	N/A	Yes	Yes	N/A	N/A	Pass	Pass

DRAIN VALVES

DRY 1 (Dry)

Description	Location	Drain	Aux Drain Drained	Water Flow Observed
Main Drain	Tank Room		N/A	Yes

Report of Inspection / Test

Frequency: Quarterly ITM

11-17-2025

Property

KESWICK VALLEY MEMORIAL - D14

20 ROUTE 617

BURTT'S CORNER NB E6L 2X3

WO Ref #: 6620563

Conducted by: Roy Barton
NB Sprinkler System Installer 10072972

Troy Life & Fire Safety Ltd
175 Henri Dunant Street
Moncton New Brunswick E1E 1E4
1-877-441-8769



Life & Fire Safety Ltd.

24 HR. SERVICE
1-877-441-8769

troylfs.com

Deficiencies - General Questions

None

Deficiencies - General Wet System Questions

None

Deficiencies - General Dry System Questions

None

Deficiencies - WET 1

None

Deficiencies - DRY 1

Deficiency #1

Sprinkler Type: Dry

For oil-filled air compressors, has the oil been replaced or changed? - 13.10.4:

No

Status: Critical

Notes:

Deficiencies - Inspectors Test Connection

None

Deficiencies - Valves

None

Deficiencies - Drain Valves

None

Report of Inspection / Test

Frequency: Quarterly ITM

11-17-2025

Property

KESWICK VALLEY MEMORIAL - D14
20 ROUTE 617
BURTT'S CORNER NB E6L 2X3

WO Ref #: 6620563

Conducted by: Roy Barton
NB Sprinkler System Installer 10072972

Troy Life & Fire Safety Ltd
175 Henri Dunant Street
Moncton New Brunswick E1E 1E4
1-877-441-8769




Life & Fire Safety Ltd.

24 HR. SERVICE
1-877-441-8769

troylfs.com

Inspector Signature

I state that the information on this form is correct at the time and place of my inspection, and all equipment tested at this time was left in operational condition upon completion of this inspection except as noted.

Inspector Name	Signature	Date Completed
Roy Barton NB Sprinkler System Installer 10072972		2025-11-17

CERTIFICATE OF ANALYSIS / CERTIFICAT D'ANALYSE

for/pour
 ASD-W (HZ3)
 Department of Education
 250 King Street, Place 2000
 Fredericton, NB E3B 9M9



921 ch College Hill Rd
 Fredericton NB
 Canada E3B 6Z9
 ☎ 506.452.1212
 📠 506.452.1395
 www.rpc.ca

Attention: Contacts Education / Distributions List ASD Contacts /
 Central Public Health

Microbiological Examination of Water/Qualité microbiologique de l'eau potable

RPC Sample ID/No. d'échantillon de RPC:				569107-1	569107-2	569107-3	569107-4
Client Sample ID/ID d'échantillon du client:				23223 Harvey Elementary School DWS	23234 Keswick Ridge School DWS	23245 Harvey High School DWS	22855 Keswick Valley
Date collected/Date du prélèvement				24-Nov-25	24-Nov-25	24-Nov-25	24-Nov-25
Time sampled/Heure du prélèvement				7:23:00 AM	8:06:00 AM	7:10:00 AM	8:35:00 AM
Analytes/Paramètre(s)	Method/Méthode	Date Analyzed Date Analysé	Units Unités				
Heterotrophic Plate Count	MICRO58	24-Nov-25	MPN/mL	10	12	23	<2
Coliforms/Coliformes	MICRO10	24-Nov-25	P-A/100mL	a	a	a	a
E. coli	MICRO10	24-Nov-25	P-A/100mL	a	a	a	a

This report relates only to the sample(s) and information provided to the laboratory.

Le présent rapport ne s'applique qu'aux échantillons et à l'information transmis au laboratoire.

a = absent/absentes

Cathy Hay
 Microbiology Supervisor
 Applied and Experimental Bioscience

Gillian Travis
 Microbiology Technician
 Applied and Experimental Bioscience

CERTIFICATE OF ANALYSIS / CERTIFICAT D'ANALYSE

for/pour
 ASD-W (HZ3)
 Department of Education
 250 King Street, Place 2000
 Fredericton, NB E3B 9M9



921 ch College Hill Rd
 Fredericton NB
 Canada E3B 6Z9
 ☎ 506.452.1212
 📠 506.452.1395
 www.rpc.ca

Attention: Contacts Education / Distributions List ASD Contacts /
 Central Public Health

Microbiological Examination of Water/Qualité microbiologique de l'eau potable

RPC Sample ID/No. d'échantillon de RPC:				569107-5
Client Sample ID/ID d'échantillon du client:				26539 Hanwell Park
Date collected/Date du prélèvement				24-Nov-25
Time sampled/Heure du prélèvement				9:26:00 AM
Analytes/Paramètre(s)	Method/Méthode	Date Analyzed Date Analysé	Units Unités	
Heterotrophic Plate Count	MICRO58	24-Nov-25	MPN/mL	65
Coliforms/Coliformes	MICRO10	24-Nov-25	P-A/100mL	a
E. coli	MICRO10	24-Nov-25	P-A/100mL	a

Report ID: 570347-ML-W1
 Report Date: 16-Dec-25
 Date Received: 15-Dec-25

CERTIFICATE OF ANALYSIS

for
 ASD-W (HZ3)
 Department of Education
 250 King Street, Place 2000
 Fredericton, NB E3B 9M9



921 ch College Hill Rd
 Fredericton NB
 Canada E3B 6Z9
 ☎ 506.452.1212
 📠 506.452.1395
 www.rpc.ca

Attention: Contacts Education / Distributions List ASD Contacts ,
 Central Public Health

Microbiological Examination of Water

Analytes:				Coliforms/Coliformes	E. coli
Units:				P-A/100mL	P-A/100mL
Method ID:				MICRO10	MICRO10
Date Analyzed:				15-Dec-25	15-Dec-25
RPC Sample ID	Client Sample ID	Date Sampled	Time Sampled		
570347-1	23223 Harvey Elementary School DWS #2	15-Dec-25	7:40:00 AM	a	a
570347-2	23234 Keswick Ridge School DWS	15-Dec-25	8:19:00 AM	a	a
570347-3	23245 Harvey High School DWS	15-Dec-25	7:20:00 AM	a	a
570347-4	22855 Keswick Valley	15-Dec-25	8:45:00 AM	a	a
570347-5	26539 Hanwell Park	15-Dec-25	9:40:00 AM	a	a

This report relates only to the sample(s) and information provided to the laboratory.

a = absent

Cathy Hay
 Microbiology Supervisor
 Applied and Experimental Bioscience

MICRO WATER

Page 1 of 1

Morgan Armour
 Microbiology Technician
 Applied and Experimental Bioscience

Report of Inspection / Test

Frequency: Semi-Annual ITM

01-07-2026

Property

KESWICK VALLEY MEMORIAL - D14
20 ROUTE 617
BURTT'S CORNER NB E6L 2X3

WO Ref #: 6646172

Conducted by: Roy Barton
NB Sprinkler System Installer 10072972

Troy Life & Fire Safety Ltd
175 Henri Dunant Street
Moncton New Brunswick E1E 1E4
1-877-441-8769



Life & Fire Safety Ltd.

24 HR. SERVICE
1-877-441-8769

troylfs.com

Inspection Summary

The system(s) listed below have been inspected and tested by qualified personnel. This summary is only valid together with the enclosed inspection report.

The noted inspection(s) and tests(s) do not address the adequacy of design criteria or capability of the fire protection system(s), but rather address the operating condition at time of inspection only and in accordance with the Fire Code. Impairments and deficiencies are required to be corrected by the Customer and/or Owner.

SPRINKLER SUMMARY

SYSTEM	TECHNICIAN	QTY INSPECTED	QTY FAILED	DATE INSPECTED
General	Roy Barton	1	0	01-07-2026
General Wet	Roy Barton	1	0	01-07-2026
General Dry	Roy Barton	1	0	01-07-2026
Wet	Roy Barton	1	0	01-07-2026
Dry	Roy Barton	1	0	01-07-2026
Butterfly	Roy Barton	10	0	01-07-2026
Dry Pipe Valve	Roy Barton	1	0	01-07-2026
Alarm Valve	Roy Barton	1	0	01-07-2026
Drain Valve	Roy Barton	1	0	01-07-2026
ITV	Roy Barton	3	0	01-07-2026

Report of Inspection / Test

Frequency: Semi-Annual ITM

01-07-2026

Property

KESWICK VALLEY MEMORIAL - D14

20 ROUTE 617

BURTT'S CORNER NB E6L 2X3

WO Ref #: 6646172

Conducted by: Roy Barton
NB Sprinkler System Installer 10072972

Troy Life & Fire Safety Ltd
175 Henri Dunant Street
Moncton New Brunswick E1E 1E4
1-877-441-8769



Life & Fire Safety Ltd.

24 HR. SERVICE
1-877-441-8769

troylfs.com

Report of Inspection / Test General Questions

OWNER SECTION

Is the building occupied?	Yes	Has the occupancy classification, hazard of contents, and/or storage method remained the same since the last inspection?	Yes
Are all fire protection systems in service?	Yes	Has the system remained in service without modification since the last inspection?	Yes
Was the system free of actuations of devices or alarms since the last inspection?	Yes	Name of owner representative who provided the information?	Neil
Does the property owner maintain records per NFPA 25 4.3.3?	Yes	Is the building/owner able to supply as-built drawings for the system(s)?	Yes

CONTROL VALVE AREA

Are the control valves in correct (open or closed) position?	Yes	Are the control valves locked or is supervision in place?	Yes
Are the control valves accessible?	Yes	Are the control valves free from leaks?	Yes
Are appropriate wrenches available for the control valves?	Yes	Are the control valves properly identified?	Yes

VALVE AREA

Are all check valves externally inspected, operating properly, and are in good condition?	Yes	Are the gauges in good condition and showing normal air and water pressure?	Yes
Are Pressure reducing valves (sprinkler system) in open position and not leaking?	N/A	Are Pressure reducing valves (sprinkler system) with downstream pressure per the design?	N/A
Are Pressure reducing valves in good condition including no handwheels broken?	N/A	Do valve supervisory switches indicate movement?	Yes
The electrical waterflow alarm devices passed test by opening inspector's test connection/bypass connection with alarms actuating and flow observed?	Yes	Are valve enclosures maintaining a minimum of 4 degrees C or more?	Yes

BACKFLOW PREVENTERS

Is relief port on RPZ device not discharging?	Yes		
---	-----	--	--

ALARMS

Have low temperature alarms passed test?	N/A	Are alarms and supervisory devices not damaged?	Yes
Do low temperature alarms appear to be free of physical damage?	N/A		

FIRE DEPARTMENT CONNECTION

Are the FDC caps and plugs in place and undamaged?	Yes	Is the FDC check valve free of leaks?	Yes
Has the interior of the FDC been inspected for obstructions?	Yes	Is the visible piping supplying the FDC undamaged?	Yes

Report of Inspection / Test

Frequency: Semi-Annual ITM

01-07-2026

Property

KESWICK VALLEY MEMORIAL - D14
20 ROUTE 617
BURTT'S CORNER NB E6L 2X3

WO Ref #: 6646172

Conducted by: Roy Barton
NB Sprinkler System Installer 10072972

Troy Life & Fire Safety Ltd
175 Henri Dunant Street
Moncton New Brunswick E1E 1E4
1-877-441-8769



Life & Fire Safety Ltd.

24 HR. SERVICE
1-877-441-8769

troylfs.com

If locking caps/plugs are in place, has an internal inspections been conducted?	Yes	Are the fire department connections visible and accessible?	Yes
Are gaskets in place and in good condition?	Yes	Is the fire department connection clapper(s) in place and operating properly?	Yes
Are identification signs in place?	Yes	Is the automatic drain valve in place and operating properly?	Yes
PIPES			
Do visible pipe and fittings have no mechanical damage or leaks?	Yes		
MAINTENANCE			
Have auxiliary drains been drained/operated?	N/A	Have adjusted, repaired, reconditioned, or replaced components had proper tests/inspections performed? (Identify component and details)	N/A
Was a drain test conducted after opening any closed valve?	Yes		
TESTING			
Mechanical waterflow alarm devices passed tests (alarms actuated and flow observed)?	Yes		
ALARMS			
Is the alarm valve free from physical damage?	Yes	Is the trim in correct (open or closed) position?	Yes
Is there no leakage in the retarding chamber or drains?	Yes		
INSPECTION			
Is the excess pressure pump free of damage and operational?	Yes		
DRY VALVE			
Low temperature alarms are in good working condition?	N/A	Are the gauges in good condition and showing normal air and water pressure?	Yes
For freezer systems, gauge near compressor reading the same as gauge near the dry-pipe valve?	N/A	Is the dry pipe valve(s) free from physical damage?	Yes
Are trim valves in appropriate (open or closed) position?	Yes	Is there no leakage in the intermediate chamber?	Yes
Is the priming level correct?	Yes	Has the quick opening device passed the test?	N/A
Have the strainers, filters and orifices been inspected?	Yes		

Report of Inspection / Test

Frequency: Semi-Annual ITM

01-07-2026

Property

KESWICK VALLEY MEMORIAL - D14
20 ROUTE 617
BURTT'S CORNER NB E6L 2X3

WO Ref #: 6646172

Conducted by: Roy Barton
NB Sprinkler System Installer 10072972

Troy Life & Fire Safety Ltd
175 Henri Dunant Street
Moncton New Brunswick E1E 1E4
1-877-441-8769



Life & Fire Safety Ltd.

24 HR. SERVICE
1-877-441-8769

troylfs.com

Report of Inspection / Test for System - WET 1

WET SYSTEM MAIN DRAIN FLOW TEST

Record initial static pressure	105	Record residual pressure	Tanks
Record static pressure	N/A	Seconds to return to initial static	ns
Is flow observed?	Yes	Are results comparable to previous test	Yes
Did waterflow alarm operate?	N/A		

Report of Inspection / Test

Frequency: Semi-Annual ITM

01-07-2026

Property

KESWICK VALLEY MEMORIAL - D14
20 ROUTE 617
BURTT'S CORNER NB E6L 2X3

WO Ref #: 6646172

Conducted by: Roy Barton
NB Sprinkler System Installer 10072972

Troy Life & Fire Safety Ltd
175 Henri Dunant Street
Moncton New Brunswick E1E 1E4
1-877-441-8769



Life & Fire Safety Ltd.

24 HR. SERVICE
1-877-441-8769

troylfs.com

Report of Inspection / Test for System - DRY 1

DRY VALVE

Have automatic air maintenance devices passed test? Yes

AIR COMPRESSORS

Is the air compressor, piping, wiring free of physical damage? Yes

Is the air compressor anchored properly to the structure or system piping? Yes

For oil-filled air compressors, is the level sufficient? Yes

Does the air compressor operate as intended on the proper drop in pressure? Yes

Does the air compressor operate without overheating? Yes

For oil-filled air compressors, has the oil been replaced or changed? Yes

DRY SYSTEM MAIN DRAIN FLOW TEST

Record initial static pressure 105

Record residual pressure (psi) tanks

Record static pressure (psi) N/A

Seconds to return to initial static N/A

Is flow observed? Yes

Are results comparable to previous test Yes

Did waterflow alarm operate? Yes

INSPECTORS TEST CONNECTION

WET 1 (Wet)

Location	Description	Time to Alarm (seconds)	Reported?	Smooth Orifice	Easily Accessible	Signs?	Pass?
Quiet room end of hall second floor	Globe valve	60	Yes	Yes	Yes	Yes	Yes
Rear exit	First Floor	60	Yes	Yes	Yes	Yes	Yes

DRY 1 (Dry)

Location	Description	Time to Alarm (seconds)	Reported?	Smooth Orifice	Easily Accessible	Signs?	Pass?
Quiet room end of hall second floor	Attic	na	N/A	Yes	Yes	Yes	Yes

VALVES

WET 1 (Wet)

Description	Location	Valve Type	Size	Secured	Open	Easily Accessible	Signs	Exercised	Stems Lubricated	Flow Pass	Tam per Pass
System Riser	Tank Room	Butterfly	4 "	Monitored	Yes	Yes	Yes	Yes	N/A	N/A	Pass

Report of Inspection / Test

Frequency: Semi-Annual ITM

01-07-2026

Property

KESWICK VALLEY MEMORIAL - D14
20 ROUTE 617
BURTT'S CORNER NB E6L 2X3

WO Ref #: 6646172

Conducted by: Roy Barton
NB Sprinkler System Installer 10072972

Troy Life & Fire Safety Ltd
175 Henri Dunant Street
Moncton New Brunswick E1E 1E4
1-877-441-8769



Life & Fire Safety Ltd.

24 HR. SERVICE
1-877-441-8769

troylfs.com

Description	Location	Valve Type	Size	Secured	Open	Easily Accessible	Signs	Exercised	Stems Lubricated	Flow Pass	Tamper Pass
Bulk feed second	Sprinkler Room	Butterfly	4 "	Monitored	Yes	Yes	Yes	Yes	N/A	N/A	Pass
Gem	Sprinkler Room	Alarm Valve	4 "	Monitored	Yes	Yes	Yes	Yes	N/A	Pass	Pass
Tank 1	Sprinkler Room	Butterfly	4 "	Monitored	Yes	Yes	Yes	Yes	N/A	N/A	Pass
Tank 2	Sprinkler Room	Butterfly	4 "	Monitored	Yes	Yes	Yes	Yes	N/A	N/A	Pass
Tank room	Sprinkler Room	Butterfly	2 "	Monitored	Yes	Yes	Yes	Yes	N/A	N/A	Pass
Elevator machine room	Above ceiling outside library	Butterfly	1 "	Monitored	Yes	Yes	Yes	Yes	N/A	N/A	Pass
Elevator shaft	Top of stairs before library	Butterfly	1 "	Monitored	Yes	Yes	Yes	Yes	N/A	N/A	Pass
Second floor	Above ceiling in library	Butterfly	3 "	Monitored	Yes	Yes	Yes	Yes	N/A	N/A	Pass
Elevator pit	Tank room	Butterfly	1 "	Monitored	Yes	Yes	Yes	Yes	N/A	N/A	Pass

DRY 1 (Dry)

Description	Location	Valve Type	Size	Secured	Open	Easily Accessible	Signs	Exercised	Stems Lubricated	Flow Pass	Tamper Pass
Attic	Sprinkler Room	Butterfly	4 "	Monitored	Yes	Yes	Yes	Yes	N/A	N/A	Pass
Tyco	Sprinkler Room	Dry Pipe Valve	4 "	Monitored	N/A	Yes	Yes	N/A	N/A	Pass	N/A

DRAIN VALVES

DRY 1 (Dry)

Description	Location	Drain	Aux Drain Drained	Water Flow Observed
Main Drain	Tank Room		N/A	Yes

Report of Inspection / Test

Frequency: Semi-Annual ITM

01-07-2026

Property

KESWICK VALLEY MEMORIAL - D14

20 ROUTE 617

BURTT'S CORNER NB E6L 2X3

WO Ref #: 6646172

Conducted by: Roy Barton
NB Sprinkler System Installer 10072972

Troy Life & Fire Safety Ltd
175 Henri Dunant Street
Moncton New Brunswick E1E 1E4
1-877-441-8769



Life & Fire Safety Ltd.

24 HR. SERVICE
1-877-441-8769

troylfs.com

Deficiencies - General Questions

None

Deficiencies - General Wet System Questions

None

Deficiencies - General Dry System Questions

None

Deficiencies - WET 1

None

Deficiencies - DRY 1

None

Deficiencies - Inspectors Test Connection

None

Deficiencies - Valves

None

Deficiencies - Drain Valves

None

Report of Inspection / Test

Frequency: Semi-Annual ITM

01-07-2026

Property

KESWICK VALLEY MEMORIAL - D14
20 ROUTE 617
BURTT'S CORNER NB E6L 2X3

WO Ref #: 6646172

Conducted by: Roy Barton
NB Sprinkler System Installer 10072972

Troy Life & Fire Safety Ltd
175 Henri Dunant Street
Moncton New Brunswick E1E 1E4
1-877-441-8769



Life & Fire Safety Ltd.

24 HR. SERVICE
1-877-441-8769

troylfs.com

Inspector Signature

I state that the information on this form is correct at the time and place of my inspection, and all equipment tested at this time was left in operational condition upon completion of this inspection except as noted.

Inspector Name	Signature	Date Completed
Roy Barton NB Sprinkler System Installer 10072972		2026-01-07

Food Premises Inspection Summary Report

Name of Premise: Compass Group - Keswick Valley Memorial School Address: 20 NB-617 Burts Corner NB E6L 2X3 Water Supply: Municipal	Licence #: 03-040087 Type: Class/Classe 4 Category: Routine Compliance Date of Inspection: January 16, 2026
--	--

MI - Minor infraction; MA - Major infraction; CR - Critical infraction; CDI - Corrected During Inspection; N/A - Not Applicable

OBSERVATIONS AND CORRECTIVE ACTIONS

Item	MI /MA/ CR	Remarks	Date for Correction
7.3	MI	If a chemical feed dishwasher is used, a suitable (food grade) sanitizer shall be available and at the recommended concentration. Observations: Chemical-feed dishwasher concentration was at about 25ppm of free available chlorine. The food handler was already aware of this issue and a work order has been submitted. Comment: <i>Where the dishwasher is malfunctioning, continue using single-use/disposable glasses or the three-compartment manual dishwashing method until the dishwasher has been repaired.</i>	Immediately

CLOSING COMMENTS

All outstanding infractions are to be corrected at the next routine inspection.

Rating colour: Green

Food Premises Inspection Report

Name of Premise: Compass Group - Keswick Valley Memorial School	Licence #: 03-040087
Operator: Vickie Morehouse	Type: Class/Classe 4
Address: 20 NB-617 Burtt's Corner NB E6L 2X3	Category: Routine Compliance
Water Supply: Municipal	Date of Inspection: January 16, 2026

Item no.	Description	CDI	R
----------	-------------	-----	---

1.0 FOOD

1.1	S	Approved Source	<input type="checkbox"/>	<input type="checkbox"/>
1.2	S	Purchasing and Receiving	<input type="checkbox"/>	<input type="checkbox"/>
1.3	S	Acceptable Containers and Labeling	<input type="checkbox"/>	<input type="checkbox"/>

2.0 FOOD STORAGE

2.1	S	Storage of Potentially Hazardous Foods	<input type="checkbox"/>	<input type="checkbox"/>
2.2	S	Frozen Storage	<input type="checkbox"/>	<input type="checkbox"/>
2.3	S	Refrigerated Storage (Temperature)	<input type="checkbox"/>	<input type="checkbox"/>
2.4	S	Refrigerated Storage (Methods)	<input type="checkbox"/>	<input type="checkbox"/>
2.5	S	Refrigerated Storage (Space)	<input type="checkbox"/>	<input type="checkbox"/>
2.6	S	Dry Storage	<input type="checkbox"/>	<input type="checkbox"/>
2.7	S	Storage of Food for Staff	<input type="checkbox"/>	<input type="checkbox"/>

3.0 FOOD PREPARATION AND HANDLING

3.1	N.O.	Thawing Methods	<input type="checkbox"/>	<input type="checkbox"/>
3.2	N.O.	Cooking Methods	<input type="checkbox"/>	<input type="checkbox"/>
3.3	N.O.	Holding Methods	<input type="checkbox"/>	<input type="checkbox"/>
3.4	N.O.	Cooling Methods	<input type="checkbox"/>	<input type="checkbox"/>
3.5	N.O.	Re-heating Methods	<input type="checkbox"/>	<input type="checkbox"/>
3.6	N.O.	Handling Methods	<input type="checkbox"/>	<input type="checkbox"/>

4.0 FOOD DISPLAY AND SERVICE

4.1	S	Display Methods	<input type="checkbox"/>	<input type="checkbox"/>
4.2	S	Advance Preparation	<input type="checkbox"/>	<input type="checkbox"/>

5.0 RECORD KEEPING AND RECALLS

5.1	N.O.	Record Keeping	<input type="checkbox"/>	<input type="checkbox"/>
5.2	N.O.	Recall of Food	<input type="checkbox"/>	<input type="checkbox"/>

6.0 PERSONNEL

6.1	S	Demonstrating Knowledge	<input type="checkbox"/>	<input type="checkbox"/>
6.2	S	Employee Health	<input type="checkbox"/>	<input type="checkbox"/>
6.3	S	Personal Hygiene Practices	<input type="checkbox"/>	<input type="checkbox"/>

7.0 FOOD EQUIPMENT AND UTENSILS

7.1	S	Food Equipment (Design, Construction, Installation and Maintenance)	<input type="checkbox"/>	<input type="checkbox"/>
7.2	S	Food Contact Surfaces	<input type="checkbox"/>	<input type="checkbox"/>
7.3	U	Mechanical Dishwashing	<input type="checkbox"/>	<input checked="" type="checkbox"/>
7.4	S	Manual Dishwashing	<input type="checkbox"/>	<input type="checkbox"/>
7.5	S	Eating Utensils and Dishes	<input type="checkbox"/>	<input type="checkbox"/>

Food Premises Inspection Report

Name of Premise:	Compass Group - Keswick Valley Memorial School	Licence#	03-040087
-------------------------	--	-----------------	-----------

8.0 CLEANING AND SANITIZING

- | | | | | |
|-----|---|---|--------------------------|--------------------------|
| 8.1 | S | Cleaning and Sanitizing | <input type="checkbox"/> | <input type="checkbox"/> |
| 8.2 | S | Detergents and Chemical Use and Storage | <input type="checkbox"/> | <input type="checkbox"/> |

9.0 SANITARY FACILITIES

- | | | | | |
|-----|---|-------------------------|--------------------------|--------------------------|
| 9.1 | S | Washroom(s) | <input type="checkbox"/> | <input type="checkbox"/> |
| 9.2 | S | Hand Washing Station(s) | <input type="checkbox"/> | <input type="checkbox"/> |

10.0 FLOORS, WALLS AND CEILINGS

- | | | | | |
|------|---|--|--------------------------|--------------------------|
| 10.1 | S | Floors (Construction and Maintenance) | <input type="checkbox"/> | <input type="checkbox"/> |
| 10.2 | S | Walls (Construction and Maintenance) | <input type="checkbox"/> | <input type="checkbox"/> |
| 10.3 | S | Ceilings (Constructions and Maintenance) | <input type="checkbox"/> | <input type="checkbox"/> |

11.0 WATER SUPPLY AND WASTE DISPOSAL

- | | | | | |
|------|---|------------------------------|--------------------------|--------------------------|
| 11.1 | S | Water (Quality and Quantity) | <input type="checkbox"/> | <input type="checkbox"/> |
| 11.2 | S | Sewage Disposal | <input type="checkbox"/> | <input type="checkbox"/> |
| 11.3 | S | Solid Waste Handling | <input type="checkbox"/> | <input type="checkbox"/> |

12.0 LIGHTING AND VENTILATION

- | | | | | |
|------|---|-------------|--------------------------|--------------------------|
| 12.1 | S | Lighting | <input type="checkbox"/> | <input type="checkbox"/> |
| 12.2 | S | Ventilation | <input type="checkbox"/> | <input type="checkbox"/> |

13.0 GENERAL

- | | | | | |
|------|---|---------------------------|--------------------------|--------------------------|
| 13.1 | S | Licence | <input type="checkbox"/> | <input type="checkbox"/> |
| 13.2 | S | Rodent and Insect Control | <input type="checkbox"/> | <input type="checkbox"/> |
| 13.3 | S | Other Infractions/Hazards | <input type="checkbox"/> | <input type="checkbox"/> |

N.O. - Not Observed; S - Satisfactory; U - Unsatisfactory; MI - Minor infraction; MA - Major infraction; CR - Critical infraction; CDI - Corrected During Inspection; R - Repeated infraction

OBSERVATIONS AND CORRECTIVE ACTIONS

Item	MI /MA/ CR	Remarks	Date for Correction
7.3	MI	If a chemical feed dishwasher is used, a suitable (food grade) sanitizer shall be available and at the recommended concentration. Observations: Chemical-feed dishwasher concentration was at about 25ppm of free available chlorine. The food handler was already aware of this issue and a work order has been submitted. Comment: Where the dishwasher is malfunctioning, continue using single-use/disposable glasses or the three-compartment manual dishwashing method until the dishwasher has been repaired.	Immediately

CLOSING COMMENTS

All outstanding infractions are to be corrected at the next routine inspection.

Rating color: **Green**



Received By: Sharon



Erin Lamey, Public Health Inspector



921 College Hill Road
 Fredericton, NB E3B 6Z9
 Canada
 Tel: 506.452.1212
www.rpc.ca

Certificate of Analysis

ASD-W (HZ3)
 250 King Street
 Fredericton, NB E3B 9M9

Report ID: 26-004067-MICRO
 Report Date: 2026-02-25

Attention: Contacts Education
Project: 26-004067
Location: n/a

Sample Received: 2026-02-23
Client Job Number: n/a
PO No.: n/a

Microbiological Examination of Water

			26-004067-1-1	26-004067-2-1	26-004067-3-1
RPC Sample ID					
Client Sample ID			23223- Harvey Elementary School DWS #2	23234- Keswick Ridge School DWS	23245- Harvey High School DWS
Matrix			Drinking Water	Drinking Water	Drinking Water
Date/Time Sampled			2026-02-23 07:17:00	2026-02-23 07:54:00	2026-02-23 07:05:00
Analyte	Units	RL			
Total Coliforms	P-A/100mL	-	A	A	A
E. coli	P-A/100mL	-	A	A	A
Heterotrophic Plate Count	MPN/mL	-	2	< 2	12

Cathy Hay
 Microbiology



Certificate of Analysis

Report ID: 26-004067-MICRO

Report Date: 2026-02-25

921 College Hill Road
Fredericton, NB E3B 6Z9
Canada
Tel: 506.452.1212
www.rpc.ca

ASD-W (HZ3)
250 King Street
Fredericton, NB E3B 9M9

Attention: Contacts Education
Project: 26-004067
Location: n/a

Sample Received: 2026-02-23
Client Job Number: n/a
PO No.: n/a

Microbiological Examination of Water

			26-004067-4-1	26-004067-5-1
RPC Sample ID			26-004067-4-1	26-004067-5-1
Client Sample ID			22855- Keswick Valley	26539- Hanwell Park
Matrix			Drinking Water	Drinking Water
Date/Time Sampled			2026-02-23 08:22:00	2026-02-23 09:13:00
Analyte	Units	RL		
Total Coliforms	P-A/100mL	-	A	A
E. coli	P-A/100mL	-	A	A
Heterotrophic Plate Count	MPN/mL	-	12	112



Certificate of Analysis

Report ID: 26-004067-MICRO

Report Date: 2026-02-25

921 College Hill Road
Fredericton, NB E3B 6Z9
Canada
Tel: 506.452.1212
www.rpc.ca

ASD-W (HZ3)
250 King Street
Fredericton, NB E3B 9M9

Attention: Contacts Education

Project: 26-004067

Location: n/a

Sample Received: 2026-02-23

Client Job Number: n/a

PO No.: n/a

Methods

Test	RPC SOP
Heterotrophic Plate Count	MICRO58
Total Coliforms and E. coli - Presence/Absence	MICRO10

Report Information

This report relates only to the sample(s) and information provided to the laboratory.

Reported results are expressed on an as-received basis.

Legend:

RL = Reporting Limit; MAC = Maximum Allowable Concentration; MPN = Most Probable Number; cfu = Colony-Forming Unit; gc/mL = genomic copies/mL; ug/L = micrograms per liter; P = present; A = absent; pp = presumptive positive; E = Estimate; ND = Not Detected; OG = Overgrown; TNTC = Too Numerous to Count

Summary of Date Analyzed:

RPC Sample ID	Test / Analysis	Date Extracted	Date Analyzed
26-004067-1-1	Heterotrophic Plate Count	-	2026-02-23
26-004067-1-1	Total Coliforms and E. coli - Presence/Absence	-	2026-02-23
26-004067-2-1	Heterotrophic Plate Count	-	2026-02-23
26-004067-2-1	Total Coliforms and E. coli - Presence/Absence	-	2026-02-23
26-004067-3-1	Heterotrophic Plate Count	-	2026-02-23
26-004067-3-1	Total Coliforms and E. coli - Presence/Absence	-	2026-02-23
26-004067-4-1	Heterotrophic Plate Count	-	2026-02-23
26-004067-4-1	Total Coliforms and E. coli - Presence/Absence	-	2026-02-23
26-004067-5-1	Heterotrophic Plate Count	-	2026-02-23
26-004067-5-1	Total Coliforms and E. coli - Presence/Absence	-	2026-02-23



Operating Permit - Elevating Device
Permis d'exploitation - Appareil élévateur

Issued under the Elevators and Lifts Act
Délivré en vertu de la Loi sur les ascenseurs et les monte-charge

Technical Inspection Services
Services d'inspection technique
Justice and Public Safety
Justice et sécurité publique

Permit No./N° de Permis: 1170-028

Issued To: **ANGLOPHONE WEST SCHOOL DISTRICT**
Délivré à:

Expiry Date: **2026/04/11**
Date d'échéance:

Mailing Address: **1135 PROSPECT ST**
Adresse d'envoi: **FREDERICTON NB**
E3B 3B9

Device No: **1170**
N° d'appareil:

Operating Address: **KESWICK VALLEY MEMORIAL SCHOOL**
Adresse d'appareil: **20 617 HWY**
BURTTS CORNER NB

Site No: **1559-01**
N° du site:

Type of Device: **PASSENGER ELEVATOR**
Type d'attraction: **ASCENSEUR**

Capacity: **1500** or **9** Persons
Capacité: ou Personnes

Description:
Description:

Chief Elevator Inspector/Inspecteur en chef des élévateurs



Fire Inspection Report
Rapport d'inspection d'incendie

Office of the Fire Marshal
Bureau du prévôt des incendies
Justice and Public Safety
Justice et sécurité publique

Inspection No.: 7100901
N° d'inspection:
Type: Fire Periodic Inspection
Sécurité-incendie - inspection périodique

Completed Date: 2025/09/18
Date complet:

Date Scheduled: 2025/11/06
Date fixée:

Site Id: 1559-01 PID#: N/A / S/O
Owner/Tenant: Anglophone West School
Client No: 166434
Location: 20 617 Hwy
Emplacement: Burtts Corner NB
Building: Keswick Valley Memorial School
Usage: School, elementary & middle
Occupancy: N/A / S/O

Installation No.: 162187
Roof Construction: Non combustible
Wall Construction: Non combustible
No Stores: 2
Ground Floor(m2): N/A
Basement: No/Non
Fire Alarm(Y/N): Yes/Oui
Occupant Load: 211
Year Constructed: N/A
Année de construction: S/O
Width (m): N/A
Largeur (m): S/O
Standpipe: No/Non
Conduite d'incendie: No/Non
Mat. dang.: No/Non
Connected to Monitoring Station: Yes/Oui

Table with 6 columns: Details, Status, Details, Status, Details, Status. Rows include items like Auto hold open devices, Electrical service room, Exit signs & lights, Fire alarm test log, Fire separations, Housekeeping/storage, Safety plans, Sprinkler maintenance.

VIOLATIONS/ORDERS/COMMENTS - INFRACTIONS/ORDERS/COMMENTAIRES

No storage in exits.
Quiet room door shall have a self-closing device installed and must fully close and latch after each use.
Recycling/garbage cans shall be non-combustible.
No storage in sprinkler room.
Comply by 16 Nov 2025.

Received By/Reçu par:
Position/Poste:
Orders Issued/Ordres émis:
Signature: [Signature]

Inspected By/Inspecté par: Forestell, Samuel (506) 440-6042
Date: 2025/09/18

Keswick Valley - Asbestos Reassessment 2026

Name:

Date:

LOCATION #	LOCATION DESCRIPTION	SYSTEM	SYSTEM COMPONENT	COMPONENT MATERIAL	COMPONENT ITEM	Quantity	Access	Good	Fair	Poor	Actions	Units	2024 Comments	2025 Comments	2026 Comments
3	Office Room 17	Ceiling		Texture Coat									Good	Good	Good
4	Stairwell 191	Wall		Plaster	Surface								Minor Cracking	Minor Cracking	Good
5	Class/Office 216 (Right of Mech)	Ceiling		Texture Coat									Good	Good	Good
		Wall		Plaster	Surface								Good	Good	Good
	Storage / Mechanical Room 217	Wall		Plaster	Surface								Many holes	Many holes	Good
6	Class / Office 218	Ceiling		Texture Coat									Good	Good	Fair
		Wall		Plaster	Surface								Good	Good	Fair
7	Class/ Office 219 (Opposite bathroom)	Ceiling		Texture Coat									Good	Good	Good
		Wall		Plaster	Surface								Good	Good	Good
8	Hallway 220	Wall		Plaster	Surface								Flaking on walls	Flaking on walls	Fair
9	Boys Washroom 221	Ceiling		Plaster									Cracks & holes over T bar	Cracks & holes over T bar	Fair
	Girls Washroom 222	Ceiling		Plaster	Surface								small cracks	small cracks	small cracks
		Wall		Plaster	Surface								small cracks	small cracks	small cracks
10	Class / Office 223 (beside girls washroom)	Ceiling		Texture Coat	Surface								Good	Good	Good
		Wall		Texture Coat	Surface								Good	Good	Good
	Class / Office 224	Ceiling		Plaster	Surface								crack	crack	Good
		Wall		Plaster	Surface								Good	Good	Fair
11	Ramp 226	Wall		Plaster	Surface								Good	Good	Good
12	Stairwell 226A	Wall		Plaster	Surface								Good	Good	Good
13	Stairwell 226B	Wall		Plaster	Surface								Good	Good	Good

14	Classroom 7 (left after ramp)	Wall	Plaster	Surface					Good	Good	Fair bulge/crack over door
15	Classroom 6 (right below ramp)	Wall	Plaster	Surface					Good	Good	Good
16	Classroom 8 (right mid)	Wall	Plaster	Surface					Good	Good	Good (bulge over closet)
17	Classroom 9 (left mid)	Wall	Plaster	Surface					Good	Good	good
18	Classroom 11 (left end)	Wall	Plaster	Surface					Good	Good	Good (spalled by router wire)
	Classroom 10 (right end)	Wall	Plaster	Surface					Good	Good	Good
19	Office 235 (Quiet Room)	Wall	Plaster	Surface					Good	Good	Fair
20	Washroom 235A (Quiet Room)	Wall	Plaster	Surface					Good	Good	Good
21	Hallway 236	Wall	Plaster	Surface					Good	Good	Good
22	Ramp 215	Wall	Plaster	Surface					crack close to washroom	crack close to washroom	Good
	Room 169								Good	Good	Good
	Room 170								Good	Good	Good
	Room 179								Floor replaced	Floor replaced	Floor replaced

PLAYSPACE MAINTENANCE / REPAIRS REPORT (ASD-W)

School / Playground: Keswick Valley

Maintenance Foreperson: Brian Stewart Date: August 26, 2025

Inspected by: Mike Barrieau Date: 8:30 - 10:00 am

Attention Required Item Number	Category	Equipment	Action Required (details)	Corrective Action Complete (Y or N)	Reviewed by Management
1	Cement	Swings.	Cement at swings by lift pump need covered		
2	Pea Gravel	under Swings	Pea Gravel needs tilled and raked under swing path		
3	Pea Gravel		Pea Gravel needs tilled everywhere		
4	Handles	Digger	Need plastic caps for both digger handles		
5	Hangers	Playstructure	Replace hangers on elevated Step/poles on Big Playstructure (5 units)		
6	Height.	Straight Slide	Exit height is 22" (1.57m high) * should be 7"-15" *		
7		Spiral Slide	* Condemed / compromised in every way *		
8	Chains	Swing	One chain needs replaced 3 rd swing in on 3 Bay set (shorter)		
9		Swing Sets	Both sets to close to Fence.		